

PWO:404:LGN:hf  
11000  
2 NOV 1981

From: Commanding General  
To: Commander, Atlantic Division, Naval Facilities Engineering Command,  
Norfolk, VA 23511 (Attn: Code 111/Mr. J. Kelley) 04

Subj: Relay Setting in Main Electrical Substation for MCAS(H), New River DEN

Ref: (a) PHONECON btwn Mr. James Kelley, NAVFAC Util Div, and Mr. Luther Norris,  
Public Works, MCB CLNC, on 29 Oct 81 404

Encl: (1) Contract Dwgs, Specifications and Relay Information

1. As requested in reference (a), we are urgently in need of the relay settings for the new electrical substation at MCAS(H), New River. There have been numerous instances when the main vacuum circuit breaker trips before a downstream circuit breaker trips. Included in this enclosure are the existing relay settings and the current transformer ratios. It is understood that this is only a temporary "fix" and that a complete electrical system analysis of the distribution system is to be made at a later date, at which time a complete coordination study will be made and the proper relay setting provided.

2. If you have any questions, please call Mr. Luther Norris at AV 484-3658 or FTS 676-3658.

R. E. CARLSON  
By direction ✓

Blind Copy to:  
AC/S, Fac (w/o encl)

