




Item # C

Item # 6



Interior Mixing Section



**INTERIOR MOTIONLESS MIXER**


Number of Stages 4 non-removable  
 Material of Construction 316SS 1/4" thick Plate

**HOUSING**

Material of Construction 316SS  
 Pipe 24" 1/4" thick 316SS welded ASTM A 312  
 End Connections 24" #150 RF50, ANSI B16.5, ASTM A 182 Grade F316

Weight of Complete Mixer 1550 lbs

<b>stata-tube Motionless Mixer</b>		<b>TAM Industries, Inc.</b>
U.S. Patent No. 4,093,198		P.O. Box 178, Imleytown, N.J. 08858 Call 609-259-9222
SCALE:	APPROVED BY:	DRAWN BY <u>JRH</u>
DATE: <u>5/26/85</u>		REVISED <u>(2)</u>
<u>Camp Lejeune</u>		
<u>Holcomb Blvd Water Treatment Pl.</u>		
<u>P/N 24-D23-D42</u>		DRAWING NUMBER



**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
 LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO. **81-C-1644** TRANSMITTAL NO. **55** DATE **6-5-85**

FROM CONTRACTOR  
**Harry Pepper & Associates, Inc.**

TO  
**Henry Von Oesen & Associates, Inc.**

PROJECT TITLE AND LOCATION  
**Holcomb Blvd Water Treatment Plant**  
**MCB, Cp Lejeune, North Carolina**

**CONTRACTOR USE ONLY**

**REVIEWER USE ONLY**

\*List only one specification division per form.

\*\*ACTION CODES

List only one of the following categories on each transmittal form,  
 and indicate which is being submitted

- Contractor Approved       OICC Approval       Deviation/Substitution For OICC Approval

- A-Approved  
 D-Disapproved  
 AN-Approved as noted  
 RA-Receipt acknowledged.  
 C-Comments  
 R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
11336		WATER TREATMENT EQUIPMENT			
1	6.3	Manufacturer's Data and Shop Drawings on Chlorine cylinder scales	4	RA	AB
2	6.5 b	Manufacturer's Data on Transfer Pump	4	RA	AB
3	6.5 c.x	Manufacturer's Data on Platform Scales	4	RA	AB
4	6.5 d	Manufacturer's Data on Metering Pumps	4	RA	AB
5	6.5 e	Manufacturer's Data and Shop Drawings on PH Controls	4	RA/C	AB
6	6.5 f	Manufacturer's Data on In-line mixer	4	RA	AB

CONTRACTOR'S COMMENTS

NOTE: A/E Item # 5 Please verify quantity and type.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC  
 ONE COPY TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

*Phil Reese*

DATE RECEIVED BY REVIEWER

6/6/85

FROM (Reviewer)

J. Robert Benson, Jr. P.E.

TO

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

"Minor corrections were made by the reviewer. The contractor is requested to update his copies of this submittal, acknowledge corrections below, and forward this submittal to the ROICC.

PH Controls appear to be proper type. Have supplier verify that sensor is suitable for installation in pipeline as shown on the drawings.

CORRECTIONS ACKNOWLEDGE:

Signature

Date

COPIES TO:  
 ROICC (2)  
 LANTDIV (1)  
 A-E (1)

DATE

6/10/85

SIGNATURE

*J. Robert Benson, Jr.*

8242-715

11 JUN 1985 12 35

*Handwritten notes at the top of the page, possibly including a name or title.*

ONE COPY TO BOLOD


*Handwritten signature or initials.*

NO.	DESCRIPTION	QTY	UNIT	PRICE	TOTAL
1	...	1	...	...	...
2	...	...	...	...	...
3	...	...	...	...	...
4	...	...	...	...	...
5	...	...	...	...	...
6	...	...	...	...	...
7	...	...	...	...	...
8	...	...	...	...	...
9	...	...	...	...	...
10	...	...	...	...	...

*Handwritten notes on the right side of the table, possibly including a name or additional details.*

...

...



Two (2) Sets of Chlor-Scale Model 12D40 to weigh the two ton cylinders shown above. The scale for each scale shall be 0 to 4000 **A/E VERIFY** pounds and shall be 12" in diameter.

Three (3) Sets of trunnions, a total of 6, to hold in storage the three ton cylinders shown above. Trunnions to be by Chlorine Specialties, Inc. Model C-256

Chlorine Scale Submittal  
 Holcomb Blvd. Water Treatment Plant  
 Camp LeJeune, North Carolina  
 Harry Pepper & Associates, Inc.  
 Purchase Order No. 642-0011  
 Contract No. N62470-81-C-1644

"It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut(s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

Approved for use.

Submitted for Government approval.

Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_

Signature CQC Rep. Phil Reese DATE 6-5-85


PLEASE ROUTE TO:  
Plant Superintendent   
Engineering Dept.   
Purchasing Dept.   
Maintenance Dept.


# CHLOR-SCALE<sup>®</sup>

HYDRAULIC LOAD CELL SCALE



**WEIGH  
TON CHLORINE  
CYLINDERS  
WITH EASE**






# CHLOR-SCALE

## Eliminates Hazards and Errors


The Force Flow CHLOR-SCALE was developed to fill an increasing need for weighing ton chlorine cylinders in municipal water treatment and sewage treatment plants. The plant operator can tell by glancing at the dial the amount of chlorine left in the cylinder. This allows a more accurate control of the chlorine used. Also, by knowing exactly the amount remaining, the operator may leave the plant and know that it will not run empty during his absence.


The dial can be remotely mounted out of the weather and away from corrosive chlorine fumes. For convenient reading some installations have dials mounted in the operator's control room. Installation is extremely simple, no pit or special installation personnel. Lag bolts secure the scale to the floor. Special heavy duty bushed trunnions allow the operator to easily position the cylinder outlet valve.

The heart of the scale is the rugged Hydraulic Load Cell System, consisting of a patented diaphragm sensing element filled with hydraulic oil, and a dial readout connected by a flexible hose. A built-in pressure snubber dampens shock loading thereby preventing damage to the dial. The accuracy of the load cell system is better than 1/2 of 1%.




The mobile self aligning diaphragm develops a piston-like stroke which provides temperature stability of the system. It is engineered so that one component cannot rub against another, eliminating friction and wear problems.






# MODELS AND ORDERING INFORMATION



## SCALES FOR ONE CYLINDER

MODEL*	DIAL DIAMETER (Inches)	DIAL CAPACITY (lbs)
6D40A	6	0-4000
8D40A	8 1/2	0-4000
12D40A	12	0-4000



## SCALES FOR TWO CYLINDERS

MODEL*	DIAL DIAMETER (Inches)	DIAL CAPACITY (lbs)
<del>6D80</del>	<del>6</del>	<del>0-8000</del>
<del>8D80</del>	<del>8 1/2</del>	<del>0-8000</del>
<del>12D80</del>	<del>12</del>	<del>0-8000</del>

\*Standard models are sized to accept standard ton chlorine cylinders; 2,000 lbs. chlorine and approximately 1,600 lbs. tare. Scales come complete with 25 ft. of hose. Specify special lengths up to 50 ft., for lengths over 50 ft., or recorders, controllers and alarms, please refer to Factory.

25' HOSE

### TYPICAL SPECIFICATION FOR CHLORINE SCALE

Chlorine scales shall be of the hydraulic cell type. Scale frame will be epoxy finished and sized to accept (1) or (2) 3,600 pound chlorine cylinders. It shall have required number of heavy duty bushed bearing trunnions installed for each cylinder to allow easy cylinder rotation. Frame shall tilt up for easy cleaning. Scale shall be of such a size that it is within the dimensions of the tank or tanks it supports.

Cell shall be of the temperature stable, rolling diaphragm type. Load plate shall be able to tilt to 4° without affecting accuracy to allow easy installation. Flexible hose shall lead from the cell to allow easy remote installation of the dial and shall be 25 feet in length.

Dial diameter shall be 12 inches and read zero to 4000 pounds with provision for tare adjustment. Dial shall be temperature stable with damper installed to prevent shock damage. Dial accuracy shall be better than 1/2 of 1%.

Scale shall be Chlor-Scale Model 12D40A as manufactured by Force Flow Equipment - 3467 Golden Gate, Lafayette, California, or equal.




**FORCE FLOW EQUIPMENT**

3467 GOLDEN GATE, LAFAYETTE, CALIFORNIA 94549  
(415) 284-2200

**Distributed By**


Litho in U.S.A.  
4735




## 6 STANDARD MODELS AVAILABLE

Depending on plant chlorine usage, scales are available to accommodate one or two 2,000 pound cylinders. Dial read-out on multiple tank units shows total weight of all tanks on scale. Each scale size available with 6, 8½, or 12 inch diameter dial.

ONE TANK MODEL



TWO TANK MODEL





Scale sized to take less floor space than tank.

Rugged load cell has few moving parts, no sensitive adjustments, no external power needed.

Heavy duty plated trunnions included on scale.

Minimum loss of monorail crane headroom.


Finished with chemical resistant epoxy paint.




Remote installation protects dial from weather and corrosive fumes. Convenient tare adjustment at dial.



Easily installed with lag bolts. No pit required.

Tilts for easy cleaning or inspection.





12" INCHES, DIAL DIA.  
25' FEET OF HOSE




**FORCE FLOW EQUIPMENT**  
 3487 GOLDEN GATE, LAFAYETTE, CALIFORNIA 94549

MODELS 6D40A, 8D40A, 12D40A  
 4000 LB. CHLOR-SCALES

DRAWN BY N.D.  
 DATE 9-16-67  
 REVISED 6-14-74  
 SCALE NONE

DRAWING  
 NUMBER  
**DWG**  
**28517**



PROVIDE THREE SETS (TOTAL OF SIX)




CHLORINE SPECIALTIES INC

## C-256 Chlorine Cylinder Trunnions

Simplify chlorine handling by using chlorine cylinder trunnions. Enables the operator to easily position correctly the outlet valves of chlorine, ammonia and sulphur dioxide cylinders.

- In addition, these trunnions provide support for and establish spacing of these cylinders in the storage room.

- **Features...** Especially designed and constructed for chlorine cylinder installations where maximum corrosion protection is required.



- $\frac{3}{4}$ " grey iron casting ... cadmium plated steel wheels with bronze bushings.

- Hollow slotted steel shaft, cadmium plated with alemite fitting for lubrication.


\* Trademark

**Service...** Chlorine Specialties Inc. carries these trunnions in stock.


**Specifications...** Simply specify TON CYLINDER TRUNNIONS • C-256

CHLORINE SPECIALTIES INC

123 HOLLOWAY AVENUE • SAN FRANCISCO, CA. 94112 • (415) 333-4822




Dimensions




TON CYLINDER TRUNNIONS • C-256

Typical Installation



**CHLORINE SPECIALTIES INC**

123 HOLLOWAY AVENUE • SAN FRANCISCO, CA. 94112 • (415) 333-4822



**DORR-OLIVER**

WORLD-WIDE RESEARCH • ENGINEERING • EQUIPMENT

**SPECIFICATIONS**

REFERENCE No.	DESCRIPTION	DATE	SUPERSEDES
	PUMPS - <del>Ø14</del> Ø2 1/2 <del>Ø14</del> ODS DIAPHRAGM	5-12-78	2-15-71
	WITH SPRING ASSIST		

**GENERAL DESCRIPTION**

The Dorr-Oliver ODS Pump with Spring Assist is an air actuated diaphragm pump. A compression spring mounted on the cover pulls the diaphragm up on the suction stroke, allowing operation on a negative suction lift of up to 10 ft. of water. Compressed air above the diaphragm forces the pumped liquid out on the discharge stroke, balancing the pressure on the diaphragm for up to 80 psi discharge pressure. During the discharge stroke the spring is compressed to provide the upward force to be used on the suction stroke. The positive action of the diaphragm increases the pump's capacity above that of the standard ODS pump. The Ø2 1/2 pump is the same as the Ø2, except it has a 3" suction valve for increased capacity.

**CONSTRUCTION***CASING AND WETTED PARTS 316 S.S.*

The body, base tee, spacers and check valves are cast iron, either unlined or lined, and are also available in 316 stainless steel. The cover, which is on the air side of the diaphragm, is always cast iron, unlined. The compression spring and operating rod are mounted vertically on the cover, enclosed by a pipe column with end cap. The operating rod is attached to the diaphragm by means of clamp plates. The standard diaphragm is Hypalon/Neoprene, with Neoprene, Nardel and Viton available.

**CHECK VALVES**

Furnished as Type Q quick-opening ball check with replaceable seat in 2" and 3" sizes only. When Type Q check valves are used on the Ø1 1/4 pump, 2" valves, base tee and spacers are supplied, together with a 2" x 1 1/4" reducer for the pump body. Type B in-line ball check valves are also available. Standard ball is the heavy ball at 2.3 SG, with a light ball 1.5 SG available. Type Q valves are lined or unlined; Type B are always lined. Type F flap check valves are furnished unlined in cast iron or 316 stainless steel.

**TIMER**

Standard timer is the Regent, which is a solid state electronic timer. Fill and discharge time are adjusted independently by means of 2 separate control knobs. Fill time is adjustable up to 10 seconds, while discharge time is adjustable up to 5 seconds. The enclosure is of Nema 4 rating.

SPECIAL OPTIONAL TIMERS ARE TABULATED ON PAGE 215.

**AIR HEADER**

Consists of a 3-way solenoid air valve with internal pilot and indicating light, air regulator, pressure-vacuum gage, air strainer and exhaust air muffler, also pipe and fittings as required to make a complete assembly.

**ENGINEERING DATA**

PUMP SIZE NUMBER	1 1/2	2	2 1/2	3	4
Max. Capacity (Nominal) GPM	15	35	42	120	150
Suction Valve Size	1 1/2	2	3	3	4
Discharge Valve Size	1 1/2	2	2	3	4
Displacement per Stroke (nominal), Gal.	4	1.1	1.1	3.8	3.8
Max. Cycles per min. (No. of strokes)	38	32	38	32	40
Max. Suction Lift, Ft. Water	10				
Max. Operating Air Pressure, PSI	100				
Air Header & 3-way Air Valve Size, In.	3/8		3/4		

NOTE: For additional data and information refer to reference drawings, lithos, bulletins, etc..... listed in the Sales Tool Index Book.

**Acid Transfer Pump Submittal**

Dorr-Oliver, Inc.  
 Holcomb Blvd. WTP  
 Camp LeJeune Water Treatment Plant  
 Harry Pepper & Associates, Inc.  
 Purchase Order No. 642-0011  
 Contract No. N62470-81-C-1644  
 Page 11336-8 thru 11336-10, paragraph b.

*Item #2*



STANDARD SPECIFICATION SHEET

ODS PUMPS

ORDER NO.	ITEM	QUANTITY
HARRY PEPPER	01	001
SERIAL NUMBER(S)		

PRODUCT CODE	SPECIFICATION CODE		
20911	012	Q20	10
	CODE A	CODE B	CODE C

CUSTOMER (USER)	
HOLCOMB BLVD WTP	
SHIPPING DATE	TO ASSEMBLY DATE

SEE TABLES BELOW

CODE A - BASIC PUMP

0	1	2
LINING	DIAPHRAGM	TYPE
0 OMIT	1 STD. HYPALON	0 WITHOUT DIAPHRAGM STOP
1 HYPALON	2	1 WITH DIAPHRAGM STOP
2	3 NORDEL	2 WITH SPRING ASSIST
3 NORDEL	4 VITON A	3 WITH CYLINDER ASSIST WITHOUT HINGE
		4 WITH CYLINDER ASSIST WITH HINGE

MATERIAL	NOMINAL SIZE	STANDARD	WITH SPRING ASSIST	WITH CYLINDER ASSIST
0 CAST IRON	X	00	10	
9 316 STN. ST.	2	01	11	
A LINED	X	02	12	
	X	03	15	13
	4	04	16	14

CODE B - CHECK VALVE ASSEMBLY \*

Q	TYPE	Z	MATERIAL/LINING CHECK VALVE	0	BALLS
0	OMIT	0	OMIT	0	HEAVY STANDARD
B	IN LINE BALL CHECK	1	CAST IRON	0	LIGHT OPTIONAL
F	FLAP CHECK	2	316 STN. ST.	0	MATERIAL
Q	QUICK OPENING	3	HYPALON	1	
		4		2	
		5	NORDEL	3	
				X	FOR FLAP CHECK VALVE ONLY.


NOTE \*


- SIZE 2B PUMP HAS 2" DISCHARGE AND 3" SUCTION CHECK VALVES
  - B IN-LINE BALL CHECK VALVES HAVE CAST IRON BODY WITH HYPALON OR NORDEL LININGS ONLY. FOR UNLINED PUMPS IN-LINE CHECK VALVE FURNISHED WITH HYPALON LINING
  - F FLAP CHECK VALVES ARE CAST IRON OR STAINLESS STEEL UNLINED ONLY
  - Q QUICK OPENING BALL CHECK VALVES AVAILABLE LINED OR UNLINED
- SEE REVERSE SIDE FOR ADDITIONS/ALTERNATIVES AND REMARKS

CODE C - AIR HEADER ASSEMBLY

1	SOLENOID VALVE		1	TIMER SELECTION
	SIZE	NEMA 4	EXPLOSION PROOF	0 OMIT
	OMIT	0	0	1 REGENT SOLID STATE NEMA 4 ENCL. (FILL 10.5 DISCH. 3.5)
	<del>3/8 STANDARD FOR 1 1/2 - 2" PUMPS</del>	1	A	STANDARD - ALTERNATIVES
	STANDARD FOR 2B, 3" AND 4" PUMPS OPTIONAL FOR 2" PUMPS	2	B	A REGENT SOLID STATE NEMA 4 ENCL. (FILL 5M. DISCH. 2.5)
	<del>1 1/2" OPTIONAL FOR 3" AND 4" PUMPS</del>	3	C	2 ELECTRO-MECH (TIME-O-MATIC) NEMA 4 ENCLOSURE.
	COMPLETE AIR HEADER FOR CYLINDER ASSIST	4		4 PACER SOLID STATE (UCC) NEMA 1 ENCL.
				5 PACER SOLID STATE (A.B.C.) NEMA 4 ENCL.
				X SPECIAL (ROUTE TO ENGINEERING)
				USE OMIT FOR TIMER SELECTION WHEN SELECTING A CYLINDER ASSIST PUMP.

F104







990E1010

**SOLENOID VALVE**

ENERGIZED      DE-ENERGIZED



BASIC PUMP SHOWN WITH AIR HEADER LOCATED FOR USE WITH DIAPHRAGM STOP OR SPRING ASSIST.  
FOR USE WITHOUT DIAPHRAGM STOP, LOCATE AIR HEADER IN CENTER BOSS TAPPED HOLE.

REDRAWN 3-15-84

ITEM NO.	QTY	AIR HEADER LESS SOL. VALVE ITEMS 1-15 P/N 20663-98A		AIR HEADER LESS SOL. VALVE ITEMS 1-15 P/N 20663-97B		AIR HEADER LESS SOL. VALVE ITEMS 1-15 P/N 20663-98A	
		PART NO.	DESCRIPTION	PART NO.	DESCRIPTION	PART NO.	DESCRIPTION
1	1	2523-018	3/4" X 3/4" REDUCING BUSHING	2523-018	3/4" X 3/4" REDUCING BUSHING	2523-018	3/4" X 3/4" REDUCING BUSHING
2	1	2526-044	3/4" X 90° ELBOW	2526-044	3/4" X 90° ELBOW	2526-044	3/4" X 90° ELBOW
3	1	2526-112	1/2" X 3/4" X 90° REDUCING ELBOW	2526-112	1/2" X 3/4" X 90° REDUCING ELBOW	2526-112	1/2" X 3/4" X 90° REDUCING ELBOW
4	0	2541-072	3/8" X 3" LG. NIPPLE	2541-100	1/2" X 3" LG. NIPPLE	2541-072	3/8" X 3" LG. NIPPLE
5	1	2541-226	1" X 3" LG. NIPPLE	2541-112	1/2" X 3" LG. NIPPLE	2541-196	1" X 3" LG. NIPPLE
6	2	2524-020	3/4" GROUND JOINT UNION	2524-008	3/4" GROUND JOINT UNION	2524-008	3/4" GROUND JOINT UNION
7	1	2530-004	3/4" STRAIGHT TEE	2530-008	1" STRAIGHT TEE	2530-002	3/4" STRAIGHT TEE
8	1	2523-062	3/4" X 1" HEXAGON HEAD REDUC. BUSHING	2523-016	1/2" X 1" HEXAGON HEAD REDUCING BUSHING	2523-046	3/4" X 1" HEXAGON HEAD REDUC. BUSHING
9	1	2541-082	1" X 1/2" LG. NIPPLE	2541-082	1" X 1/2" LG. NIPPLE	2541-082	1" X 1/2" LG. NIPPLE
10	1	X23-1025	0-100 PSI PRESSURE GAUGE / COCK	X23-1025	0-100 PSI PRESSURE GAUGE / COCK	X23-1025	0-100 PSI PRESSURE GAUGE / COCK
11	1	2430-128	3/4" BALL VALVE	2430-124	1/2" BALL VALVE	2430-126	3/4" BALL VALVE
12	1	2471-062	3/4" AIR FILTER	2471-060	1/2" AIR FILTER	2471-058	3/4" AIR FILTER
13	1	2440-042	3/4" AIR REGULATOR	2440-040	1/2" AIR REGULATOR	2440-038	3/4" AIR REGULATOR
14	1	2425-010	3/4" AIR MUFFLER	2425-010	1/2" AIR MUFFLER	2425-010	3/4" AIR MUFFLER
15	1	2421-088	1" FEMALE COCK BRZ.	2421-088	1" FEMALE COCK BRZ.	2421-088	1" FEMALE COCK BRZ.
16	1	2444-052	3/4" SOLENOID VALVE	2444-052	1/2" SOLENOID VALVE	2444-052	3/4" SOLENOID VALVE

- 1- THE 3/4" AIR HEADER IS STANDARD WITH NOS. 1 AND 2 PUMPS (20 SCFM MAX.)
- 2- THE 3/4" AIR HEADER IS STANDARD WITH NOS. 2 AND 20 PUMPS (65 SCFM MAX.)
- 3- THE 1/2" AIR HEADER IS STANDARD WITH NOS. 3 AND 4 PUMPS (250 SCFM MAX.)
- 4- ALL PIPING COMPONENTS ARE OF MALLEABLE IRON CLASS 150 BLACK FINISH.

THIS DRAWING SUPERSEDES DRAWING NOS. OICM649 AND OICM170


REV	DATE	BY	CHKD	DESCRIPTION
1	3-15-84	EDG	WJC	REDRAWN
2	3-15-84	WJC	WJC	REVISED
3	3-15-84	WJC	WJC	REVISED

AIR HEADER ARRGT FOR GRAVITY FILL AND SPRING ASSIST ODS PUMP 2/2/84 4/2/84	6331 OICM1065
--	------------------

OICM1065





PUMP SIZE	NO-1 1/2	NO-2	NO-3	NO-3B	NO-4
MAX. CAPACITY PER STROKE	0.4	1.1	1.1	3.8	3.8
MAX. STROKES PER MINUTE	36	32	30	32	40
RATED G.P.M. MAX.	75	35	42	120	152
MAX. SUCTION LIFT IN FEET	10	10	10	8	8
SLURRY VALVE - INLET	2	3	3	4	4
SLURRY VALVE - OUTLET	2	2	3	4	4
D	4 1/8	4 7/8	5 1/8	6 1/8	6 1/8
E (APPROX.)	59	59	70	70	70
F	3 1/4	3 1/4	7 1/2	6	6
FF	3 1/4	3 1/4	7 1/2	6	6
J	7 3/8	8 1/8	8 1/8	10 1/4	10 1/4
JJ	7 3/8	7 3/8	8 1/8	10 1/4	10 1/4
K	16 1/2	16 1/2	24 1/2	24 1/2	24 1/2
M	4 1/8	4 1/8	4 1/8	5 1/2	5 1/2
N	6 1/2	6 1/2	8	8	8
P	4 1/2	4 1/2	6	10	10
Q	2 3/8	2 3/8	3 1/8	3	3
R	1 1/2	1 1/2	2 1/8	4	4
S	5/8	5/8	3/4	7/8	7/8
T (MIN.)	16 1/8	14 1/8	23 1/8	25 3/8	25 3/8
U	9 1/4	9 1/4	12	12 3/4	12 3/4
V	1 1/8	1 1/8	1	1	1
W (MIN.)	16 1/8	16 1/8	23 1/8	25 3/8	25 3/8
X	3 1/4	3 1/4	3 1/4	3 1/4	3 1/4
WW	4 1/2	-	5 1/2	6 1/2	6 1/2
XX	2 3/4	-	3 1/4	3 5/8	3 5/8
ZZ	4 5/8	-	5 5/8	6 5/8	6 5/8

AVAILABLE ONLY AS SPECIAL NO-1 1/2 PUMP WITH 2" VALVE - SEE DWG. 01C12118

- NOTES:
- ALL FLANGED CONNECTIONS ARE AMERICAN STANDARD 125 LBS. HOLES STRADDLE CENTER LINES.
  - ALL DIMENSIONS ARE IN INCHES UNLESS OTHERWISE SPECIFIED.
  - 2x3 REDUCER SUPPLIED BY DORR OLIVER ON 2B PUMP ONLY. SPACER SUPPLIED WITH OTHER PUMPS.
  - RATED CAPACITIES ARE FIGURED AT 10 P.S.I. DISCHARGE HEAD AT DATUM LINE WHEN HANDLING WATER, AT SUCTION LIFT SHOWN IN TABLE.

REV.	DESCRIPTION	DATE	BY	CHECKED	APPROVED	MATERIAL	SPECIFICATION	PART NUMBER
6	REV. PER ECA 12-1256	11.9.1						
5	REV. PER ECOI-7892	NOV 28 1970						
4	REV. PER ECN 01-6538	NOV 28 1970						
3	REV. PER ECN 01-6415	NOV 28 1970						
2	REV. PER ECN 01-6056	NOV 28 1970						
1	PUMP DATA ECN 01-5783	NOV 28 1970						

METRIC: SEE DWG. 12C10531

44116-  
PICS No. 24000

UNLESS OTHERWISE SPECIFIED  
DIMENSIONS ARE IN INCHES/16 PART  
TOLERANCES ARE AS FOLLOWS:  
FRACTIONS  
DECIMALS  
MILLIS

DORR OLIVER  
CORPORATION  
1110  
1110

NO. 1 1/2, 2, 2B, 3 & 4 O.D.S. PUMP  
SPRING ASSIST  
TYPE "O" BALL CHECK VALVE  
OUTLINES & DIMENSIONS

01-5687

01C12118

APR 15 1970



0990102

PUMP SIZE	PART NO. KIT ASSY	DIMENSIONS					REMARKS
		A	B	C	D	E	
1 1/2"	12C10553-01	6 1/2"	5 1/2"	2"	7/8"	2 1/4"	
2 (2B)	12C10552-01	8 3/4"	7 1/4"	2 1/2"	1"	3 1/4"	
3 1/4"	12C10551-01	10 1/8"	9 1/2"	3"	1 1/4"	5 1/2"	


**A. COMPONENTS INCLUDED IN THE STROKE INDICATOR KIT**

A SENSOR TRANSPARENT TUBE SCREWED TO THE SPRING COLUMN TUBE CAP AND A STROKE INDICATOR ROD.

- 1) PART NUMBER 12C10551-01
- 2) PART NUMBER 12C10552-01
- 3) PART NUMBER 12C10553-01

**B. INSTALLATION INSTRUCTIONS**


1. REMOVE THE SPRING COLUMN TUBE CAP AND DISCARD.
2. REMOVE THE SPRING COLUMN TUBE. THIS MAY NOT BE NECESSARY DEPENDING ON THE TYPE OF TOOLS AVAILABLE TO GET ACCESS TO THE STROKE INDICATOR NUT.
3. VERIFY THAT ALL EXPOSED PARTS ARE IN GOOD WORKING ORDER.
4. ADD GREASE TO THE SPRING AS REQUIRED (SEE YOUR INSTRUCTION MANUAL UNDER LUBRICATION).
5. INSTALL THE STROKE INDICATOR ON TOP OF THE OPERATING ROD, FASTEN UNTIL YOU ARE REASONABLY SURE THAT THE HEX. NUT HAS BOTTOMED OUT ON THE OPERATING ROD.
6. REPLACE THE SPRING COLUMN TUBE AND SCREW INTO THE ADAPTER, HAND TIGHTEN PLUS TWO (2) REVOLUTIONS, OR SAME AS YOU HAD BEFORE.
7. INSTALL THE NEW CAP WITH ITS TRANSPARENT INDICATOR TUBE, HAND TIGHTEN PLUS TWO (2) REVOLUTIONS.
8. TURN PUMP ON AND CHECK THAT YOUR PUMP STROKES THE FULL REQUIRED STROKE (SEE ABOVE TABLE DIM. 'A')
9. IF PUMP DOESN'T OPERATE CORRECTLY, CHECK: AIR PRESSURE SETTING, SUCTION AND DISCHARGE TIMER SETTING, SPRING PRELOAD SETTING, PROCESS FLOW CONDITIONS, EXHAUST MUFFLER CONDITIONS, ETC... (CONSULT YOUR INSTALLATION, OPERATION AND MAINTENANCE MANUAL FOR ALL THESE ADJUSTMENTS)



PROVIDED ON EACH PUMP

NO. OF PAGES	DATE FILED	OFFICE OF ORIGINATOR	REF. NUMBER
SPRING ASSIST O.D.S. PUMP STROKE INDICATOR KIT CUSTOMER INSTRUCTION			12D10560
CONTACTED BY: [ ] CONTACTED AT: [ ] CONTACTED BY: [ ] CONTACTED AT: [ ]			

G102.4



**DISTILLATION INSTRUCTIONS**

1. WHEN DISASSEMBLING PUMPS, THE FOLLOWING PRECAUTIONS MUST BE OBSERVED TO PREVENT INJURY:

AIR PRESSURE MUST BE VENTED COMPLETELY FROM THE COVER BEFORE REMOVING.

DISCONNECT THE ELECTRICAL SUPPLY WHICH WILL DE-ENERGIZE THE 3-WAY SOLENOID. THIS WILL SHUT OFF THE AIR SUPPLY AND ALLOW TRAPPED AIR IN THE COVER TO ESCAPE.

PUMPS AND CHECK VALVES MUST BE ISOLATED FROM THE REST OF THE SYSTEM AND BE EMPTIED.

- REMOVE OLD PUMP COVER AND DIAPHRAGM. TRANSFER INVEPLATE FROM OLD COVER TO NEW COVER. DISCARD OLD COVER AND DIAPHRAGM.
- CLEAN AND INSPECT INTERIOR OF PUMP BODY.
- ASSEMBLE SPRING ASSIST KIT (AS RECEIVED) TO PUMP BODY. TIGHTEN FLANGE BOLTS IN AN ALTERNATE SEQUENCE TO EVENLY CLAMP THE PERIPHERY OF THE DIAPHRAGM. REFER TO INSTRUCTION MANUAL PH-002 FOR SPRING ADJUSTMENT PROCEDURE.
- USE PROPER START-UP PROCEDURE PER INSTRUCTION MANUAL PH-002.
- FOR ALL FUTURE USE, REFER TO INSTRUCTION MANUAL PH-002 AND DISCARD THE OLD MANUAL.

\* 92 $\frac{1}{2}$  AND 42 ARE REQUIRED WHEN PUMP IS FULLY ASSEMBLED TO REMOVE THE SPRING COLUMN TO ITEM B  
52 AND 26 ARE REQUIRED TO REMOVE SPRING ASSEMBLY AND COVER PUMP


**TABLE I**

NOMINAL PUMP SIZE	PRODUCT CODE	SPEC. CODE SPRING ASSIST KIT	DIAPHRAGM AND LOWER CLAMP	PICS SHIP/CTN
1 $\frac{1}{2}$ "	20D10	P20138-	01A HYPALON	44116-000
			02A NEOPRENE	44116-002
			03A NORDEL	44116-004
			04A VITON	44116-006
2"	20D11	P20138-	05A HYPALON	44116-008
			06A NEOPRENE	44116-010
			07A NORDEL	44116-012
			08A VITON	44116-014
2B	20D12			


**EXAMPLE:**

2 VITON KIT WOULD BE SPECIFIED THUS;

20D11 P20138-08A



PRODUCT CODE SPEC. CODE DIAPHRAGM LWR. CLAMP



ITEM	QTY	UNIT	PK. NO.	PART. PK. NO.	DESCRIPTION
			1 1/2	2 AND 2B	
1	1		01D13349-01	01D13350-01	COVER
2	1		01B12039-01	01B12017-01	UPPER CLAMP
3	1		01A15322-01	01A15323-01	STOP COLLAR
4	1		01B12192-01	01B12193-01	OPERATING ROD
5	1		01B12051-01	01B12056-01	SPRING COLUMN ADAPTER
6	2		01A15060-01		SPRING
	4			01A15060-02	
7	1		01B12044-01	01A12044-02	ROD GUIDE
8	1		01A15049-01	01A15049-02	SPRING COLUMN TUBE
9			2672-012	2672-018	PIPE CAP
10	2		2183-058	2183-066	JAM NUT
11	1		2001-168	2001-168	WASHER-STD-ROD GUIDE
12	1		NOT REQ'D.	01A15050-01	SPRING SEAT
13	1		01A15045-01	01A15041-01	ROD GUIDE BUSHING
14	2		01A15384-01	2041-080	RETAINING RING
15	1		01A15450-01	01A15450-01	SPANNER WRENCH
			01B12189-01	01B12189-01	-DIAPHRAGM-
16			HYP NEO-OR	NORDEL-04	MAT'L-AS SPECIFIED
			NEOPRENE-03	VITON-05	
			01B12052-01	01B12053-01	-LOWER CLAMP-
17			HYPALON-02	NORDEL-04	MAT'L-CAST IRON AND
			NEOPRENE-03	VITON-05	AS SPECIFIED
18	1		B-609-1	B-609-1	LABEL-WARNING

USE ONLY WHEN CONVERTING FROM OTHER ODS TYPES TO SPRING ASSIST.


**NOTE:**

1-SPRINGS MUST BE THOROUGHLY COATED WITH GREASE. GREASE RECOMMENDED IS DORR-OLIVER PICS NO. 1080-002 OR 1080-202. (MOBILPLEX 47 OR EQUIVILANT)

DIAPHRAGM	LOWER CLAMP	DIAPHRAGM	LOWER CLAMP
VITON	P20138-08A	VITON	P20138-08A
NORDEL	P20138-07A	NORDEL	P20138-07A
NEOPRENE	P20138-06A	NEOPRENE	P20138-06A
HYPALON	P20138-05A	HYPALON	P20138-05A
VITON	P20138-04A	VITON	P20138-04A
NORDEL	P20138-03A	NORDEL	P20138-03A
NEOPRENE	P20138-02A	NEOPRENE	P20138-02A
HYPALON	P20138-01A	HYPALON	P20138-01A

ITEM	QTY	UNIT	PK. NO.	DESCRIPTION
2	1		ECA 12-1301	SPRING ASSIST KIT
1	1		ECA 12-1181	1 1/2, 2 AND 2B ODS PUMP
				4-27-81
				12D10541
				ECA 12-11-7

C102.2







**NOTES:**

AIR HEADER ASSEMBLY DWG. NO. 01D13065


CHECK VALVE ASSEMBLY DWG. NO. 01D13062

2 1/2" B SPRING ASSIST ASSEMBLY DWG. NO. 01D12889

3 1/4" B SPRING ASSIST ASSEMBLY DWG. NO. 01D13139

**PARTS LIST**

ITEM NO.	DESCRIPTION
1	CASING (BODY)
4	BASE (TEE)
67S	CHECK VALVE ASSEMBLY
72	FLANGED SPACER
78	GASKET
141	ELBOW
173	SPRING ASSIST ASSEMBLY (SEE NOTES)
191	FLANGED REDUCER
186	ELECTRIC TIMER



SPECIFY FOR LINED OR UNLINED PUMP

REV	DATE	BY	CHKD	APP'D	DESCRIPTION
4		ECA 12-217	UD		
3		ECN 01-6538	CV		
2		ECN 01-6415	CV		
1		ECN 01-6262	CV		

AND WELDING SYMBOLS SHOWN  
MACHINE FRACTIONAL DIMENSIONS 2 D SHIP  
MACHINE FINISHED TO A.S.A. STANDARDS

2,2B,3&4 O.D.S. PUMPS  
SPRING ASSIST-LINED OR UNLINED  
QUICK OPENING CHECK VALVE  
CROSS SECTION & PARTS LIST

DRAWN 6-25-70 BY C.V. SCALE 1/2" = 1"  
CHECKED BY C.V.  
DATE 6-25-70

THIS PRINT IS SUBJECT TO RETURN UPON DEMAND  
AND IS LOANED UPON THE EXPRESS CONDITION  
THAT IT IS NOT TO BE USED DIRECTLY OR IN  
DIRECTLY IN ANY WAY DETRIMENTAL TO  
THE INTERESTS OF


**DORR-OLIVER**  
INCORPORATED  
STAMFORD, CONNECTICUT, U.S.A.

ISSUED 8/3/57  
DORR-OLIVER  
01C12183

APR 5 1968  
MAY 22 1971  
MAY 13 1971  
MAY 3 1971  
MICROFILMED  
AUG 3 1970

01C12183

G107





## DAY TANK FILL SYSTEM

IN THE MANUAL MODE, the operator can simply turn on the pump let it run until he receives the desired volume.


IN THE AUTO MODE, the operator will simply push the reset switch to obtain a fixed volume of acid to be delivered to the day tank.

The Dorr-Oliver ODS pump delivers 1.1 gallons with each stroke of the pump. Let's assume the operator never wants to overfill the tank so he sets the predetermining counter in panel a for 100 strokes. When the level in the acid tank gets low, the operator would have the switch on Panel "A" switched into Auto Mode and push the reset button. The pump would deliver 100 strokes, (110 gallons) to the day tank and quit. Next time the operator sees the tank level low, he repeats the process by pushing the reset button. The predetermining counter will allow the owner to adjust the volume automatically pumped by adjusting the predetermining counter to the number of strokes desired before the pump stops. Detailed wiring panel drawings to follow.










# COMPRESSED AIR REQUIREMENTS



ENTER CURVE FROM A TO B. DROP DOWN TO C AT INTERSECTION OF REQUIRED SUCTION LIFT D. READ CFM'S ON CURVED LINE. INTERPOLATE IF NECESSARY.  
CALCULATE COMPRESSOR HP AS 1 HP PER 4 CFM


*AT 329pm, AIR CONSUMPTION ± 175 CFM @ 60 psi*

### RATED CAPACITIES OF ODS PUMPS CONNECTIONS

MODEL	MAX. GPM	INLET	DISCHARGE	MAX. SUCTION
1 1/2 G	15	1 1/2"	1 1/2"	10'
2S	35	2"	2"	10'
2BS	42	3"	3"	10'
SS	120	6"	3"	8'
4S	152	7"	4"	8'

### AIR COMPRESSOR SELECTION 60 - 100 PSIG OPERATION


MODEL	HP	CFM
5ED8R	5	21.4
10EU12R	10	42.2
15BN12R	15	67.5
20BN24R	20	84.5
25BN24R	25	98.0



Two-stage tank-mounted unit with water-cooled aftercooler and belt guard.









PLATFORM SCALES TO WEIGH THE 200 GALLON DAY TANK

A reinforced 1/4" plate steel platform as shown below shall be mounted over a fixed support hydraulic load cell type scale to weigh up to 4000 pounds and indicate on a 12" diameter dial type indicator which can be wall mounted up to 25 feet away from the tank. Scales similar to the type proposed for weighing the ton cylinder of chlorine. Scales to be Emery Type 711-4-12.



Contract No. N62470-81-C-1644  
Holcomb Blvd. Water Treatment Plant  
Camp LeJeune, N. C.  
Harry Pepper & Associates, Inc.  
Purchase Order No. 642-0011  
Page 11336-10, Paragraph c.



# Emery

## CHLORINE CYLINDER SCALE

4000 lbs. & 8000 lbs.

Series 711

These scales monitor the use of chlorine in municipal water treatment and sewage plants. The dial indicates the weight of chlorine left in the cylinder at any time, allowing the operator to schedule replacement cylinders when needed. At the same time, the scale provides an accurate control of chlorine usage. Features of this scale are described below:

**SUPER RUGGED CONSTRUCTION** — high sustained accuracy, sensitivity, and stability under severe conditions of shock, vibration, moisture, corrosion, and dust because of the famous Emery hydraulic load cell, heart of its weighing system.

**WEAR-FREE OPERATION** — no knife edges or bearings to wear, corrode, or replace; scale keeps its initial sensitivity indefinitely.

**WASH OR STEAM IT DOWN** — without hurting it; the scale is practically impervious to environmental hazards; it can be abrasive-cleaned, too.

**IMMUNE TO POWER FAILURE** — this is a completely self-contained hydraulic weighing system when used with the analog dial . . . no electrical components.




**1/4 OF 1% ACCURACY** — of full scale reading, sustained indefinitely.


**REMOTE DIAL LOCATION** — adaptable for wall, panel, or pedestal mounting remote from the weighing site (up to 100').

**VIRTUALLY SERVICE-FREE** — no moving parts in the scale . . . very little can go wrong.

**EASY INSTALLATION** — scale comes completely fabricated, ready to set into place.

**OPTIONS** — low level alarm; dial pedestal; digital indicator; rate-of-usage recorders; extra-length tubing.





# SPECIFICATIONS AND DIMENSIONS






TABLE OF MODELS AND CAPACITIES

SCALE FOR ONE CYLINDER		
Model Number	Dial Diameter	Dial Capacity (lbs.) (*)
711-4-8	8 1/2"	4000 X 10
711-4-12	12"	4000 X 10
711-4-16	16"	4000 X 5
711-4-20	20"	4000 X 5
SCALES FOR TWO CYLINDERS		
711-8-8	8 1/2"	8000 X 20
711-8-12	12"	8000 X 20
711-8-16	16"	8000 X 10
711-8-20	20"	8000 X 10

\* Dials available in metric units.

## DESCRIPTION OF SCALE

**FRAME** — fabricated from high strength tubular steel members; designed for maximum rigidity to prevent flexing.

**SUPPORTING FRAME TRUNNIONS** — for easy cylinder positioning; designed especially for a chlorine atmosphere environment.

**THREE-POINT SUSPENSION** — two ball-type pivots and an Emery hydraulic load cell make up the weight sensing system. Pivots and load cells are totally enclosed and virtually unaffected by environmental hazards. Scales for two cylinders have a five-point suspension; each scale has two ball-type pivots, with the weight sensing for both being done by a common load cell.

**DIAL** — with white face and black numerals; temperature compensated; tare adjustment; tubing and fittings furnished for location up to 25' from the scale (or further if required).

**FINISH** — all metal surfaces are coated with corrosion-resistant finish at the factory.

## STANDARD SPECIFICATIONS FOR AN EMERY CHLORINE SCALE

The chlorine scale shall be designed to accept one or two 4000 pound chlorine cylinders, sized within the dimensions of the tank or tanks it supports.

The scale shall be pivoted on totally enclosed ball pivots and a diaphragm type hydraulic load cell, capable of sustaining shock loads of 300% of indicator capacity.

The dial indicator size shall be 12" inches, with a capacity of 4000 ~~or 8000~~ pounds with a 50% tare adjustment capability. The dial indicator shall be temperature stable, with an accuracy of 1/4 of 1%.

The scale frame shall be constructed of high strength tubular steel for absolute rigidity, finished with a primer and two coats of corrosion-resistant epoxy paint.

The scale shall include no less than 25 ft. of flexible, polyethylene-coated, copper tubing to allow for easy remote location of the indicator.

The scale shall be an Emery Model 711-4-12 or approved equal.


## ABOUT THE EMERY HYDRAULIC LOAD CELL

Heart of every Emery weighing system is the famous Emery Hydraulic Load Cell. This unique weight sensing device, virtually indestructible, approaches the ultimate in durability, sustained accuracy, sensitivity, and stability. The world's largest Universal Testing Machine at the National Bureau of Standards uses Emery Hydraulic Load Cells. The cell has design refinements that give it high accuracy capability and resistance to severe environmental conditions such as shock, vibration, corrosion, and moisture (it will even function under water). It will take up to 300% overload.

## THE A. H. EMERY COMPANY

70 PINE ST. · P.O. BOX 608  
NEW CANAAN, CONNECTICUT 06840  
203-966-4551  
CABLE ADDRESS: AHEMCO

YOUR REPRESENTATIVE IS:



Item # 4

# Neptune


CHEMICAL PUMP COMPANY

Division of R. A. Industries, Inc.


Lansdale, PA 19446 • 215-699-8701 Telex: 84-6117

**Neptune Series 500 and 500-A "dia-PUMPS"**  
are products of innovative design and quality  
workmanship which offer long-term reliability.


525-S-N1



515-S-N3-TE1-PC



560-S-N1



Power train  
operates in oil  
bath for extended  
service.

Hydraulically  
balanced Teflon  
diaphragm elimi-  
nates diaphragm  
stress associated  
with mechanically  
flexed units.

Valve cartridges  
can be removed  
for cleaning  
without disturbing  
the piping to the  
pump.

Adjustable while  
running through  
100% of range by  
micrometer dial.

Vent-refill  
mechanism  
operates once  
per stroke.

Internal relief valve standard to safeguard  
pump.

Two (2) Neptune Model 532-S-N3 metering pumps with stroke control to respond to the pH analyzers. Pumps to produce 11 gphr at 350 psi maximum, 72 strokes per hour, and be equipped with automatic stroke positioning capabilities. Motor to be 1/4 Hp 120 Volts/ 60Hz/ 1 phase.


ACID METERING PUMPS

Holcomb Blvd. WTP




Harry Pepper & Associates, Inc.

Contract No. N62470-81-C-1644

Purchase Order No. 642-0011



# NEPTUNE SERIES 500 "dia-PUMP"




## NEPTUNE SERIES 500 "dia-PUMP" SELECTION CHART

Standard Motor 1/3HP-1ph-115v-60c-TENV

MODEL NUMBER	CAPACITY GPH AT 100 PSI	MATERIALS OF CONSTRUCTION	PRESSURE PSI	PISTON DIAMETER	STROKES PER MINUTE	STYLE	SHIPPING WEIGHT LBS.
500-S-N1 500-S-N3 500-S-N4 500-S-N5	<i>Handwritten mark</i>	Cast Iron 316SS C-20 PVC	1000 1000 1000 150	0.500	37	Simplex	60
510-S-N1* 510-S-N3* 510-S-N4* 510-S-N5*	1.0	Cast Iron 316SS C-20 PVC	700 700 700 150	0.500	37	Simplex	60
515-S-N1 515-S-N3 515-S-N4 515-S-N5	3.0	Cast Iron 316SS C-20 PVC	1100 1100 1100 400	0.500	117	Simplex	60
515-S-N3-HP 515-S-N4-HP	3.0 (2.0 at 1800 psi)	316SS C-20	1800 1800	0.500	117	Simplex	60
500-D-N1 500-D-N3 500-D-N4 500-D-N5	1.0 Ea. Head	Cast Iron 316SS C-20 PVC	1000 1000 1000 150	0.500	37	Duplex	80
510-D-N1* 510-D-N3* 510-D-N4* 510-D-N5*	1.0 Ea. Head	Cast Iron 316SS C-20 PVC	700 700 700 150	0.500	37	Duplex	80
515-D-N1 515-D-N3 515-D-N4 515-D-N5	3.0 Ea. Head	Cast Iron 316SS C-20 PVC	1100 1100 1100 400	0.500	117	Duplex	80
515-D-N3-HP 515-D-N4-HP	3.0 Ea. Head (2.0 at 1800 psi)	316SS C-20	1800 1800	0.500	117	Duplex	80
520-S-N1 520-S-N3 520-S-N4 520-S-N5	2.0	Cast Iron 316SS C-20 PVC	700 700 700 400	0.687	37	Simplex	60
525-S-N1 525-S-N3 525-S-N4 525-S-N5	7.0	Cast Iron 316SS C-20 PVC	900 900 900 400	0.687	117	Simplex	60
520-D-N1 520-D-N3 520-D-N4 520-D-N5	2.0 Ea. Head	Cast Iron 316SS C-20 PVC	700 700 700 400	0.687	37	Duplex	80
525-D-N1 525-D-N3 525-D-N4 525-D-N5	7.0 Ea. Head	Cast Iron 316SS C-20 PVC	900 900 900 400	0.687	117	Duplex	80
530-S-N1 530-S-N3 530-S-N4 530-S-N5	5.5	Cast Iron 316SS C-20 PVC	350 350 350 300	1.062	37	Simplex	60
532-S-N1 532-S-N3 532-S-N4 532-S-N5	11.0	Cast Iron 316SS C-20 PVC	350 350 350 300	1.062	72	Simplex	60
535-S-N1 535-S-N3 535-S-N4 535-S-N5	18.0	Cast Iron 316SS C-20 PVC	350 350 350 300	1.062	117	Simplex	60
538-S-N1 538-S-N3 538-S-N4 538-S-N5	26.5	Cast Iron 316SS C-20 PVC	350 350 350 300	1.062	175	Simplex	60

\*(See Page 3)



# NEPTUNE SERIES 500 "dia-PUMP" SELECTION CHART (Continued)

## Standard Motor 1/3HP-1ph-115v-60c-TENV

MODEL NUMBER	CAPACITY GPH AT 100 PSI	MATERIALS OF CONSTRUCTION	PRESSURE PSI	PISTON DIAMETER	STROKES PER MINUTE	STYLE	SHIPPING WEIGHT LBS.
530-D-N1 530-D-N3 530-D-N4 530-D-N5	5.5 Ea. Head	Cast Iron 316SS C-20 PVC	350 350 350 300	1.062	37	Duplex	80
532-D-N1 532-D-N3 532-D-N4 532-D-N5	11.0 Ea. Head	Cast Iron 316SS C-20 PVC	350 350 350 300	1.062	72	Duplex	80
535-D-N1 535-D-N3 535-D-N4 535-D-N5	18.0 Ea. Head	Cast Iron 316SS C-20 PVC	350 350 350 300	1.062	117	Duplex	80
538-D-N1 538-D-N3 538-D-N4 538-D-N5	26.5 Ea. Head	Cast Iron 316SS C-20 PVC	350 350 350 300	1.062	175	Duplex	80
560-S-N1 560-S-N3 560-S-N4 560-S-N5	20.0	Cast Iron 316SS C-20 PVC	125 ± 125 ± 125 ± 125 ±	2.0	37	Simplex	75
562-S-N1 562-S-N3 562-S-N4 562-S-N5	40.0	Cast Iron 316SS C-20 PVC	125 ± 125 ± 125 ± 125 ±	2.0	72	Simplex	75
565-S-N1 565-S-N3 565-S-N4 565-S-N5	60.0	Cast Iron 316SS C-20 PVC	125 ± 125 ± 125 ± 125 ±	2.0	117	Simplex	75

\*This model cannot be used for suction lift applications.  
± 175 PSI models available, contact the factory.

## NOTES TO SERIES 500 AND SERIES 500-A "dia-PUMP" SELECTION CHARTS

### NOTE 1, Motors:

Series 500 "dia-PUMPS" are supplied with an integrally mounted 1/3HP-1-60c-115v-TENV motor as standard. This motor is provided with automatic thermal overload protection.

Stock motor options available for Series 500 and Series 500-A as follows:


- A. 1/4HP-3ph-60c-230/460-TENV – Add Suffix "3" to model number.
- B. Explosion-Proof Motors (Class 1, Group D; Class II, Group E, F and G Hazardous locations):
  - 1/4HP-1ph-60c-115/230-Explosion-Proof – Add Suffix "EX-1" to model number.
  - 1/3HP-3ph-60c-230/460-Explosion-Proof – Add Suffix "EX-3" to model number.
- C. Totally Enclosed Fan-Cooled Motors.
  - 1/4HP-1ph-60c-115/230-TEFC – Add Suffix "TE-1" to model number.
  - 1/4HP-3ph-60c-230/460-TEFC – Add Suffix "TE-3" to model number.
- D. Other motors available, including units for 50 cycle operation and chemical duty service. Contact the factory.

### NOTE 2, Capacity:

Capacity figures are listed at 100 PSI discharge pressure. Capacity will decrease by approx. 1.5% for each 100 PSI increase in pressure.

### NOTE 3, PVC Head Pumps (N5)

PVC head pumps satisfactory for temperatures to 125°F/52°C.




# NEPTUNE AUTOMATIC CAPACITY CONTROL OPTIONS

## ELECTRONIC CAPACITY CONTROL (PATENT PENDING)

Utilizing the Neptune Electronic Capacity Control, the flow rate of any Series 500 or Series 500-A "dia-PUMP" can be controlled automatically by a process instrument, or remotely from the control module.


The Neptune Electronic Capacity Control consists of two elements; A) An Electric Control Rod Positioner mounted on the pump, and B) the Electronic Control Module, which may be located at the pump or remotely. (See Bulletin ECC for complete details, and ordering information.)



### FEATURES:

- Unit follows analog signal or potentiometer.
- Adjustable ratio signal to stroke 0.3:1 or 1:0.3.
- Direct (forward) or indirect (reverse) response to changing signal.
- All units allow manual override in event of instrument signal or power loss, a unique feature.

## PNEUMATIC STROKE CONTROL




The flow rate of any Series 500 or Series 500-A "dia-PUMP" can be controlled by an instrument air signal when using the pneumatic stroke control.

The control will respond to a standard signal of 3 to 15 PSI; other signal ranges available. Positioning is controlled by the Moore Products Model 73 Valve Positioner. Forward (direct) response to signal change is standard. Reverse (indirect) response and local manual override options are available.

To order, add Suffix "PC" to Model No. of pump.


## SCR MOTOR SPEED



The capacity of any Neptune Series 500 or Series 500-A "dia-PUMP" may be controlled by changing motor speed using the General Electric Full-Wave Statatrol Drive and Controller. (Contact factory for complete details and ordering information.)


### FEATURES:

- Manual speed control by potentiometer.
- Automatic speed control in response to a 4 to 20 ma signal (other signal ranges available).
- Control range 30 to 1.
- Additional flow range combinations using full micrometer adjustment at all speeds.




# SERIES 500 AND SERIES 500-A "dia-PUMP" DIMENSIONS


**FIG. 1 - DIMENSIONS SERIES 500 "dia-PUMP" WITH METAL HEAD (EXCEPT MODEL 560)**




**FIG. 2 - DIMENSIONS SERIES 500 "dia-PUMP" WITH PVC HEAD (EXCEPT MODEL 560)**



**FIG. 3 - DIMENSIONS SERIES 500 "dia-PUMP" MODELS 560/562/565**



**FIG. 4 - DIMENSIONS SERIES 500-A "dia-PUMP"**



## NOTES:

A. Dimensions shown are for cast iron-units. Dimensions will vary slightly for 316SS and C-20 models.

B. "dia-PUMP" with 1/4HP-1ph-115/230-Exp. Proof Motor (illustrated FIG. 1). Motor dimensions vary slightly with other motor models.



## pH Transmitter System

### Series 17PH1000

The Series 17PH1000 Transmitter System provides continuous measurement of the pH value of a process liquid. The system includes a pH Sensor assembly and an indicating pH Transmitter.

The Sensor houses the pH sensing probes (measuring and reference electrodes and temperature compensator) and a preamplifier which act to produce a current signal, automatically compensated for changes in process liquid temperature, which is representative of the pH value. The circuitry of the preamplifier is designed to permit measurements in either grounded or ungrounded solutions; and, includes input filtering to provide a signal which is highly immune to common mode or ground loop interferences.

The Transmitter functions to power the preamplifier and receive and convert the signal produced by the Sensor into a proportional 4-20 mA dc signal over any one of its manually selectable measurement ranges. The converted signal is applied to its self-contained indicator to show the pH value. Output terminals are provided for applying the signal to compatible secondary instrumentation for recording/controlling/indicating the pH of the process liquid.

#### DESIGN FEATURES

- **Input/Output Isolation:** Unique circuitry separates transmitter input stage from the output stage and power supply in order to avoid false signals due to noise or grounding problems.
- **Sensor Mounted Preamplifier:** Eliminates need for expensive shielded cable between Sensor and Transmitter. Interconnecting cable is standard unshielded, five-conductor, #18 AWG cable.
- **Field Mounting:** Weather-proof transmitter housing permits location near point of measurement with electronic transmission to remotely located instruments.
- **Convenience:** Continuous pH measurement frees operator for other duties by eliminating the need for frequent laboratory and field testing and allows automatic pH control.
- **Multiple Ranges:** Three switch selectable ranges.


#### ENGINEERING SPECIFICATIONS

##### Transmitter

**Operating Ranges:** 0-10, 2-12, or 4-14 pH (switch selective) with fixed 10 pH unit span

**Meter Indication:** 0-10, 2-12 (furnished as standard) or 4-14 pH on 5-1/2" (140 mm) scale

**Output:** 4-20 mA dc into 0-600 ohms max, isolated



**Ambient Temperature Limits:** -18 to 49°C (0-120°F). Performance is derated for -40 to 65°C (-40 to 150°F).

**Enclosure Classification:** NEMA 3 (IEC IP66) dust and raintight, suitable for outdoor mounting

**Electrical Classification:** Designed for Class I, Div. 2, Group C and D, locations.

**Power Requirements:** 120, 220/240 V ac ±10%, 50/60 Hz single phase, 10 Watts max.

**Case Construction:** Corrosion resistant fiberglass reinforced polyester

**Mounting:** Panel surface or pipe is standard. Field mounted, integral with immersion sensor on rail mounting bracket and sensor support post is optional.

**Sensitivity:** 0.005 pH units


**Accuracy:** ± 0.5% of span at output terminals (± 0.05 pH) and ± 2% at meter (± 0.2pH)

**Stability:** ± 0.001 pH unit per week max.

##### Response Time:

Sensor Assembly - 0.5 seconds for 95% response  
System - Approximately 20 seconds full scale.

**System Shipping Weight:** 35 lb (15.9 kg)



# Sensor Assembly

## Housing




	Flow-thru (In-Line)	Immersion
Flow Chamber Volume	175 ml	—
Materials		
Cover and Connecting Ring	Polypropylene	Polypropylene
Flow Chamber	Polypropylene	—
Guard	Viton A	Polypropylene
O-Rings	—	Viton A
Sample Flow Rate	15 gpm (0.95 L/s) max. Lower flow rate for viscous solutions, abrasives and high-purity water	
Maximum Pressure and Temp.	100 psig (690 kPa), 60°C (140°F) 50 psig (345 kPa), 80°C (176°F)	
Immersion Depth	—	Up to 200 ft (60 m) in a non-pressurized vessel or chamber
Relative Humidity Limit	Usable at 100% relative humidity	

## Electrodes


	pH Measuring Electrode		Reference Electrode	Temp. Compensation
Range	0-10 or 2-12	4-14	0-10, 2-12 or 4-14	0-10, 2-12 or 4-14
Operating Temp. Limit	-5 to 40°C (23 to 104°F)	10-80°C (50-176°F)	-5 to 80°C (23 to 176°F)	-5 to 80°C (23 to 176°F)
Internal Element	Silver-Silver Chloride		Silver-Silver Chloride	—
Material	Glass		Epoxy	Epoxy
Body Tip	Sensitive Glass		Removable Ceramic Plug	—
Electrolyte Supply	—		Non-flowing transparent (visible electrolyte supply) filled with long lasting KCl Slurry	—

## DIMENSIONS


### TRANSMITTER




### ~~Pipe Mounting (Horizontal or Vertical Pipe)~~




### ~~Flush Panel Mounting~~




### ✓ Surface Mounting






DIMENSIONS (continued)

✓ IMMERSION SENSOR ASSEMBLY




A/E VERIFY


~~ULTRASONIC FREQUENCY GENERATOR (OPTIONAL)~~



~~FLOW-THRU (IN-LINE) SENSOR ASSEMBLY~~




~~SURFACE MOUNTING~~



Notes:

1. Dimensions are in inches, and (millimeters).
2. Dimensions provided for reference only.
3. Transmitter mounting hardware is furnished for the type of mounting specified at time of purchase.



**EQUIPMENT DESCRIPTION**

The pH Transmitter System shall consist of a sensor assembly and an indicating transmitter. The system shall measure and indicate the pH value of the process liquid and transmit a 4-20 mA dc signal proportional to that of the measurement. The sensor assembly shall be available either as a flow-thru or immersion type cell. The sensor assembly shall consist of a fiberglass reinforced polypropylene body containing both reference and pH measuring electrodes (of suitable operating characteristics for the service); a temperature compensator and preamplifier; and be furnished with either a flow chamber for flow-thru service or protecting guard for immersion type application. Unshielded, five-conductor, #18 AWG cable shall be utilized for interconnection of the sensor assembly to the transmitter. The length of cable shall be as indicated on the plans but limited to 1000 ft (305 m) maximum.

The pH Transmitter shall be of all solid state electronic construction with integrated circuitry mounted on printed circuit boards. It shall measure the pH value over any of three switch selective ranges of 0-10, 2-12, or 4-14 pH. A 2-12 pH scale shall be furnished as standard. The transmitter housing shall be NEMA 3 (IEC IP 66) and suitable for (flush panel) surface (pipe) mounting. Ambient temperature range shall be -18 to 49°C (0 to 120°F). The transmitter shall transmit a 4-20 mA dc signal into a maximum load of 600 ohms. Input-output isolation shall be standard. Power Supply shall be (120) 220/240 V ac ±10%, 50/60 Hz. The pH transmitter system shall be Fischer & Porter Series 17PH1000.

**Ultrasonic Electrode Cleaning Kit (optional)**

The transducer and holder are 316 SS and are constructed for Class I Div. 2 Group C and D locations. The ultrasonic generator itself is housed in a sheet metal, NEMA 12 case for wall mounting in a non-hazardous or general purpose location and requires a 120 or 240 V ac, 50/60 Hz power supply at 75 watts (max.) The kit contains 20 ft. (6m) of lead wire for use between the transducer and generator.


**OPTIONAL EQUIPMENT**

- Spare Sensor Assembly
- Spare pH Sensing Probes (measuring and reference electrodes and temperature compensator).
- Support Beam and Mounting Bracket for immersion type sensor assembly.
- Sensor Assembly Maintenance Kit (includes two spare pH measuring electrodes, buffer solutions and seals).
- Remote indicator/recorder/controller.
- Ultrasonic Electrode Cleaning Kit


**ORDERING INFORMATION**

- Series Number
- Voltage and Frequency
- Optional Equipment
- Application Data
- pH Range
- Sensor Configuration
- Transmitter Mounting
- Process Liquid Characteristic:  
(eg: Flow rate, Pressure and Temperature)

**MODEL NUMBER DESIGNATION**



Note: Specifications are subject to change without notice.





ANALYZER SYSTEMS  
EQUIPMENT SPECIFICATION

Sheet \_\_\_ of \_\_\_

Customer Name: Holcomb Blvd. Water Plant Inquiry No.: Harry Pepper & Assoc, Inc.

F&P Proposal No.: Combs & Associates Item No.: J4001 & J4002 Quan. Two (2)

Tag No(s): J4001 pH ANALYZER TRANSMITTER  
J4002 " " "

Model Number: F&P 17pH1211A

System Functions


P.B.

- Analyzer - Refer to reverse side for Description
- 51-1321 Recorder - Refer to Sheet \_\_\_\_\_ for Description
- 53EG4000 Controller - Refer to Sheet \_\_\_\_\_ for Description
- 51-1102DB Circular Chart Recorder - Refer to Sheet \_\_\_\_\_ for Description

Note: All accessories (ie. Charts, Ink, etc...) are to be specified on the appropriate Equipment Specification Sheet referenced above. Provide complete price breakdown on attached sheets and use this form for the total system price only.

Total:

Notes:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



**ANALYZER - TRANSMITTER  
EQUIPMENT SPECIFICATION**

Item No.: J4001 & 002 Quantity: Two Model: F & P 17PH1211A

Tag No(s): J4001 & J4002 pH analyzer transmitters

Input:  Free  Total Residual Chlorine  Fluoride  With Hexametaphosphate (Calgon)  
 Dissolved Ozone  Potassium Permanganate  pH  Redox (ORP)  Dissolved Oxygen

Operating and Scale Range:  0-0.5  0-1  0-2  0-3  0-5  0-10  0-20 mg/L Residual Chlorine  
 0-1 mg/L (Not Available with Calgon)  0-2 mg/L Fluoride  
 0-2 (Scale Range 0-20)  0-5  0-10  0-20 mg/L Dissolved Oxygen  
 0-0.5  0-1  0-2 mg/L Potassium Permanganate  
 0-10  2-12  4-14 pH  
 0-0.5  0-1 mg/L Dissolved Ozone  
 \_\_\_\_\_ mv (Redox) (Standard Scale Is Percent)

Output Signal: 4-20 mA dc ✓

Operating Voltage:  120 V 50/60 Hz.  220/240 V 50/60 Hz (17DO, 17PH, 17RX)

Sensor Configuration (17PH, 17RX):  Immersion  Flow Thru

P.B.

Base Price of meter as described above.....

Options and Accessories


17B, 17F, 17L, 17P

- Door Lock Shatterproof Glass
- Sample Filter P/N
- Chemicals (Provide Part Number and Quantity) - Model 17B, 17F w/Calgon
- Sample Pump Model

- <sup>2-12</sup> With Indicator  Without Indicator
- Salt/Seawater Service (17B)
- Breakpoint (17B) 0-10 mg/L Max. Range

17DO, 17PH, 17RS

- Mounting Bracket and Support Extension (Base on 17DO)
- Cable Length \_\_\_\_\_  Maintenance Kit
- Spare Sensor Assembly (17DO, 17PH)
- Spare Membrane Assembly (17DO)
- Spare Reference Electrode (17PH, 17RX)
- Spare Temperature Compensator  Ultrasonic Electrode Cleaning Kit (17PH)
- Spare Measuring Electrode (17PH, 17RX)  Special Direct Read Meter (17RX)



Hurt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO 81-C-1644	TRANSMITTAL NO 132	DATE 12-17-85
--------------------------	-----------------------	------------------

FROM CONTRACTOR  
Harry Pepper & Associates, Inc.

PROJECT TITLE AND LOCATION  
Holcomb Blvd Water Treatment Plant

TO  
Henry Von Oesen & Associates, Inc.

MCB, Cp Lejeune, North Carolina

**CONTRACTOR USE ONLY**

**REVIEWER USE ONLY**

\*List only one specification division per form.

\*\*ACTION CODES

List only one of the following categories on each transmittal form,  
and indicate which is being submitted

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged
- C-Comments
- R-Resubmit

- Contractor Approved       OICC Approval       Deviation/Substitution For OICC Approval

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
1	11336 4.3	WATER TREATMENT EQUIPMENT Filter media Gradation and Material Certification	4		RB

CONTRACTOR'S COMMENTS

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

ONE COPY TO ROICC

Phil Reese *Phil Reese*

DATE RECEIVED BY REVIEWER

FROM (Reviewer)

TO

12/20/85

Henry von Oesen & Assoc., Inc.

Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.

Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

CONTRACTOR'S APPROVAL APPEARS TO APPROPRIATE.

HENRY VON OESEN AND ASSOCIATES, INC.  
CONSULTING ENGINEERS & PLANNERS

COPIES TO  
ROICC (2)  
LANTDIV (1)  
A-E (1)

DATE

12/23/85

SIGNATURE

*Al Brown*

11/12/1917  
The Board of Directors  
of the  
Company

Dear Sirs:  
I have the honor to acknowledge the receipt of your letter of the 11th inst. in relation to the above mentioned matter.

I am sorry to hear that you are unable to attend the meeting of the Board of Directors on the 14th inst. and I trust that you will be able to attend the meeting on the 17th inst.

I am, Sir, very respectfully,  
Yours truly,  
Wm. H. [Signature]

Wm. H. [Signature]  
Secretary



# LAW ENGINEERING TESTING COMPANY

3301 WINTON ROAD • P.O. BOX 18288  
TELEPHONE (919) 876-0416 • RALEIGH, N.C. 27619



## REPORT OF FILTER GRAVEL ANALYSIS

CLIENT: Southern Products & Silica Co.  
Hoffman, North Carolina

DATE: November 29, 1984

PROJECT: Laboratory Testing

JOB NO.: RAG-1660

### SIEVE ANALYSIS

SAMPLE SIZE	SIEVE	% RET	% PASSING	SPECIFICATIONS LIMITS % PASSING
1 1/2" X 3/4"	1 1/2"	1.7	98.3	92.0 Min.
	3/4"	97.4	2.6	8.0 Max.

NOTE: Test sample obtained and tested in accordance with the American Water Works Association, Section B100-80.

This analysis is true and correct.

North Carolina

Moore County

C. K. Smith, General Manager

I, Pam H Wood, a Notary Public for said County and State, do hereby certify that C & K Smith personally appeared before me this day, and signed the foregoing instrument.

~~Witness my hand and official seal, this the 3rd day of December, 1985.~~

Notary Public

My commission expires  
4-2-89.

**Respectfully Submitted**  
**LAW ENGINEERING TESTING CO.**

is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number NG2470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

- Approved for use.
- Submitted for Government approval.
- Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_  
Signature CQC Rep. Phil Pease DATE 12-17-85



# LAW ENGINEERING TESTING COMPANY

3301 WINTON ROAD • P.O. BOX 18288  
TELEPHONE (919) 876-0416 • RALEIGH, N.C. 27619



## REPORT OF FILTER GRAVEL ANALYSIS

CLIENT: Southern Products & Silica Co.      DATE: November 29, 1984  
          Hoffman, North Carolina  
PROJECT: Laboratory Testing                      JOB NO.: RAG-1660

### SIEVE ANALYSIS

SAMPLE SIZE	SIEVE	% RET	% PASSING	SPECIFICATIONS LIMITS % PASSING
1" X 5/8"	1"	1.9	98.1	92.0 Min.
	5/8"	97.8	2.2	8.0 Max.

NOTE: Test sample obtained and tested in accordance with the American Water Works Association, Section B100-80.

This analysis is true and Correct.


  
C. K. Smith, General Manager

North Carolina

Moore County

I, Pam H. Wood, a Notary Public for said County and State, do hereby certify that C K Smith personally appeared before me this day, and signed the foregoing instrument.

Witness my hand and official seal, this the 3rd day of December, 1985.

  
Notary Public

My commission expires 4-2-89.

**Respectfully Submitted**  
**LAW ENGINEERING TESTING CO.**





THE NATIONAL ASSOCIATION OF  
LABORERS AND GUILD MEMBERS

November 1931

LABORERS' UNION



# LAW ENGINEERING TESTING COMPANY

3301 WINTON ROAD • P.O. BOX 18288  
TELEPHONE (919) 876-0416 • RALEIGH, N.C. 27619



## REPORT OF FILTER GRAVEL ANALYSIS

CLIENT: Southern Products & Silica Co.  
Hoffman, North Carolina

DATE: December 20, 1984

PROJECT: Laboratory Testing

JOB NO.: RAG-1660

### SIEVE ANALYSIS

SAMPLE SIZE	SIEVE	% RET	% PASSING	SPECIFICATIONS LIMITS & PASSING
5/8" X 3/8"	5/8"	0	100	92.0 Min.
	3/8"	98.8	1.2	8.0 Max.

NOTE: Test sample obtained and tested in accordance with the American Water Works Association, Section B100-80.

This analysis is true and correct.

C. K. Smith  
C. K. Smith, General Manager

North Carolina  
Moore County

I, Pam H. Wood, a Notary Public for said County and State, do hereby certify that C K Smith personally appeared before me this day, and signed the foregoing instrument.

Witness my hand and official seal, this the 3rd day of December, 1985.

Pam H. Wood  
Notary Public

My commission expires 4-2-89.

**Respectfully Submitted**  
**LAW ENGINEERING TESTING CO.**

[Signature]



DATE: December 20, 1954

JOB NO.: RAG-1800

HOLLIMAN NORTH CAROLINA

LABORATORY TESTING

GIVE AND TAKE

TESTING

92.0 MIN.

8.0 MAX.

NOTE: Test sample obtained and tested in accordance with the American Water Works Association, Section 8100-80.

W. R. BARTON, General Manager

Test sample obtained and tested in accordance with the American Water Works Association, Section 8100-80.

Tested on 12th day of December, 1954.

LAW ENGINEERING TESTING CO.



# LAW ENGINEERING TESTING COMPANY

3301 WINTON ROAD • P.O. BOX 18288  
TELEPHONE (919) 876-0416 • RALEIGH, N.C. 27619



## REPORT OF FILTER GRAVEL ANALYSIS

CLIENT: Southern Products & Silica Co.  
Hoffman, North Carolina

DATE: November 29, 1984

PROJECT: Laboratory Testing

JOB NO.: RAG-1660

### SIEVE ANALYSIS

SAMPLE SIZE	SIEVE	% RET	% PASSING	SPECIFICATIONS LIMITS % PASSING
3/8" X 3/16"	3/8"	0	100	92.0 Min.
	3/16"	98.0	2.0	8.0 Max.

NOTE: Test sample obtained and tested in accordance with the American Water Works Association, Section B100-80.

This analysis is true and correct.

C. K. Smith  
C. K. Smith, General Manager

North Carolina

Macon County

I, Pam H Wood, a Notary Public for said County and State, do hereby certify that C. K. Smith personally appeared before me this day, and signed the foregoing instrument.

Witness my hand and official seal, this the 3rd day of December, 1985

Pam H Wood Notary Public

My commission expires 4-2-1989.

**Respectfully Submitted**  
**LAW ENGINEERING TESTING CO.**



STATE OF NORTH CAROLINA  
DEPARTMENT OF TRANSPORTATION

DATE: November 23, 1984  
OFFICE: Raleigh, North Carolina

STRENGTH ANALYSIS


SPECIFICATIONS

SECTION 810.0

These items are to be used in accordance with the American  
Water Works Association, Section 810-80.

... and shall be used for ...  
... and shall be used for ...  
... and shall be used for ...

STATE OF NORTH CAROLINA  
DEPARTMENT OF TRANSPORTATION  
RALEIGH, NORTH CAROLINA



# LAW ENGINEERING TESTING COMPANY

3301 WINTON ROAD • P.O. BOX 18288  
TELEPHONE (919) 876-0416 • RALEIGH, N.C. 27619



## REPORT OF FILTER GRAVEL ANALYSIS

CLIENT: Southern Products & Silica Co.      DATE: November 29, 1984  
Hoffman, North Carolina


PROJECT: Laboratory Testing      JOB NO.: RAG-1660

### SIEVE ANALYSIS

SAMPLE SIZE	SIEVE	% RET	% PASSING	SPECIFICATIONS LIMITS % PASSING
3/16 X #10	3/16"	1.1	98.9	92.0 Min.
	#10	99.2	.8	8.0 Max.

NOTE: Test sample obtained and tested in accordance with the American Water Works Association, Section B100-80.

This analysis is true and Correct.


  
C. K. Smith, General Manager

North Carolina

Moore County  
I, Pam N. Wood, a Notary Public for said County and State, do hereby certify that C. K. Smith personally appeared before me this day, and signed Witness my hand and official seal, this the 3rd day of

December, 19 85  
Pam N. Wood  
Notary Public  
477-02

My commission  
expires 4-2-89.

**Respectfully Submitted**  
**LAW ENGINEERING TESTING CO.**  


TEST REPORT

HOFFMAN, NORTH CAROLINA  
TEST NO. 100-1000

SPECIFICATIONS

ITEM	TEST RESULT	REMARKS
1	0.0	
2	0.0	
3	0.0	
4	0.0	
5	0.0	
6	0.0	
7	0.0	
8	0.0	
9	0.0	
10	0.0	
11	0.0	
12	0.0	
13	0.0	
14	0.0	
15	0.0	
16	0.0	
17	0.0	
18	0.0	
19	0.0	
20	0.0	
21	0.0	
22	0.0	
23	0.0	
24	0.0	
25	0.0	
26	0.0	
27	0.0	
28	0.0	
29	0.0	
30	0.0	
31	0.0	
32	0.0	
33	0.0	
34	0.0	
35	0.0	
36	0.0	
37	0.0	
38	0.0	
39	0.0	
40	0.0	
41	0.0	
42	0.0	
43	0.0	
44	0.0	
45	0.0	
46	0.0	
47	0.0	
48	0.0	
49	0.0	
50	0.0	
51	0.0	
52	0.0	
53	0.0	
54	0.0	
55	0.0	
56	0.0	
57	0.0	
58	0.0	
59	0.0	
60	0.0	
61	0.0	
62	0.0	
63	0.0	
64	0.0	
65	0.0	
66	0.0	
67	0.0	
68	0.0	
69	0.0	
70	0.0	
71	0.0	
72	0.0	
73	0.0	
74	0.0	
75	0.0	
76	0.0	
77	0.0	
78	0.0	
79	0.0	
80	0.0	
81	0.0	
82	0.0	
83	0.0	
84	0.0	
85	0.0	
86	0.0	
87	0.0	
88	0.0	
89	0.0	
90	0.0	
91	0.0	
92	0.0	
93	0.0	
94	0.0	
95	0.0	
96	0.0	
97	0.0	
98	0.0	
99	0.0	
100	0.0	

Test sample obtained and tested in accordance with the American Water Works Association standard.





ANALYSIS

DATE: November 13, 1984  
PROJECT: [Illegible]

FOR: [Illegible]

TEST NO.	TEST TYPE	TEST RESULT	TEST UNIT
10	...	...	...
15	...	...	...
20	...	...	...
25	...	...	...
30	...	...	...
35	...	...	...
40	...	...	...
45	...	...	...
50	...	...	...
55	...	...	...
60	...	...	...
65	...	...	...
70	...	...	...
75	...	...	...
80	...	...	...
85	...	...	...
90	...	...	...
95	...	...	...
100	...	...	...

TESTING COEFFICIENTS  
TESTING SIZE

TESTING SAMPLES  
TESTING WATER WORKS

TESTING ANALYSIS

TESTING RESULTS

TESTING CONCLUSIONS

TESTING RECOMMENDATIONS

TESTING SIGNATURES

Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO 81-C-1644	TRANSMITTAL NO 61-B	DATE 1-2-86
--------------------------	------------------------	----------------

FROM CONTRACTOR  
Harry Pepper & Associates, Inc.

TO  
Henry Von Oesen & Associates, Inc.

PROJECT TITLE AND LOCATION  
Holcomb Blvd Water Treatment Plant

MOB, Cp. Lefevre, North Carolina

<p align="center"><b>CONTRACTOR USE ONLY</b></p> <p align="center">*List only one specification division per form.</p> <p align="center">List only one of the following categories on each transmittal form, and indicate which is being submitted</p> <p><input type="checkbox"/> Contractor Approved      <input type="checkbox"/> OICC Approval      <input type="checkbox"/> Deviation/Substitution For OICC Approval</p>	<p align="center"><b>REVIEWER USE ONLY</b></p> <p align="center">**ACTION CODES</p> <p>A-Approved D-Disapproved AN-Approved as noted RA-Receipt acknowledged. C-Comments R-Resubmit</p>
---	---

ITEM NO	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
		Letter from Combs & Associates, Inc. to Harry Pepper & Associates, Inc.			
	6.2.6	Manufacturer's Data and Shop Drawings of Filter Console			

CONTRACTOR'S COMMENTS

---

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC		CONTRACTOR REPRESENTATIVE (Signature)	
DATE RECEIVED BY REVIEWER		FROM (Reviewer)	TO

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

Equipment installation, connections, etc. should be checked with equipment manufacturer to ensure correct installation.

COPIES TO ROICC (2) LANTDIV (1) A-E (1)	DATE	SIGNATURE
--	------	-----------

23 JAN 1966 12 07

Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**

LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO 81-C-1644	TRANSMITTAL NO 181	DATE 3-13-86
--------------------------	-----------------------	-----------------

FROM CONTRACTOR  
Harry Pepper & Associates, Inc.

TO  
Henry Von Oesen & Associates, Inc.

PROJECT TITLE AND LOCATION  
Holcomb Blvd Water Treatment Plant  
MCB, Cp Lejeune, North Carolina

**CONTRACTOR USE ONLY**

\*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

- Contractor Approved       OICC Approval       Deviation/Substitution For OICC Approval

**REVIEWER USE ONLY**

**\*\*ACTION CODES**

- A-Approved  
D-Disapproved  
AN-Approved as noted  
RA-Receipt acknowledged.  
C-Comments  
R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1	6.5.e	Manufacturer's Data and Drawings on PH Sensor	7	A	CCS 405 4/7/86
2		Estimate for Change Order	7	C	CCS 405 4/7/86
					CCS 405 4/7/86

**CONTRACTOR'S COMMENTS**

- The attached Manufacturer's Data is being provided for the following reasons.
  - The current PH Sensor when removed causes Treatment Process System to be shut down.
  - The Deviation will allow removal of Sensor without a shut down.
- The attached Manufacturer's Data has been reviewed by Plant Operating Personnel and found to be acceptable.
- Cost of Deviation (PH Sensor) is provided as shown.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

ONE COPY TO ROICC

Phil Reese *Phil Reese*

DATE RECEIVED BY REVIEWER

FROM (Reviewer)

TO

4/3/86

*Bm*

*disty*

Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.

Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

**REVIEWER'S COMMENTS**

Deviation is approved subject to an equitable change order settlement to be negotiated by Lt. Klug.

COPIES TO ROICC (2) LANTDIV (1) A-E (1)

DATE

SIGNATURE

4/8/86

*Bill Mawley*

17 APR 1986 13 00

*[Handwritten scribble]*

*[Handwritten scribble]*

*[Faint, illegible text]*

*[Faint, illegible text]*

ONE(1) MODEL 222T-A01-H

# pH and ORP Electrode Assemblies

## Basic Assembly

This multi-purpose sensor assembly is suitable for virtually all pH and ORP measurement applications, and flexibility is further enhanced when used with a variety of mounting option accessories. Assembly accepts a variety of glass pH and metallic pH and ORP electrodes with unique design for interchangeability or replacement. Units available for use with 2220 Series Monitor or E99 Series Transmitters.

The sensor assembly is a compact unit, comprises a Ryton housing, a pH or ORP measuring electrode, a plug-in dual liquid reference junction and a replaceable solution ground, and built-in automatic temperature compensator. The electrode and reference junction are mechanically secured with a replaceable keeper and a knurled stud. The keeper and stud also serve as solution ground. The unit is not affected by normally encountered chemical solutions and is capable of withstanding continuous operation in a wide range of process pressures and temperatures. A differential high impedance solid state preamplifier is optionally encapsulated in the sensor housing.

## Measuring Electrodes

Interchangeable plug-in sensing electrodes are available in both glass and metal configurations to suit any given application. This unique concept allows the user a choice of any of these electrodes. If an incorrect one is chosen, or if the measurement conditions change, it is simple to change from one measurement system to another in the field.

Glass pH electrodes offer the best performance in most solutions, and inherently provide the most accurate measurement. The small bulb design results in a rugged electrode suitable for industrial service.

Metallic antimony pH electrodes are available for abrasive solutions or for solutions containing hydrofluoric acid or other chemicals which attack glass electrodes. Antimony should not be used in acid copper solutions nor in oxidizing or reducing solutions such as chromates, chlorine, hypochlorites, or sulfides. ORP electrodes are available in both platinum or gold (gold is primarily used in cyanide reduction systems).

## Reference Electrode


The reference electrode is a non-flowing dual liquid type. A silver-silver chloride half cell immersed in saturated potassium chloride is used because of its highly stable output voltage. The filling solution and the junction may be readily replaced in the field.

## Mounting

The basic sensor assembly may be mounted as follows:

- ~~A. In situ, in tank or trough, etc. — optional electrode protection sleeve is recommended for this use (outaway view).~~
- ~~B. In line via twist lock bushings or tee for permanent installation in pipeline or tank.~~
- ~~C. Sample line twist lock flow chambers are available for clean sample stream applications. 216-66 flow chamber is recommended for pure or ultrapure water pH measurement.~~


In-line via ball valve unit which permits sensor assembly to be removed from process stream or tank, underrated temperature and pressure, without draining the system or resorting to a bypass arrangement.



Ryton is a trademark of Phillips Petroleum Company.  
Viton is a trademark of E I duPont de Nemours and Company.

## PRODUCT SPECIFICATIONS

PSS 6-1A2 B  
pH AND ORP ELECTRODE ASSEMBLIES



## SERIES 222 pH AND ORP ELECTRODE ASSEMBLIES

### Features:

- SINGLE, MULTI-PURPOSE ASSEMBLY SUITABLE FOR VIRTUALLY ALL APPLICATIONS
- FIELD INTERCHANGEABLE, PLUG-IN GLASS AND METAL ELECTRODES FOR pH AND ORP
- PLUG-IN REPLACEABLE DUAL LIQUID REFERENCE JUNCTION
- DESIGNED FOR CONTINUOUS OPERATION AT HIGH TEMPERATURES AND PRESSURES
- AUTOMATIC INTEGRAL TEMPERATURE COMPENSATION
- RECHARGEABLE REFERENCE ELECTRODE
- INTEGRAL PREAMPLIFIER AVAILABLE
- FLEXIBILITY ENHANCED WHEN USED WITH VARIETY OF MOUNTING ACCESSORIES: IN-LINE TWIST LOCK BUSHINGS, BALL VALVE INSERTION UNIT, SAMPLE LINE FLOW CHAMBERS, ELECTRODE PROTECTION SLEEVE

**FOXBORO**

Item #1

I hereby certify that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut(s), etc., and approved/proposed to be incorporated into Contract Number **05-81-C-1644** is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

- Approved for use.
- Submitted for Government approval.
- Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_  
 Signature CQC Rep. Phil Pease DATE 3-13-86

**ATLANTIC DIVISION**  
**NAVAL FACILITIES ENGINEERING COMMAND**  
 NORFOLK VIRGINIA 23511

APPROVED \_\_\_\_\_  
 AS NOTED \_\_\_\_\_  
 DISAPPROVED \_\_\_\_\_  
 SUBJECT TO THE REQUIREMENTS OF \_\_\_\_\_

**05-81-1644**  
 CONTRACT NO.

APPROVAL OF A SUBMITTAL DOES NOT INCLUDE APPROVAL OF ANY DEVIATION FROM THE CONTRACT REQUIREMENTS UNLESS THE CONTRACTOR CALLS ATTENTION TO AND SUPPORTS THE DEVIATION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING PROPER PHYSICAL DIMENSIONS & WEIGHTS COORDINATION OF TRADES, ETC., AS REQUIRED

REVIEWER \_\_\_\_\_ DATE \_\_\_\_\_

FOR OFFICER IN CHARGE OF CONSTRUCTION

**ATLANTIC DIVISION**  
**NAVAL FACILITIES ENGINEERING COMMAND**  
 NORFOLK, VIRGINIA 23511

APPROVED  \_\_\_\_\_  
 APPROVED AS NOTED \_\_\_\_\_  
 DISAPPROVED \_\_\_\_\_  
 SUBJECT TO THE REQUIREMENTS OF \_\_\_\_\_

**05-81-1644**  
 CONTRACT NO.

APPROVAL OF A SUBMITTAL DOES NOT INCLUDE APPROVAL OF ANY DEVIATION FROM THE CONTRACT REQUIREMENTS UNLESS THE CONTRACTOR CALLS ATTENTION TO AND SUPPORTS THE DEVIATION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING PROPER PHYSICAL DIMENSIONS & WEIGHTS COORDINATION OF TRADES, ETC., AS REQUIRED

REVIEWER CCS DATE 7 APR 1986

FOR OFFICER IN CHARGE OF CONSTRUCTION

ONE (1) MODEL 2220 -A 02 -W -J

## Product Specifications

PSS 6-1A1 C



## 2220 MONITORS (pH AND ORP)

The Foxboro 2220 Monitor, in conjunction with an appropriate 222T Sensor, provides continuous measurement and indication of the pH or Oxidation-Reduction Potential (ORP) of a wide variety of industrial process solutions.

The 2220 Monitor provides a 0 to 10 V dc output to drive a recorder, digital voltmeter, or similar device. An optional isolated 4 to 20 or 10 to 50 mA dc output signal is available for recorders, controllers, or converters that provide an input to computers.

This direct readout monitor features a variety of ranges that cover several spans between the range limits of 0 and 14 pH and -500 and +2000 mV dc ORP on easily read scales.

### EASY ACCESS TO CONTROLS

Monitor operation and pre-operation checks are simplified because of easy access to the High and Low Alarm settings and Standardize control, both conveniently located on the monitor front panel.

### CHOICE OF MOUNTING

Panel mounting (into panel cutout), surface mounting (with or without rear access), pipe mounting (DN 25 or 1 in), or field mounting (optional hinged-door enclosure) are offered. The monitor may be located a maximum of 300 m (1000 ft) from the measurement location.

### SENSOR AND ACCESSORY SELECTIONS

A variety of sensors is available (e.g., choices of body material, measuring electrode, reference junction, etc.). A versatile selection of sensor mounting accessories meet virtually all process requirements. For information on sensors and accessories, refer to PSS 6-1A2 B.

**FOXBORO**<sup>®</sup>

®Registered Trademark

PSS 6-1A1 C

Page 2

### CONTINUOUS ALARM INDICATION

A pair of red light-emitting diodes (LED's), located on the monitor front panel, provide a constant visible alarm indication when the measured value is above or below the alarm settings.

### INSTALLATION AND MAINTENANCE SIMPLIFIED

Removal of two screws on the monitor front panel permits easy access for installation or routine maintenance. Unplugging a cable connector allows the front panel to be separated from the housing.

### FUNCTIONAL SPECIFICATIONS

#### Model Code

2220= Monitor, pH and ORP

#### Supply Voltage

-A = 120 V, 50/60 Hz

-B = 240 V, 50/60 Hz

#### Range

01 = 0 to 14 pH, Glass Electrode

02 = 2 to 12 pH, Glass Electrode

03 = 4 to 10 pH, Glass Electrode

04 = 0 to 14 pH, Antimony Electrode

05 = 2 to 12 pH, Antimony Electrode

06 = 4 to 10 pH, Antimony Electrode

07 = 0 to 10 pH, Antimony Electrode

08 = -500 to +500 mV, ORP Electrode

09 = 0 to 1000 mV, ORP Electrode

10 = 0 to 2000 mV, ORP Electrode

11 = Fixed Intermediate, Glass (Specify)

12 = Fixed Intermediate, Antimony (Specify)

13 = Fixed Intermediate, ORP (Specify)

#### Mounting

P = Panel/Rear Access Surface

S = Pipe/Front Access Surface

W = Field, NEMA 4

#### Selectable Options

#### Current Output (Isolated)

J = 4 to 20 mA dc, 120/240 V ac

K = 10 to 50 mA dc, 120/240 V ac

#### Alarm - Sealed Relay


-R = Sealed Alarm Contacts (2 Form C contacts)

#### Dial Lock


-DL1 = Dial Lock, 1-position

-DL2 = Dial Lock, 2-position

Example: 2220-A01P-J-R-DL1



SELECTABLE OPTIONAL FEATURES

Optional Feature	Description	Model Code Suffix
 Isolating Current Output PWA	Available for a recorder, controller, or a converter that serves as an input to a computer. Isolated, 4 to 20 mA dc into 1 kΩ Isolated, 10 to 50 mA dc into 400 Ω	-J -K
 Dial Lock	Provides added system security by allowing locking of either Low or High Alarm knob (-DL1) or both (-DL2). 1-Position 2-Position	-DL1 -DL2
 Alarm	Sealed alarm contacts, (2 Form C contacts)	-R

NEMA 4 ENCLOSURE

Description	How to Order
 Enclosure With 2220 Monitor	Specify Mounting Code W
 Enclosure Without Monitor	Specify Foxboro Part Number 0051101

**Output Signal (For a Recorder)** 0 to 10 V dc linear into 2 kΩ minimum

**Optional Output Signal**  
 Isolated, 4 to 20 mA dc into 1 kΩ maximum  
 Isolated, 10 to 50 mA dc into 400 Ω maximum

**Supply Voltage and Frequency Limits**  
 105 and 125 V, 50/60 ± 1 Hz, 10 VA maximum  
 210 and 250 V, 50/60 ± 1 Hz, 10 VA maximum

**Range and Span Limits**

Measurement	Range Limits*	Span Limits*
pH	0 and 14 pH	4 and 14 pH
ORP	-500 and +2000 mV	1000 and 2000 mV

\*As specified by Range in Model Code

**Ambient Temperature Limits** -20 and +60°C (-5 and +140°F)

**Temperature Compensation** When used with Foxboro 2221 Sensors, the monitor provides automatic temperature compensation for electrode thermal errors for solution temperature between -5 and +105°C (20 and 220°F).

**Alarms** Two independently set Form C contacts rated 3 A resistive at 120 V ac or 28 V dc. (Optional sealed relay available with same ratings.)

**Operating Adjustments (On Front Panel)**

- Low Alarm** Potentiometer (with knob)
- High Alarm** Potentiometer (with knob)
- Standardize** Potentiometer (screwdriver adjustment)

**Electrical Classification (Mounting Suffixes P and W Only)** CSA approved for ordinary locations

PERFORMANCE SPECIFICATIONS

**Accuracy** ± 1% of span

**Indicator Accuracy** ± 2% of upper-range value

**Repeatability** 0.1% of span

**Alarm Lockup** Fixed lockup of 3% of span nominal

**Humidity Effect** Negligible effect between 0 and 95% relative humidity.

**Supply Voltage and Frequency Effect** Line voltage and frequency affect the measurement less than 1% within the supply limits.

PHYSICAL SPECIFICATIONS

**Mounting**

**Monitor Housing Model Code P**

**Panel Mounting** Mounting into panel cutout (mounting hardware supplied).

**Surface Mounting** Mounting on a surface with rear access by user-supplied hardware.

**Model Code S (Surface Mounting)** Mounting on a surface with no rear access. A gray steel plate, plus mounting hardware, is supplied.

**Surface** Mounting on a surface that is too thick to be penetrated by the 1/4-20 × 0.50 in hardware that connects into the rear of housing.

**Pipe** Mounting on any unobstructed horizontal or vertical section of DN 25 or 1 in pipe, 300 mm (12 in) long (user supplied).

**Model Code W (Field)** Surface mounting enclosure has a hinged door for convenient access to controls. The door has a window to observe indicator and controls.

**Environmental Protection**

**Monitor Housing** The monitor housing is weather-proof and dust-protected as defined by IEC IP53 and provides the rain-tight protection of NEMA Type 3.

**Optional Enclosure** The enclosure is weather-proof and dust-tight as defined by IEC IP65 and provides the watertight protection of NEMA Type 4 (or CSA Enclosure 4).

**Monitor Material**

**Front Panel** Fully gasketed glass-reinforced polyester.  
**Housing** Aluminum, epoxy paint finish

**Optional NEMA 4 Housing** Aluminum, epoxy paint finish

**Indicator Scale Length** 114 mm (4.5 in)


**Wiring Connections**

**Through Housing** At bottom through conduit (user supplied)

**Internal** Terminal connections



ORDERING INSTRUCTIONS

1. Model Code
2. Scale Range ( For Range Model Codes 11, 12, and 13 Only)
3. Tag



DIMENSIONS—NOMINAL

mm  
in





DIMENSIONS—NOMINAL (Cont)

mm  
in

FIELD MOUNTED (NEMA 4)

*YES*





### Specifications

- ✓ **Performance:** Reproducibility is typically 2 mV (0.03 pH unit) at reference conditions. Reproducibility at operating conditions depends on calibration standard employed, cleanliness of electrode and other process-related conditions. Optional Foxboro electrode cleaners aid in maintaining a high degree of reproducibility on pH and ORP electrodes in dirty process streams. (See PSS on Electrode Cleaning Systems.)
- ✓ **Measuring electrodes:** Plug-in interchangeable electrodes, glass pH, employing high stability silver, silver chloride (Ag<sub>2</sub>AgCl) internals; antimony pH, and platinum or gold ORP. For easy identification, the plug-in end of the electrode is color coded as per page 4.
- ✓ **Reference electrode:** Non-flowing, double junction with Ag<sub>2</sub>AgCl internal and saturated potassium chloride (KCl) electrolyte. Process junction is ceramic. Measuring and reference junctions are mounted in Ryton and pte mounts with Viton O-rings.
- ✓ **Automatic temperature compensation (ATC):** Assembly includes encapsulated ATC compatible with 2220 Series Monitors or E99 Series Transmitters, as specified. Covers temperatures between -5 and +105°C (20 and 220°F).
- ✓ **Solution ground:** Titanium Grade 2 CP solution ground stud or screw when used with optional electrode wiper cleaning systems. Also acts as keeper for securing electrodes in assembly.
- ✓ **Basic sensor assembly:** Immersion/Submersion Depth: 50 mm (2 in) minimum and 6 m (20 ft) maximum.

Specification	Housing*			Glass pH Electrode*	ORP or Antimony Electrode*
	with Preamp.	without Preamp.	with or without Preamp.		
Operating Temperature Limits	-5 and +80°C (20 and 175°F) submerged	-5 and +125°C (20 and 255°F) submerged	-5 and +125°C (20 and 255°F) in-line	-5 and +105°C (20 and 220°F)	-5 and +125°C (20 and 255°F)
Maximum Pressure	1 MPa (150 psi)			0.7 MPa (100 psi)	1 MPa (150 psi)

\*See also specifications for mounting options

### Specifications of Options

#### Mounting Options Ball Valve Unit



The unit consists of the ball valve unit itself, and the insertion shaft assembly to support the sensor in the stream. Since the area of the insertion shaft is 2 cm<sup>2</sup> (0.3 in<sup>2</sup>), a force of only 170 newtons (37.5 pound force) is required to insert the sensor in the stream at the maximum rated pressure of 0.9 MPa (125 psi). Standard flexible conduit (user provided) can be easily utilized if desired for cable protection, etc. Overall Dimensions: 500 mm (19 in) long x 130 mm (5 in) high x 100 mm (4 in) wide. 1.3 m (48 in) from mounting (pipe, tank wall, etc.) is required to remove sensor from unit.

**Pressure/temperature:** 0.9 MPa (125 psi) at 20°C

- ✓ **Wetted parts:** Durable Ryton housing, Viton O-ring, electrodes and solution ground as noted.
- ✓ **Preamplifier:** Specify appropriate unit for use with 2220 Series Monitor or E99/E91 Series Transmitter (preamp Suffix B). 222F version is used with E99/E91 Series Transmitters with integral or remote preamplifier (HIZ module) with E99 HIZ Suffix A or C. 222F version may also be used with the high impedance input of various other pH units—but automatic temperature compensation compatible only with DIN 100 ohm platinum units. May be used with manually compensated or uncompensated units.
- ✓ **Cable:** 6 m (20 ft) integral cable terminated in numbered spade lugs. PVC jacketed cable on units with integral preamplifier, and units without preamplifier have vinyl jacketed cable.
- ✓ **Extension cable and junction boxes:** Sensor assemblies with integral preamplifier may be mounted up to 300 m (1000 ft) from the basic monitor or transmitter. For longer distances, or other assemblies, refer to Foxboro.
- ✓ **Electrical classification:** 222 Series electrode assemblies may be used in ordinary locations (general purpose) and in Class I, Groups A, B, C and D, Division 2. Certain assemblies may be used in Class I, Groups A, B, C and D, Division 1 locations when coupled to specified versions of pH transmitters. Electrical classification of sensor does not apply when used with optional electrode cleaning systems.

(70°F) or 0.5 MPa (70 psi) at 65°C (150°F) or 0.3 MPa (50 psi) at 95°C (200°F).

**Process line connection:** 1 1/2 NPT.

**Process wetted parts:** 316 SS process connection and housing. Glass filled polypropylene ball valve with pte seats and EPR O-ring seals.

#### Twist Lock Accessories

Twist lock connection for sensor assembly on flow chambers, bushings, tee and electrode protection sleeve listed below allows easy installation of sensor without tools. 90° rotation locks sensor in place and fittings are tapped for locking screw for added security.


Temperature and pressure specifications per Table.

Material	Temperature		Pressure	
	°C	°F	MPa	psi
PVC	50	120	0.4	60
316 SS	100	212	0.7	100

### Mounting Options (continued)


#### Flow Chambers

Inlet and outlet tapped for 1/4 NPT. Cell holder passes nominal 70 mesh (2 gpm) 316 SS or PVC as specified. Nominal size is 127 mm (5 in) high, 38 mm (1 1/2 in) diameter.



#### Bushings

Threaded bushing, 316 SS 1 1/4 or 1 1/2 NPT, or PVC 1 1/4 NPT as specified.



#### Tee

Solvent weld 1 inch IPS, PVC tee for insertion in pipeline.



#### Electrode Protection Sleeve PVC

For submersible unit only



### Interconnection Options For 222E or 222T Only

#### Junction Box

Provides junction box for interconnecting sensor assembly cable to extension cable to allow separation of sensor and monitor/transmitter to 300 m (1000 ft). Box provides the environmental protection of NEMA Type 4.

#### Extension Cable

For use with sensor and junction box specified above. Specify length.

#### Plug Options

Twist lock 316 SS or PVC plugs may be used to provide system security if sensor assembly is removed for inspection or service.

#### Spare Parts

It is recommended that an additional electrode kit, buffer packets or solution and a reference cavity refill kit be ordered with a basic system.

#### Electrode Kit

Contains electrode, replacement locking keeper and stud, and electrode removal tool and complete instructions. All parts necessary for field installation are provided. Electrode can be inserted or removed in less than a minute. For identification, the plug-in end of the electrode is color-coded, as per the chart below.

coded, as per the chart below:

Description	Color	Part Number
Glass pH Electrode Kit	White	0022505
Antimony pH Electrode Kit	Green	0022506
Platinum ORP Electrode Kit	Red	0022507
Gold ORP Electrode Kit	Black	0022508

### Reference Cavity Refill Kit

The refill kit contains the replaceable dual liquid reference junction, a bottle of saturated potassium chloride filling solution, all necessary tools, and complete instructions.

#### Buffers

Solution	Buffer	Volume	Part Number
Dry Powder	4.00 pH	1600 mL	00104KC
	7.00 pH	1600 mL	00104KB
	10.00 pH	1600 mL	00104KA

Packet mixed with distilled water makes .5L (16 fl oz) of buffer.


### Ordering Instructions:

Model and Description	
222E	Electrode Assembly with preamplifier (E99-E91 Series)
222F	Electrode Assembly without preamplifier (E99-E91 Series)
222T	Electrode Assembly (with preamplifier 2220 Series)
Electrode:	
-A	Glass pH
-B	Antimony pH
-D	Platinum ORP
-E	Gold ORP
Reference Junction:	
01	Ceramic
Mounting Options:	
-H	Ball Valve Unit
-M	Flow Chamber, 316 SS
-N	Flow Chamber, PVC
-P	Bushing, 1 1/4 NPT, 316 SS
-R	Bushing, 1 1/2 NPT, 316 SS
-S	Bushing, 1 1/4 NPT, PVC
-T	Tee, PVC, 1 IPS
-U	Electrode Protection Sleeve, PVC (submersion only)
Interconnection Options: (222E or T Series only)	
-1	Junction Box, NEMA 4
-2	Extension Cable (specify length)
Plug Options:	
-Y	PVC (N, S, T only)
-Z	316 SS (M, P, R only)

#### Example:

222T-A01-U (Electrode assembly with preamplifier for 2220 Series monitor, with glass pH electrode, ceramic reference junction and PVC electrode protection sleeve)





Item #2

**QUOTE FOR CHANGE ORDER (Less than \$500,000)**

VFAC 4330/43 (6/82) E/N 0105-LF-003-3430

CONTRACT #	CONTRACT TITLE	DATE
N62470-81-C-1644	Expansion of Holcomb Blvd. Water Treatment Plant	3/11/86

CHANGE DESCRIPTION:  
MOD # 35 Ph Sensor

PRIME CONTRACTOR'S WORK		REVISIONS
LABOR	-0-	
FRINGE BENEFITS	-0-	
MATERIAL (incl. sales tax)	1,384.00	
RENTAL EQUIPMENT (incl. sales tax)	-0-	
OPERATING & MINOR MAINT. FOR OWNED EQUIPMENT	=0-	
<b>SUB-TOTAL (1 + 2 + 3 + 4 + 5)</b>		1,384.00
FIELD OVERHEAD (10% of line 6)	138.00	
LIABILITY & COMPENSATION INS. ( % of line 1)	-0-	
<b>SUB-TOTAL (6 + 7 + 8)</b>		1,522.00
HOME OFFICE OVERHEAD (3% of line 9)	46.00	
EQUIPMENT OWNERSHIP EXPENSE	-0-	
SOCIAL SECURITY & UNEMPLOYMENT INS. ( % of line 1)	-0-	
<b>SUB-TOTAL (9 + 10 + 11 + 12)</b>		1,568.00

MARKS

SUB-CONTRACTOR'S WORK		
LABOR		
FRINGE BENEFITS		
MATERIAL (incl. sales tax)		
RENTAL EQUIPMENT (incl. sales tax)		
OPERATING & MINOR MAINT. FOR OWNED EQUIPMENT		
<b>SUB-TOTAL (14 + 15 + 16 + 17 + 18)</b>		
FIELD OVERHEAD (10% of line 19)		
LIABILITY & COMPENSATION INS. ( % of line 14)		
<b>SUB-TOTAL (19 + 20 + 21)</b>		
HOME OFFICE OVERHEAD (3% of line 22)		
EQUIPMENT OWNERSHIP EXPENSE		
SOCIAL SECURITY & UNEMPLOYMENT INS. ( % of line 14)		
<b>SUB-TOTAL (22 + 23 + 24 + 25)</b>		
PROFIT (6% of line 26)		
<b>SUB-TOTAL (26 + 27)</b>		


MARKS

SUMMARY		
PRIME CONTRACTOR'S WORK (from line 13)	1,568.00	
SUB-CONTRACTOR'S WORK (from line 28)	-0-	
PRIME CONTRACTOR'S OVERHEAD ON SUB-CONTRACT WORK (5% of line 30)	-0-	
<b>SUB-TOTAL (29 + 30 + 31)</b>		1,568.00
PRIME CONTRACTOR'S PROFIT (6% of line 32)	94.00	
<b>SUB-TOTAL (32 + 33)</b>		1,662.00
PRIME CONTRACT BOND PREMIUM ( % of line 34, actual)	8.00	
<b>TOTAL COST (34 + 35)</b>		1,670.00

ESTIMATED TIME EXTENSION AND JUSTIFICATION CALENDAR DAYS

HARRY PEPPER & ASSOCIATES, INC. Field Engineer

CONTRACTOR'S NAME SIGNATURE AND OFFICIAL TITLE



### INSTRUCTIONS FOR PREPARING CHANGE ORDER ESTIMATE

All Cost Estimates shall be addressed to the Resident Officer in Charge of Construction. Such requests must clearly state the conditions and scope of the change and shall be accompanied by a breakdown of cost as indicated. Lump sum items will not be accepted in either the prime or sub-contractor's breakdown. The total cost for labor, material, and equipment rentals for each item shall be transferred to the front of this form. At the contractor's option, the standard overhead rates shown on the front of this form may be used in lieu of detailed itemized estimates of field and home office overhead expenses. Requests for overhead rates in excess of the standard rates must be accompanied by an independently prepared audit report covering at least a current one-year period that substantiates the higher overhead costs claimed. The estimate should also include a request for an extension of time, in calendar days, if any, required in order to complete the work covered by the proposed change. The contractor shall not proceed with any of the work included in the change prior to written approval of the Resident Officer in Charge of Construction.


#### BREAKDOWN ESTIMATE OF DIRECT COSTS

CONTRACT NO.  
N62470-81-C-1644

NAME OF CONTRACTOR  
HARRY PEPPER & ASSOCIATES, INC

CONTRACTOR  
 PRIME  SUBCONTRACTOR

ITEM NO.	ITEM OF WORK	NO. OF UNITS	LABOR		MATERIAL		EQUIPMENT			TOTAL COST
			UNIT COST	TOTAL COST	UNIT COST	TOTAL COST	EGU. DAYS	RATE	TOTAL COST	
1.	Original Sensor CREDIT	1	-----	-----	(1151.00)	(1151.00)	-----	---	-----	(1,151.
2.	Removable Sensor	1	-----	-----	2,475.00	2,475.00	-----	---	-----	\$2,475.
			XXX	-----	XXX	1,324.00	XXXXX	XX	-----	1,324



Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**

LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO 81-C-1644		TRANSMITTAL NO 114-A	DATE 1-3-86
FROM CONTRACTOR Harry Pepper & Associates, Inc.		PROJECT TITLE AND LOCATION Holcomb Blvd Water Treatment Plant	
TO Henry Von Oesen & Associates, Inc.		MCB, Cp Lejeune, North Carolina	

<p align="center"><b>CONTRACTOR USE ONLY</b></p> <p align="center">*List only one specification division per form.</p> <p align="center">List only one of the following categories on each transmittal form, and indicate which is being submitted</p> <p><input type="checkbox"/> Contractor Approved      <input checked="" type="checkbox"/> OICC Approval      <input type="checkbox"/> Deviation/Substitution For OICC Approval</p>	<p align="center"><b>REVIEWER USE ONLY</b></p> <p align="center">**ACTION CODES</p> <p>A-Approved D-Disapproved AN-Approved as noted RA-Receipt acknowledged C-Comments R-Resubmit</p>
--	--

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
11336		WATER TREATMENT EQUIPMENT			
1	6.5	Shop Drawings on Acid Transfer Pumps and Acid Feed Pumps, Control Panel	7	AN	JPB 1/9/86

CONTRACTOR'S COMMENTS

Shop Drawings have been revised. See Transmittal # 114, dated 10-17-85.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC <b>ONE COPY TO ROICC</b>		CONTRACTOR REPRESENTATIVE (Signature) Phil Reese <i>Phil Reese</i>
DATE RECEIVED BY REVIEWER 1/6/86	FROM (Reviewer) Henry von Oesen & Assoc., Inc.	TO ROICC

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

Equipment submittals must be coordinated with other equipment with which it operates to assure that they are compatible and complete and that the system will perform the required function.

COPIES TO ROICC (2) LANTDIV (1) A-E (1)	DATE 10 20 1986 1/9/86	SIGNATURE <i>Phil Reese</i>
--	------------------------------	--------------------------------

10 JAN 1986 11 17

THE UNITED STATES OF AMERICA  
DEPARTMENT OF JUSTICE  
FEDERAL BUREAU OF INVESTIGATION

*[Handwritten signature]*

UNITED STATES OF AMERICA

FEDERAL BUREAU OF INVESTIGATION

MEMORANDUM FOR THE DIRECTOR

DATE: 10 JAN 1986


TO: DIRECTOR, FBI

FROM: SAC, [illegible]




SUBJECT: [illegible]

CONTROL PANEL—LAYOUT AND FABRICATION—FRONT & SIDE

SCALE 1/4" = 1.0"



ACID TRANSFER PUMP AND ACID METERING PUMP WIRING DIAGRAM



FLOW DIAGRAM

ATLANTIC DIVISION  
NAVAL FACILITIES ENGINEERING COMMAND  
NORFOLK, VIRGINIA 23511

APPROVED: \_\_\_\_\_  
APPROVED FOR USE: \_\_\_\_\_  
DISAPPROVED: \_\_\_\_\_

SUBJECT TO THE REQUIREMENTS OF  
CONTRACT NO. N62470-81-C-1644

APPROVAL OF THIS DRAWING DOES NOT INCLUDE  
APPROVAL OF ANY PORTION THEREOF FROM THE CONTRACTOR'S INSURANCE COVERAGE. THE CONTRACTOR'S INSURANCE COVERAGE SUPPORTS THE PRIMA FACIE ASSUMPTION THAT THE CONTRACTOR IS RESPONSIBLE FOR OBTAINING NECESSARY PHYSICAL PERMITS AND NECESSARY COORDINATION OF TRADES, ETC., AS REQUIRED.

REVIEWER: Shawn A. Date DATE: 1/3/86  
FOR OFFICER IN CHARGE OF CONSTRUCTION

"It is hereby certified that the material (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

Approved for use. \_\_\_\_\_  
Submitted for Government approval. \_\_\_\_\_  
Approved for use subject to Government approval of specific deviation. \_\_\_\_\_

Authorized Reviewer: Shawn A. Date DATE: \_\_\_\_\_  
Signature CQC Rep. Shawn A. Date DATE: 1-3-86

COMBS & ASSOCIATES, INC.  
CHARLOTTE, NORTH CAROLINA

EXPANSION HOLCOMB BOULEVARD WTP

SCALE: AS SHOWN  
DRAWN BY: DAH  
REVISED: 12-3-85

ACID FEED AREA CONTROL PANEL

DATE: 9-10-85  
APPROVED BY: \_\_\_\_\_  
DRAWING NUMBER: HB102



Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**

LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO <b>81-C-1644</b>	TRANSMITTAL NO <b>111</b>	DATE <b>10-17-85</b>
---------------------------------	------------------------------	-------------------------

FROM CONTRACTOR  
**Harry Pepper & Associates, Inc.**

TO  
**Henry Von Oesen & Associates, Inc.**

PROJECT TITLE AND LOCATION  
**Holcomb Blvd Water Treatment Plant**  
**Cp Lejeune, North Carolina**

**CONTRACTOR USE ONLY**

\*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

- Contractor Approved       OICC Approval       Deviation/Substitution For OICC Approval

**REVIEWER USE ONLY**

\*\*ACTION CODES

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit

ITEM NO	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1	4.2	Manufacturer's Data on Filter Bottom Anchor Bolts	4	RA	EdR 10/21/85

CONTRACTOR'S COMMENTS

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

**ONE COPY TO ROICC**

Phil Reese *Phil Reese*

DATE RECEIVED BY REVIEWER

FROM (Reviewer)

TO

**10/21/85**

**Henry von Oesen & Assoc.**

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

Contractors approval appears to be appropriate.

HENRY VON OESSEN AND ASSOCIATES, INC.

COPIES TO  
ROICC (2)  
LANTDIV (1)  
A-E (1)

DATE

**10/21/85**

SIGNATURE

*Phil Reese*

22 OCT 1985 11 12

THE UNIVERSITY OF MICHIGAN LIBRARY

ANN ARBOR, MICHIGAN 48106-1000

LIBRARY

UNIVERSITY OF MICHIGAN LIBRARY

UNIVERSITY OF MICHIGAN LIBRARY

UNIVERSITY OF MICHIGAN LIBRARY

*Handwritten signature or initials*

UNIVERSITY OF MICHIGAN LIBRARY

Contract N62470-81-C1644  
Holcomb Boulevard Water Treatment Plant  
Marine Corps Base  
Camp Lejeune, North Carolina

Equipment Submittal  
Section 11336

Henry von Oeson & Associates  
Engineer  
Wilmington, North Carolina

Harry Pepper & Associates, Inc.  
Contractors  
Jacksonville, Florida

Anchor Bolts

Purchase Order # 642-0011

August 15, 1985

"It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut(s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

Approved for use.  
 Submitted for Government approval.  
 Approved for use subject to Government approval of specific deviation.


Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_  
Signature CQC Rep. Phil Pease DATE 10-17-85



# Thunder Stud

THE ULTIMATE CONCRETE WEDGE ANCHOR


PATENT NUMBERS 31,171,322 / 3,216,305 / 3,667,341




## 3 Concrete Reasons To Use Thunderstud

1. The Thunderstud is the ultimate concrete anchor.
  2. Once complete, it's nuts and bolts ready to use.
  3. Collar design offers full strength with no epoxy.
- Available in collar and non-collar configurations.
- For more information, contact your distributor or call 1-800-451-7829.


## EASY INSTALLATION



UNIFAST INDUSTRIES, INC. 45 GILPIN AVE., HAUPPAUGE, NY 11788/516-348-0290/TELEX: 5102246151



# ThunderStud Technical Data



Listed by Underwriters Laboratories (UL), International Conference of Building Officials (ICBO), Board of Standards and Appeals (BSA)

Meets or exceeds U.S. Government G.S.A. Specifications FF-S-325 Group 11, Type 4, Class 1

Size	Carbon Steel Cat. No.	Stainless Steel (Grade 303) Cat. No.	Galvanized Steel Cat. No.	Hole Size & Threads Per Inch	Fastens Material Up To	Thread Length	Minimum Embed.	Ultimate Pullout* Lbs.	Ultimate Shear* Lbs.
1/4 x 1 3/4"	TS-14-134	TS-14-134SS		1/4" / 20	3/16"	3/4"	1 1/8"	1855	1647
1/4 x 2 1/4"	TS-14-214	TS-14-214SS		1/4" / 20	5/8"	3/4"	1 1/8"	1855	1647
1/4 x 3"	TS-14-3	TS-14-3SS		1/4" / 20	1 1/2"	3/4"	1 1/8"	1855	1647
5/16 x 2"	TS-516-2	TS-516-2SS		5/16" / 18	1/8"	7/8"	1 1/2"	2500	2455
5/16 x 2 1/4"	TS-516-234	TS-516-234SS		5/16" / 18	5/8"	7/8"	1 1/2"	2500	2455
5/16 x 3 1/2"	TS-516-312	TS-516-312SS		5/16" / 18	1 1/2"	7/8"	1 1/2"	2500	2455
5/16 x 5"	TS-516-5	TS-516-5SS		5/16" / 18	2 3/4"	7/8"	1 1/2"	2500	2455
3/8 x 2 1/2"	TS-38-218	TS-38-218SS		3/8" / 16	1/8"	7/8"	1 1/2"	3075	3294
3/8 x 2 3/4"	TS-38-234	TS-38-234SS		3/8" / 16	1/2"	7/8"	1 1/2"	3075	3294
3/8 x 3"	TS-38-3	TS-38-3SS		3/8" / 16	3/4"	7/8"	1 1/2"	3075	3294
3/8 x 3 1/2"	TS-38-312	TS-38-312SS		3/8" / 16	1 1/4"	7/8"	1 1/2"	3075	3294
3/8 x 3 3/4"	TS-38-334	TS-38-334SS		3/8" / 16	1 1/2"	7/8"	1 1/2"	3075	3294
3/8 x 5"	TS-38-5	TS-38-5SS		3/8" / 16	2 3/4"	7/8"	1 1/2"	3075	3294
1/2 x 2 1/4"	TS-12-234	TS-12-234SS		1/2" / 13	1/8"	1 1/2"	2 1/4"	4982	6243
1/2 x 3 1/4"	TS-12-334	TS-12-334SS		1/2" / 13	7/8"	1 1/2"	2 1/4"	4982	6243
1/2 x 4 1/4"	TS-12-414	TS-12-414SS	TS-12-414G	1/2" / 13	1 1/2"	1 1/2"	2 1/4"	4982	6243
1/2 x 5 1/2"	TS-12-512	TS-12-512SS	TS-12-512G	1/2" / 13	2 1/2"	1 1/2"	2 1/4"	4982	6243
1/2 x 7"	TS-12-7	TS-12-7SS		1/2" / 13	4"	1 1/2"	2 1/4"	4982	6243
5/8 x 3 1/2"	TS-58-312	TS-58-312SS		5/8" / 11	3/16"	1 1/2"	2 3/4"	7007	8084
5/8 x 4 1/2"	TS-58-412	TS-58-412SS		5/8" / 11	1 1/8"	1 1/2"	2 3/4"	7007	8084
5/8 x 5"	TS-58-5	TS-58-5SS		5/8" / 11	1 1/2"	1 1/2"	2 3/4"	7007	8084
5/8 x 6"	TS-58-6	TS-58-6SS	TS-58-6G	5/8" / 11	2 1/2"	1 1/2"	2 3/4"	7007	8084
5/8 x 7"	TS-58-7	TS-58-7SS		5/8" / 11	3 1/2"	1 1/2"	2 3/4"	7007	8084
5/8 x 8"	TS-58-8	TS-58-8SS		5/8" / 11	4 1/2"	1 1/2"	2 3/4"	7007	8084
5/8 x 8 1/2"	TS-58-812	TS-58-812SS		5/8" / 11	5"	1 1/2"	2 3/4"	7007	8084
3/4 x 4 1/4"	TS-34-414	TS-34-414SS		3/4" / 10	1/2"	1 1/2"	3 3/4"	10820	12556
3/4 x 4 3/4"	TS-34-434	TS-34-434SS		3/4" / 10	3/4"	1 1/2"	3 3/4"	10820	12556
3/4 x 5 1/2"	TS-34-512	TS-34-512SS	TS-34-512G	3/4" / 10	1 1/2"	1 1/2"	3 3/4"	10820	12556
3/4 x 7"	TS-34-7	TS-34-7SS		3/4" / 10	3"	1 1/2"	3 3/4"	10820	12556
3/4 x 8 1/2"	TS-34-812	TS-34-812SS	TS-34-812G	3/4" / 10	4 1/2"	1 1/2"	3 3/4"	10820	12556
3/4 x 10"	TS-34-10	TS-34-10SS		3/4" / 10	6"	1 1/2"	3 3/4"	10820	12556
7/8 x 6"	TS-78-6	TS-78-6SS	TS-78-6G	7/8" / 9	1"	2 1/4"	4"	13244	22360
7/8 x 8"	TS-78-8	TS-78-8SS	TS-78-8G	7/8" / 9	3"	2 1/4"	4"	13244	22360
7/8 x 10"	TS-78-10	TS-78-10SS		7/8" / 9	5"	2 1/4"	4"	13244	22360
7/8 x 12"	TS-78-12	TS-78-12SS		7/8" / 9	7"	2 1/4"	4"	13244	22360
1 x 6"	TS-1-6	TS-1-6SS		1" / 8	1/2"	2 1/4"	4 1/2"	15188	20250
1 x 9"	TS-1-9	TS-1-9SS	TS-1-9G	1" / 8	3 1/2"	2 1/4"	4 1/2"	15188	20250
1 x 12"	TS-1-12	TS-1-12SS		1" / 8	6 1/2"	2 1/4"	4 1/2"	15188	20250
1 1/4 x 9"	TS-114-9	TS-114-9SS		1 1/4" / 7	2 1/4"	2 1/4"	5 1/2"	29952	40784
1 1/4 x 12"	TS-114-12	TS-114-12SS		1 1/4" / 7	5 1/4"	2 1/4"	5 1/2"	29952	40784

•UL LISTED Grades 304, 316 Stainless Available Upon Request. Special Lengths Available Upon Request.

\*Ultimate load capacity in 4000 PSI concrete. Laboratory test reports available upon request. Safe working loads for static loading should not exceed 25% of ultimate loads.




**UNIFAST INDUSTRIES, INC.**

45 GILPIN AVE., HAUPPAUGE, NY 11788

**516-348-0290**

SOLD ONLY THROUGH AUTHORIZED DISTRIBUTORS

Distributed by:



# LOAD CALCULATIONS

## DOWNWARD FORCE


FILTER BLOCK 4 SQ FT = 150#/BLOCK	
9-3" CERAMIC SPHERES = 11.16#/BLOCK	
36-1 3/8" CERAMIC SPHERES = 4.32#/BLOCK	
165.48#/BLOCK ÷ 4 SQ.FT./BLOCK =	41.37#/SQ FT.
12" GRAVEL @ 100#/CUFT =	100.00 #/SQ FT.
27" SAND @ 100#/CUFT =	225.00 #/SQ FT.
2'-6" WATER TO THE LIP OF THE TROUGH = 62.4 X 2.5 =	156.00 #/SQ FT.
WEIGHT OF WATER IN PORE SPACE OF MEDIA =	<u>81.00 #/SQ FT.</u>
	603.37 #/SQ FT.

$h_L$  OF ±250' PIPE @ 18"  $\phi$  = ±1.0'  
 $h_L$  THROUGH ISOLATION VALVE @ 30° = 45'  
 $h_L$  THROUGH CONTROL VALVE = (17.46 PSI @  
 50' @ 7000 gpm

PSI SUPPLY → 50' X 62.4 = 3120 POUNDS/SQ FT = 21.64 PSI  
 PSI BACKPRESSURE = 603.37 #/SQ FT = -4.18 PSI

17.46 PSI CONTROL VALVE ANGLE = 35° OPEN

ANCHOR BOLTS




THUNDERSTUD 303 STAINLESS STEEL

1/2"  $\phi$  5" ANCHOR DEPTH = WORKING PULLOUT @ 1878 #  
 ULTIMATE @ 7512 # PULLOUT

17.46 PSI X 144 = 2514.24 POUNDS/SQ FT  
 X 360 SQ FT/FILTER  
905,126 #/FILTER = 8228 #/BOLT  
 110 BOLTS

HOLCOMB BLVD WTP  
FILTER BOTTOM ANCHORS



4000 PSI CONCRETE

5/8" $\phi$	4 1/2" EMBED	11,658 # PULLOUT	ULTIMATE
	6" EMBED	13,358 # PULLOUT	"
3/4" $\phi$	5 1/2" EMBED	15,265 # PULLOUT	"
	4 1/2" EMBED	11,589 # PULLOUT	"

$$3/4" \phi \quad 5 1/2" \text{ EMBED} \quad \frac{15265 \# \text{ PULLOUT}}{4} = 3816.25 \text{ WORKING STRENGTH}$$

$$\frac{\times 110 \text{ BOLTS}}{419,787 \# \text{ WORKING STRENGTH FOR 110 BOLTS}}$$

17.46 PSI


$$\frac{8.09 \text{ PSI}}{9.37 \text{ PSI}}$$

40° ANGLE ON VALVE


$$\frac{419,787 \#}{360 \text{ SQ FT} \times 144 \text{ SQ IN/SQ FT}} = 8.09 \text{ PSI}$$

USE - 3/4"  $\phi$  ANCHOR BOLT  $\leftarrow$   
 5 1/2" EMBED IN 4000 PSI CONCRETE

\*\*\* NOTE: CONTRACTOR TO LIMIT & IF POSSIBLE CUT BACK UP TO 15 PSI FROM BACKWASH PUMP OUTPUT AS DELIVERED TO THE FILTER BY THROTTLING AFTER THE BACKWASH PUMP AND/OR STOPS ON THE ISOLATION & THROTTLING VALVES TO LIMIT OPENING OF THE VALVES TO CREATE HEADLOSS.




CONTROL VALVE



SIZING NOMOGRAPH FOR (S.I.B.O.) SURESEAL BUTTERFLY VALVES  
CLASS 150A - 150B

Fig. 5




# BIF


BASIC IN FLOW

A UNIT OF GENERAL SIGNAL · WEST WARWICK, R.I. 02893

ISOLATION VALVE

FLOW OF WATER THRU WIDE OPEN (90°) BUTTERFLY VALVE (S.I.B.O. SURESEAL) 150 A & B





Hant

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
LANTDIV.NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO <b>81-C-1644</b>	TRANSMITTAL NO <b>172</b>	DATE <b>3-4-86</b>
---------------------------------	------------------------------	-----------------------

FROM CONTRACTOR  
**Harry Pepper & Associates, Inc.**

TO  
**Henry Von Oesen & Associates, Inc.**

PROJECT TITLE AND LOCATION  
**Holcomb Blvd Water Treatment Plant**

**MCB, Cp Lejeune, North Carolina**

<p align="center"><b>CONTRACTOR USE ONLY</b></p> <p align="center"><i>List only one specification division per form.</i></p> <p align="center"><i>List only one of the following categories on each transmittal form, and indicate which is being submitted</i></p> <p><input checked="" type="checkbox"/> Contractor Approved      <input type="checkbox"/> OICC Approval      <input type="checkbox"/> Deviation/Substitution For OICC Approval</p>	<p align="center"><b>REVIEWER USE ONLY</b></p> <p align="center"><b>**ACTION CODES</b></p> <p>A-Approved D-Disapproved AN-Approved as noted RA-Receipt acknowledged. C-Comments R-Resubmit</p>
---	--

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1	4.2	Manufacturer's Data on Filter Bottom Anchor Bolts.	4	RA	ROB 3/13/86

CONTRACTOR'S COMMENTS

This Transmittal replaces Transmittal # 111, dated 10-17-85. Anchor Bolts originally submitted were designed by the wrong criteria, per discussion between Combs and Associates and Mr. Robbie Benson, of Henry Von Oesen.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC		CONTRACTOR REPRESENTATIVE (Signature)	
<b>ONE COPY TO ROICC</b>		Phil Reese <i>Phil Reese</i>	
DATE RECEIVED BY REVIEWER	FROM (Reviewer)	TO	
<b>3/7/86</b>	<b>Henry von Oesen &amp; Assoc., Inc.</b>		

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

Contractor's approval appears to be appropriate.

COPIES TO ROICC (2) LANTDIV (1) A-E (1)	DATE <b>3/13/86</b>	SIGNATURE <i>[Signature]</i>
--	------------------------	---------------------------------

14 MAR 1986 11 31


*[Handwritten signature]*

*[Handwritten text]*


*[Handwritten marks]*

## PULL OUT CALCULATIONS

ANCHOR BOLTS ORIGINALLY DISCUSSED & SUBMITTED WERE DESIGNED BY THE WRONG CRITERIA. DURING A DISCUSSION ON FILTER BOTTOM ANCHORING WITH MR. ROBBIE BENSON, OF HENRY VON OESON, CONSULTING ENGINEERS FOR THIS PROJECT, IT WAS DETERMINED THAT 2PSI SHOULD BE THE ABSOLUTE MAXIMUM HEAD LOSS THROUGH THE FILTER BOTTOM. THE CALCULATIONS BELOW VERIFY A 1/2"  $\phi$  ANCHOR BOLT WHICH IS THE INDUSTRY STANDARD FOR ANCHORING FILTER BOTTOMS.



N.T.S.



$$2 \text{ PSI HEAD LOSS} = \frac{4 \text{ SQ. FT}}{\frac{2 \text{ PSI} = 4.62 \text{ H}_2\text{O}}$$

$$462 \times 62.4 \text{ #/cuft} \times 4 \text{ SQ FT} = 1,153 \text{ #}$$

$$\text{SAFETY FACTOR} = 4$$

$$4 \times 1,153 \text{ #} = 4,612 \text{ # ULTIMATE}$$

USE 1/2" X 2 1/4" EMBEDDED (LENGTHS AS NECESSARY)  
THUNDER STUD

SS ANCHOR BOLTS (303SS)

EACH FILTER TO HAVE 72 BOLTS 29" LONG - EMBED X 2 1/4"

$$\therefore 72 \times 3 = 216 - 29" \text{ LONG} \times 2 1/4" \text{ EMBED}$$

EACH FILTER HAS 38 BOLTS 7" LONG - EMBED X 2 1/4"

$$\therefore 38 \times 3 = 114 - 7" \text{ LONG BOLTS} \times 2 1/4" \text{ EMBED}$$

It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:


- Approved for use.
- Submitted for Government approval.
- Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_  
Signature CQC Rep. Phil Peew DATE 3-4-86

# Thunder Stud

THE ULTIMATE CONCRETE WEDGE ANCHOR

PATENT NUMBERS 3,177,022 3,216,031 3,667,341




3 Concrete Reasons to Use Thunder Stud

1. Anchor diameter equals hole diameter

2. Comes complete with nuts and washers ready for use

3. Collar expands after full set contact with masonry


EASY INSTALLATION



UNIFAST INDUSTRIES, INC. 45 GILPIN AVE., HAUPPAUGE, NY 11788/516-348-0290/TELEX: 5102246151

FTS-84

## ThunderStud Technical Data



Listed by Underwriters Laboratories (UL), International Conference of Building Officials (ICBO), Board of Standards and Appeals (BSA)  
Meets or exceeds U.S. Government G.S.A. Specifications FF-S-325 Group 11, Type 4, Class 1

Size	Carbon Steel Cat. No.	Stainless Steel (Grade 304) Cat. No.	Galvanized Steel Cat. No.	Hole Size & Threads Per Inch	Fastens Material Up To	Thread Length	Minimum Embed.	Ultimate Pullout* Lbs.	Ultimate Shear* Lbs.
1/4 x 1 1/2"	TS-14-134	TS-14-134SS		1/4" / 20	3/16"	3/4"	1 1/2"	1855	1647
1/4 x 2"	TS-14-214	TS-14-214SS		1/4" / 20	5/8"	3/4"	1 1/2"	1855	1647
1/4 x 3"	TS-14-3	TS-14-3SS		1/4" / 20	1 1/2"	3/4"	1 1/2"	1855	1647
5/16 x 2"	TS-516-2	TS-516-2SS		5/16" / 18	7/8"	7/8"	1 1/2"	2500	2455
5/16 x 2 1/4"	TS-516-234	TS-516-234SS		5/16" / 18	5/8"	1 1/4"	1 1/2"	2500	2455
5/16 x 3 1/4"	TS-516-312	TS-516-312SS		5/16" / 18	1 1/4"	1 1/4"	1 1/2"	2500	2455
5/16 x 5"	TS-516-5	TS-516-5SS		5/16" / 18	2 1/4"	1 1/4"	1 1/2"	2500	2455
3/8 x 2 1/2"	TS-36-218	TS-36-218SS		3/8" / 16	1 1/8"	7/8"	1 1/2"	3075	3294
3/8 x 2 3/4"	TS-36-234	TS-36-234SS		3/8" / 16	1 1/2"	1 1/4"	1 1/2"	3075	3294
3/8 x 3"	TS-36-3	TS-36-3SS		3/8" / 16	3/4"	1 1/4"	1 1/2"	3075	3294
3/8 x 3 1/2"	TS-36-312	TS-36-312SS		3/8" / 16	1 1/4"	1 1/4"	1 1/2"	3075	3294
3/8 x 3 3/4"	TS-36-334	TS-36-334SS		3/8" / 16	1 1/2"	1 1/4"	1 1/2"	3075	3294
3/8 x 5"	TS-36-5	TS-36-5SS		3/8" / 16	2 1/4"	1 1/4"	1 1/2"	3075	3294
1/2 x 2 1/2"	TS-12-234	TS-12-234SS		1/2" / 13	1 1/8"	1 1/4"	2 1/4"	4982	6243
1/2 x 3"	TS-12-304	TS-12-304SS		1/2" / 13	1 1/8"	1 1/4"	2 1/4"	4982	6243
1/2 x 4 1/4"	TS-12-414	TS-12-414SS	TS-12-414G	1/2" / 13	1 1/2"	1 1/4"	2 1/4"	4982	6243
1/2 x 5 1/2"	TS-12-512	TS-12-512SS	TS-12-512G	1/2" / 13	2 1/4"	1 1/4"	2 1/4"	4982	6243
1/2 x 7"	TS-12-7	TS-12-7SS		1/2" / 13	4"	1 1/4"	2 1/4"	4982	6243
5/8 x 3 1/2"	TS-58-312	TS-58-312SS		5/8" / 11	3 1/8"	1 1/2"	2 1/4"	7007	8084
5/8 x 4 1/2"	TS-58-412	TS-58-412SS		5/8" / 11	1 1/2"	1 1/2"	2 1/4"	7007	8084
5/8 x 5"	TS-58-5	TS-58-5SS		5/8" / 11	1 1/4"	1 1/2"	2 1/4"	7007	8084
5/8 x 6"	TS-58-6	TS-58-6SS	TS-58-6G	5/8" / 11	2 1/2"	1 1/2"	2 1/4"	7007	8084
5/8 x 7"	TS-58-7	TS-58-7SS		5/8" / 11	3 1/2"	1 1/2"	2 1/4"	7007	8084
5/8 x 8"	TS-58-8	TS-58-8SS		5/8" / 11	4 1/2"	1 1/2"	2 1/4"	7007	8084
5/8 x 8 1/2"	TS-58-812	TS-58-812SS		5/8" / 11	5"	1 1/2"	2 1/4"	7007	8084
3/4 x 4 1/4"	TS-34-414	TS-34-414SS		3/4" / 10	1 1/2"	1 1/2"	3 1/4"	10820	12556
3/4 x 4 3/4"	TS-34-434	TS-34-434SS		3/4" / 10	3 1/4"	1 1/2"	3 1/4"	10820	12556
3/4 x 5 1/2"	TS-34-512	TS-34-512SS	TS-34-512G	3/4" / 10	1 1/2"	1 1/2"	3 1/4"	10820	12556
3/4 x 7"	TS-34-7	TS-34-7SS		3/4" / 10	4 1/2"	1 1/2"	3 1/4"	10820	12556
3/4 x 8 1/2"	TS-34-812	TS-34-812SS	TS-34-812G	3/4" / 10	6"	1 1/2"	3 1/4"	10820	12556
7/8 x 6"	TS-78-6	TS-78-6SS	TS-78-6G	7/8" / 9	1"	2 1/4"	4"	13244	22360
7/8 x 8"	TS-78-8	TS-78-8SS	TS-78-8G	7/8" / 9	3"	2 1/4"	4"	13244	22360
7/8 x 10"	TS-78-10	TS-78-10SS		7/8" / 9	5"	2 1/4"	4"	13244	22360
7/8 x 12"	TS-78-12	TS-78-12SS		7/8" / 9	7"	2 1/4"	4"	13244	22360
1 x 6"	TS-1-6	TS-1-6SS		1" / 8	1 1/2"	2 1/4"	4 1/2"	15188	20250
1 x 8"	TS-1-8	TS-1-8SS	TS-1-8G	1" / 8	3 1/2"	2 1/4"	4 1/2"	15188	20250
1 x 12"	TS-1-12	TS-1-12SS		1" / 8	6 1/2"	2 1/4"	4 1/2"	15188	20250
1 1/4 x 8"	TS-114-8	TS-114-8SS		1 1/4" / 7	2 1/4"	2 1/4"	5 1/2"	29952	40784
1 1/4 x 12"	TS-114-12	TS-114-12SS		1 1/4" / 7	5 1/2"	2 1/4"	5 1/2"	29952	40784

\*UL LISTED Grades 304, 316 Stainless Available Upon Request. Special Lengths Available Upon Request.

\*Ultimate load capacity in 4000 PSI concrete. Laboratory test reports available upon request. Safe working loads for static loading should not exceed 25% of ultimate loads.

SOLD ONLY THROUGH AUTHORIZED DISTRIBUTORS




UNIFAST INDUSTRIES, INC.


45 GILPIN AVE., HAUPPAUGE, NY 11788

516-348-0290

Distributed by:




UNIFAST INDUSTRIES INC. - Printed in U.S.A.



UNIVERSAL FASTENINGS CORPORATION

PART NO.	DIA. (in.)	EMBED. (in.)	CONCRETE STRENGTH (PSI)	TENSION				SHEAR			
				AVG. LOAD @ 1/16" (lbs.)	AVG. ULT. LOAD (lbs.)	TYPICAL MODE OF FAILURE*	NO. TESTS	AVG. LOAD @ 1/16" (lbs.)	AVG. ULT. LOAD (lbs.)	TYPICAL MODE OF FAILURE*	NO. TESTS
TS 12-234	1/2	2 1/4	2000	1315	3415	C-C	3	2875	6115	S	3
TS 12-334		3		2602	4452	C-C	3	3049	6491	S	5
TS 12-512		3 1/2		2146	4576	P-O	3	3781	7996	S	3
TS 12-7		4		3103	5950	P-O	5	4939	8042	S	3
TS 12-234	1/2	2 1/4	4000	3869	4982	C-C	3	1625	6243	S	3
TS 12-334		3		2029	6852	P-O, C-C	3	3729	7307	S	3
TS 12-512		3 1/2		2938	9537	P-O	3	6170	11021	S	3
TS 12-7		4		2375	8679	P-O	3	4969	8050	S	3
TS 12-234	1/2	2 1/4	6000	3012	5982	C-C	3	3307	7062	S	3
TS 12-334		3		3864	9557	P-O, C-C	3	3568	6601	S	3
TS 12-512		3 1/2		4988	9293	P-O, C-C, A-D	3	5385	10899	S	3
TS 12-7		4		4561	11019	A-D	3	6669	10051	S	3

\* P-O - Pull out  
 C-C - Concrete cone  
 S - Shear  
 A-D - Anchor Device through reduced  
 portion of bolt diameter



Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**

LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO 81-C-1644	TRANSMITTAL NO 161	DATE 1-28-86
--------------------------	-----------------------	-----------------

FROM CONTRACTOR  
**Harry Pepper & Associates, Inc.**

TO  
**Henry Von Oesen & Associates, Inc.**

PROJECT TITLE AND LOCATION  
**Holcomb Blvd Water Treatment Plant**

**MCB, Cp Lejeune, North Carolina**

**CONTRACTOR USE ONLY**

\*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

- Contractor Approved       OICC Approval       Deviation/Substitution For OICC Approval

**REVIEWER USE ONLY**

**\*\*ACTION CODES**

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit.

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	02713	EXTERIOR WATER DISTRIBUTION SYSTEM			
1	1.3.2 2.2.7	Manufacturer's Certification on 12 inch Single Acting Altitude Valve.	4	RA	JB

**CONTRACTOR'S COMMENTS**

This Certification is for the 12 inch Altitude Valve located at the Montford Point Elevated Storage Tank.

**COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC**

ONE COPY TO ROICC

**CONTRACTOR REPRESENTATIVE (Signature)**

Phil Reese

**DATE RECEIVED BY REVIEWER**

1/29/86

**FROM (Reviewer)**

Henry von Oesen & Assoc.

**TO**

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

**REVIEWER'S COMMENTS**

Contractor's approval appears to be appropriate.

COPIES TO  
ROICC (2)  
LANTDIV (1)  
A-E (1)

**DATE**

30 JAN 1986  
1/29/86

**SIGNATURE**

30 JAN 1986 13 09

UNITED STATES DEPARTMENT OF JUSTICE

OFFICE OF THE ATTORNEY GENERAL

WASHINGTON, D.C.

2053 LIND

*[Handwritten signature]*

UNITED STATES DEPARTMENT OF JUSTICE

January 23, 1986

The Bryant Companies  
P.O. Box 1430  
High Point, NC 27261

Subject: P.O. 8539-14  
GAI #850683Rev#1  
Camp LeJeune, NC  
Holcomb Blvd. WTP Expansion  
#N62470-81-B-1644

Attn: Mr. Richard Money

Dear Mr. Money:

We hereby certify that the 12" Fig. 3200-D, Single-Acting Altitude Valve provided on the subject order is of standard materials and meets the above specifications.

Very truly yours,

GA INDUSTRIES, INC.

*Janet L. McKinney*  
Janet L. McKinney

cc Heyward, Inc. (NC)

Sworn before me on this

day 23rd of JAN 1986

*Juanita M. Scharf*

JUANITA M. SCHARF, NOTARY PUBLIC  
CRANBERRY TWP., BUTLER COUNTY  
MY COMMISSION EXPIRES JULY 11, 1989  
Member, Pennsylvania Association of Notaries

It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

- Approved for use.
- Submitted for Government approval.
- Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_  
Signature CQC Rep. *Phil Reese* DATE 1-28-86

Sworn before me on this

\_\_\_\_\_ of 1913

Member, National Association of Writers  
at \_\_\_\_\_  
\_\_\_\_\_ 1913

and to \_\_\_\_\_  
I, \_\_\_\_\_  
Notary for Government approval  
I have for the subject to Government approval  
\_\_\_\_\_ approved  
DATE \_\_\_\_\_  
\_\_\_\_\_



27 JUN 1985 11 22

UNITED STATES DEPARTMENT OF JUSTICE  
FEDERAL BUREAU OF INVESTIGATION

MEMORANDUM FOR THE DIRECTOR, FBI  
FROM: SAC, [illegible]  
SUBJECT: [illegible]

RE: [illegible]

NO.	DATE	DESCRIPTION	INITIALS	REMARKS
1	6/27/85	[illegible]	[illegible]	[illegible]
2	6/27/85	[illegible]	[illegible]	[illegible]
3	6/27/85	[illegible]	[illegible]	[illegible]
4	6/27/85	[illegible]	[illegible]	[illegible]
5	6/27/85	[illegible]	[illegible]	[illegible]
6	6/27/85	[illegible]	[illegible]	[illegible]
7	6/27/85	[illegible]	[illegible]	[illegible]
8	6/27/85	[illegible]	[illegible]	[illegible]
9	6/27/85	[illegible]	[illegible]	[illegible]
10	6/27/85	[illegible]	[illegible]	[illegible]
11	6/27/85	[illegible]	[illegible]	[illegible]
12	6/27/85	[illegible]	[illegible]	[illegible]
13	6/27/85	[illegible]	[illegible]	[illegible]
14	6/27/85	[illegible]	[illegible]	[illegible]
15	6/27/85	[illegible]	[illegible]	[illegible]
16	6/27/85	[illegible]	[illegible]	[illegible]
17	6/27/85	[illegible]	[illegible]	[illegible]
18	6/27/85	[illegible]	[illegible]	[illegible]
19	6/27/85	[illegible]	[illegible]	[illegible]
20	6/27/85	[illegible]	[illegible]	[illegible]
21	6/27/85	[illegible]	[illegible]	[illegible]
22	6/27/85	[illegible]	[illegible]	[illegible]
23	6/27/85	[illegible]	[illegible]	[illegible]
24	6/27/85	[illegible]	[illegible]	[illegible]
25	6/27/85	[illegible]	[illegible]	[illegible]
26	6/27/85	[illegible]	[illegible]	[illegible]
27	6/27/85	[illegible]	[illegible]	[illegible]
28	6/27/85	[illegible]	[illegible]	[illegible]
29	6/27/85	[illegible]	[illegible]	[illegible]
30	6/27/85	[illegible]	[illegible]	[illegible]
31	6/27/85	[illegible]	[illegible]	[illegible]
32	6/27/85	[illegible]	[illegible]	[illegible]
33	6/27/85	[illegible]	[illegible]	[illegible]
34	6/27/85	[illegible]	[illegible]	[illegible]
35	6/27/85	[illegible]	[illegible]	[illegible]
36	6/27/85	[illegible]	[illegible]	[illegible]
37	6/27/85	[illegible]	[illegible]	[illegible]
38	6/27/85	[illegible]	[illegible]	[illegible]
39	6/27/85	[illegible]	[illegible]	[illegible]
40	6/27/85	[illegible]	[illegible]	[illegible]
41	6/27/85	[illegible]	[illegible]	[illegible]
42	6/27/85	[illegible]	[illegible]	[illegible]
43	6/27/85	[illegible]	[illegible]	[illegible]
44	6/27/85	[illegible]	[illegible]	[illegible]
45	6/27/85	[illegible]	[illegible]	[illegible]
46	6/27/85	[illegible]	[illegible]	[illegible]
47	6/27/85	[illegible]	[illegible]	[illegible]
48	6/27/85	[illegible]	[illegible]	[illegible]
49	6/27/85	[illegible]	[illegible]	[illegible]
50	6/27/85	[illegible]	[illegible]	[illegible]

1000

1. Hydro Reference No. 1184015  
 Hydro Sales Order No. 85-0198  
 Hydro Purchase Order No. \_\_\_\_\_  
 Vendor Shop No. \_\_\_\_\_  
 Mark/Tag all Dwgs. & Equipment: FILTER  
INLET, HYDRO DWG 850198002  
 Vendor Dwg. No's. \_\_\_\_\_

Date: 11-21-84  
 Date Revised: 5/8/85, Tim Frazier  
 Engineer: U.S. NAVAL FACILITIES ENGR Command  
 Project: Water Treatment System  
Camp Lejeune, North Carolina  
 Gate Location: \_\_\_\_\_

2. Gate Data Quantity: 3  
 A. Model: Heavy Duty Sluice  
 B. Size: 12" x 18"  
 C. Operating Head: 10 ft.  
 D. Push Load: 462 Lbs.  
 E. Pull Load: 662 Lbs.

3. Project Requirements  
 A. Cylinder   
 B. Power Unit   
 C. Accumulators   
 D. Electrical Controls   
 E. \_\_\_\_\_

4. Cylinder Data  
 A. Model: \_\_\_\_\_  
 B. Bore: 5"  
 C. Rod Diameter: 1"  
 D. Rod End Style: STD  
 \*E. Rod End Threads: 7/8-9UNC-2A, 6" LONG  
 \*F. Stroke: 20"  
 \*G. Rod Extension Length (Piston Retracted): 9"  
 H. Single or double acting. (circle one)  
 I. Cushioning - none, both ends, rod end, cap end (circle one)  
 J. Operating Media: WATER  
 K. Operating Pressure: 50 P.S.I.  
 L. Rate of Travel: 12"-24" (Unless Specified)  
 M. Port Sizes: 1/2"  
 N. Cylinder Rated Pressure: 150 PSI  
 \*O. Underwater Usage - yes, no (circle one)  
 P. Double Rod End yes, no (circle one)  
 \*Q. Type of Mounting: Front Flange  
 lug & side, trunion, clevis tie rod (circle one)  
 R. Limit Switch - Both Ends, One End (circle one)  
 S. Limit Switch Type (if required): \_\_\_\_\_

5. Materials  
 A. Piston: CAST IRON CADMIUM PLATED  
 B. Barrel: BRONZE  
 C. Rod: TYPE 304 STAINLESS  
 D. Caps: CAST IRON CADMIUM PLATED  
 E. Tie Rods/Nuts: \_\_\_\_\_  
 F. Wiper Seals: \_\_\_\_\_  
 G. Piston Rod Seals: BUNA-N  
 H. Rod Bearings: BRONZE ASTM B-144 ALLOY 3B  
 I. Piston Seals: BUNA-N  
 J. Size, Quantity & Material of Mounting Bolts: BY HYDRO  
 K. Cleaning & Paint: EPOXY PAINT

6. Power Unit And Accessories (Describe Major Components By Size and Quantity)

Tail Rod = 60" Long  
Out wiper

GATE POSITION IS INDICATED BY ROD POSITION

7. Vendor Notes

"it is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

Approved for use.

Submitted for Government approval.



Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_

Signature CQC Rep. *Phil Fene* DATE 6-24-82

KEY	QTY.	DESCRIPTION	MATERIAL	KEY	QTY.	DESCRIPTION	MATERIAL
1	4	TIE ROD	STRESSPROOF	12	1	CYLINDER HEAD	STEEL CAD. PL.
2	4	TIE ROD NUT	GRADE 8	13	1	ROD BUSH. SEAL	BUNA-N
3	1	BUSH. RETAINER	STEEL	14	2	ROD PACKING	BUNA-N
4	1	TALE ROD	STEEL CHR. PL.	15	1	FLANGE PLATE	STEEL
5	1	CYLINDER CAP	STEEL CAD. PL.	16	1	ROD WIPER	BUNA-N
6	2	TUBE END SEAL	BUNA-N	17	1	ROD BUSHING	BRONZE
7	2	PISTON PACKING	BUNA-N	18	1	ROD WIPER	BUNA-N
8	1	PISTON	DUCTILE IRON CAD. PL.	19	1	ROD BUSHING	BRONZE
9	1	PISTON ROD SEAL	BUNA-N	20	1	ROD BUSH. SEAL	BUNA-N
10	1	CYLINDER TUBE	BRASS	21	2	ROD PACKING	BUNA-N
11	1	PISTON ROD	304 SST. CHR. PL.	22	1	PISTON O-RING	BUNA-N


QUAN \_\_\_\_\_ 3  
 BORE: \_\_\_\_\_ 5  
 STROKE: \_\_\_\_\_ 20  
 MODEL \_\_\_\_\_ LH-20  
 PORT LOC.: \_\_\_\_\_ POS. #1 BOTH ENDS  
 CUST. P.O.#: \_\_\_\_\_ D-4088  
 CUST: \_\_\_\_\_ HYDRO GATE CORP.  
 WORK ORDER 5278C  
 OPERATING PRESSURE: 50 PSI  
 $\frac{9}{16}$  DIA. HOLE  
 4 REQ'D.




NOTE:  
 PAINT: COAL TAR EPOXY


REVISIONS	MACHINING TOLERANCES
2 1	UNLESS OTHERWISE SPECIFIED FRACTIONAL DIMENSIONS $\pm 1/64$ DECIMAL DIMENSIONS $\pm .005$ ALL ANGLES $\pm 1^\circ$ DIAMETERS ON COMMON CENTERLINE ARE TO BE CONCENTRIC WITHIN .003 T.I. MAX. SURFACE ROUGHNESS 125 $\mu$ = 5 REMOVE ALL BURRS AND BREAK ALL SHARP CORNERS

<b>CHICAGO FLUID POWER</b>		SCALE: NONE	APPROVED BY: R. Darden	DRAWN BY TS
		DATE: 5-22-85		REVISED
		TITLE: CERTIFICATION DRWG. LIGHT DUTY HYDRAULIC CYLINDER		
		DRAWING NUMBER C-2039-B		







FRONT VIEW




DETAIL A  
SIDE WEDGING DEVICE



ANCHOR BOLT LAYOUT FOR LIFT



DETAIL B  
TOP WEDGING DEVICE




DETAIL C  
BOTTOM WEDGING DEVICE

NOTES

- CASTING TOLERANCES APPLY ON ALL UNMACHINED SURFACES.
- SEE MANUAL G-1000 FOR INSTALLATION AND ADJUSTMENT INSTRUCTIONS.
- ALL DIMENSIONS IN INCHES UNLESS NOTED OTHERWISE.
- MATERIAL SPECIFICATIONS AND COATINGS PER DRAWING 850198500.
- TOP AND BOTTOM WEDGES  YES  NO
- GATE DESIGN HEAD  35'  50' FEET SEATING  
 20' FEET UNSEATING
- MECHANICAL JOINT HAS TAPPED HOLES. BOLTS, NUTS, GLAND & GASKET NOT BY HYDRO.
- TAG-FINISH WATER INLET TO RESERVOIR.

*A/E Please verify if seating and unseating heads specified are applicable for this gate*  
*Yes JWB*




SECTION A-A

STUD BOLT LAYOUT ON FACE OF THIMBLE

NOTICE  
THIS IS A PROPRIETARY DESIGN OF HYDRO GATE CORP. THE DESIGN, DATA AND INFORMATION RELATING THERETO IS NOT TO BE USED DISSEMINATED, OR REPRODUCED IN WHOLE OR IN PART WITHOUT THE WRITTEN CONSENT OF HYDRO GATE CORP.

Hydro Gate Corporation  
6101 DEXTER STREET  
COMMERCE CITY, COLORADO 80022

SLUICE GATE SERIES 501				
SIZE 24x24				
UNIVERSAL FRAME-FLANGE			NOT SELF CONTAINED	
STANDARD BOTTOM			RISING STEM	
ONE REQUIRED				
REVISED	DRAWN BY	APPROVED BY	DIST. ORDER	PLANT ORDER
	M/S			85-0198
	CHECKED BY	SCALE	DATE	DWG. NO.
		JL	5-2-85	850198001



MATERIAL SPECIFICATIONS

Gate Part or Item of Assembly

Material Description Material Code

Materials Shown in ASTM Specification unless Noted Otherwise

EMBEDMENTS

Wall Thimble	Cast Iron	(A)	A126, Class B
Wall Thimble Studs	Stainless Steel	(L)	A276, Type 304
Wall Thimble Nuts	Stainless Steel	(L)	F593, Alloy Group 1
Anchor Bolts	Stainless Steel	(L)	A276, Type 304
Anchor Bolt Nuts	Stainless Steel	(L)	F593, Alloy Group 1

GATE ASSEMBLY

Frame & Slide	Cast Iron	(A)	A126, Class B
Seating Faces	Naval Bronze	(F)	B21, Alloy 482
Side Wedge Blocks	Manganese Bronze	(K)	B584, Alloy 863
Side Wedges	Manganese Bronze	(K)	B584, Alloy 863
Top & Bottom Wedges	Manganese Bronze	(K)	B584, Alloy 863
Fasteners	Stainless Steel	(L)	F593 (Bolts) F594 (Nuts) Alloy Group 1
<del>Stop Plate &amp; Retainer</del>	<del>Stainless Steel</del>	<del>(L)</del>	<del>A276, Type 304</del>
<del>Flush Bottom Seal</del>	<del>Rubber</del>	<del>(B)</del>	<del>D2000, Grade 1AA625</del>

STEM AND ACCESSORIES

Stem	Stainless Steel	(L)	A276, Type 304
<del>Stem Splice</del>	<del>Stainless Steel</del>	<del>(L)</del>	<del>A502, Type 303</del>
Stem Block	Manganese Bronze	(K)	B584, Alloy 865
Key	Stainless Steel	(L)	A276, Type 304

LIFT ASSEMBLY

Lift Pedestal & Housing	Cast Iron	(A)	A126, Class B
Lift Nut	Manganese Bronze	(K)	B584, Alloy 865
Stop Nut	Naval Bronze	(F)	B21, Alloy 485

STEM GUIDE ASSEMBLY

Stem Guide	Cast Iron	(A)	A126, Class B
Stem Guide Bushing	Tin Bronze	(E)	B584, Alloy 932
Fasteners	Stainless Steel	(L)	F593 (Bolts), Alloy Group 1 F594 (Nuts), Alloy Group 1
Base Plate Stem Guide	Carbon Steel	(V)	A36

COATING SPECIFICATIONS

CLEANING:

- Standard Clean - Removal of Loose Rust, Mill Scale and Paint by Air Hose, Scraping, and Wire Brush.
- Blast Clean (Per Steel Structures Painting Council)  
**COMMERCIAL** Grade **SSPC-SP10**

COATING:

**KOPPER'S 654 EPOXY PRIMER** Color **MAROON**  
2 Shop Coats for a Dry Film Thickness of **4.0** Mils for the following components:

- Gate
- Thimble
- Stem Block
- Stem
- Stem Guides
- Wall Bracket
- Lift
- Base Plate Stem Guide

COATING:

Shop Coats for a Dry Film Thickness of \_\_\_\_\_ Mils for the following components:

- Lift
- Base Plate Stem Guide

NOTES:

1. Surfaces embedded in concrete are not painted.
2. Seating surfaces machined to 63 micro-inch finish.
3. Wall thimbles stamped with the word "top" for alignment.
4. .004 clearance check provided on seating surfaces between frame and slide.

NOTICE


This is a proprietary design of Hydro Gate Corp. The design, data and information relating thereto is not to be used disseminated, or reproduced in whole or in part without the written consent of Hydro Gate Corp.




MATERIAL AND COATING SPECIFICATIONS  
HEAVY DUTY SLICE GATE  
MATERIAL COMBINATION NO. 1


REVISED	DRAWN BY	APPROVED BY	DIST. ORDER	PLANT ORDER
	MS			85-0198
	DATE	SCALE	DWG. NO.	
	5-2-85	CH	850198500	

H4-7.00






CURTIS FLUID POWER  
HYDRAULIC CYLINDER  
MODEL LH-20  
5 BORE 20 STROKE  
DIMENSION DRAWINGS TO BE  
FURNISHED BY MANUFACTURER




IMPORTANT: SEE DETAIL FOR CLEARANCE

FRONT VIEW




SECTION A-A


STUD BOLT LAYOUT  
ON FACE OF THIMBLE




DETAIL B  
TOP WEDGING DEVICE




DETAIL C  
SIDE WEDGING DEVICE




DETAIL D  
STANDARD BOTTOM  
BOTTOM WEDGING DEVICE



ANCHOR BOLT DETAIL



INSTALLATION CLEARANCE



DETAIL E  
FLUSH BOTTOM

NOTES:

1. CASTING TOLERANCES APPLY ON ALL UNMACHINED SURFACES.
2. SEE MANUAL G-1000 FOR INSTALLATION AND ADJUSTMENT INSTRUCTIONS.
3. ALL DIMENSIONS IN INCHES UNLESS NOTED OTHERWISE.
4. TOP WEDGES YES  NO
5. BOTTOM WEDGES YES  NO
6. MAX. OPERATING HEAD 10'  20'
7. MATERIAL & COATING SPECIFICATIONS PER DRAWING 850198500

PLEASE CONFIRM THIS ELEVATION TO HYDRO.

TAG: FILTER INLET GULLET, DWG 33 & 34


3 REQUIRED

NOTICE

THIS IS A PROPRIETARY DESIGN OF HYDRO GATE CORP. THE DESIGN, DATA AND INFORMATION RELATING THERETO IS NOT TO BE USED DISSEMINATED, OR REPRODUCED IN WHOLE OR IN PART WITHOUT THE WRITTEN CONSENT OF HYDRO GATE CORP.

Hydro Gate Corporation  
5101 DEXTER STREET  
COMMERCE CITY, COLORADO 80222

HEAVY DUTY SLUICE GATE				
DESIGNED FOR 100' SEATING (30') UNSEATING HEAD				
SIZE 12 X 18 SEATING SPACES BRONZE				
FLANGE BACK SELF-CONTAINED FRAME				
STANDARD BOTTOM NON-RISING STEM				
REVISED	DRAWN BY	APPROVED BY	DIST. ORDER	PLANT ORDER
	M3			85-0198
	ENCL. BY			DWG. NO.
				5-3-85 850198002



**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

*Hunt*

CONTRACT NO 81-C-1644		TRANSMITTAL NO 21-A	DATE 6-24-85
FROM CONTRACTOR Harry Pepper & Associates, Inc.		PROJECT TITLE AND LOCATION Holcomb Blvd Water Treatment Plant	
TO Henry Von Oesen & Associates, Inc.		MCB, Cp Lejeune, North Carolina	

<b>CONTRACTOR USE ONLY</b> <i>*List only one specification division per form.</i>  <i>List only one of the following categories on each transmittal form, and indicate which is being submitted</i>	<b>REVIEWER USE ONLY</b> <b>**ACTION CODES</b> A-Approved D-Disapproved AN-Approved as noted RA-Receipt acknowledged. C-Comments R-Resubmit
<input type="checkbox"/> Contractor Approved	<input type="checkbox"/> OICC Approval
<input checked="" type="checkbox"/> Deviation/Substitution For OICC Approval	

ITEM NO	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1	6.2.6	Hydraulically Operated Filter Valves	7	A	CCS 405 7/9/85
	15271	PLANT PIPING			
1	5.4.1.b3	Hydraulically Operated Valves	7	A	↓
2		AWWA Approval for Non-Metal Cylinders	7	D	

**CONTRACTOR'S COMMENTS**  
 The attached (Item # 2) of AWWA C504-85 allows the use of Non-Metallic operators. The Contractor, in the past has had corrosion problems with metallic operators due to the presents of various other metals in the operators and would prefer the use of these operators as submitted. If this proposed deviation is approved there will be no additional cost to the Government and any changes caused by this deviation will be the responsibility of the Contractor at no expense to the Government.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC ONE COPY TO ROICC	CONTRACTOR REPRESENTATIVE (Signature) <i>Phil Reese</i>
DATE RECEIVED BY REVIEWER 7/12/85	FROM (Reviewer) LANTDIV TO ROICC / HARRY PEPPER

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

**REVIEWER'S COMMENTS**  
*NON-METALLIC OPERATORS ARE NOT APPROVED BY AWWA; PROVIDE BRONZE BODY OPERATORS AS SPECIFIED.*

COPIES TO ROICC (2) LANTDIV (1) A-E (1)	DATE 7/12/85	SIGNATURE <i>Phil Reese</i>
--	-----------------	--------------------------------

19 JUL 1985 13 01

Item # 1

CUSTOMERS NAME: HARRY PEPPER & ASSOCIATES

CUSTOMERS P.O. NO. 642-0009

JOB NAME: EXPANSION OF THE HOLCOMB BLVD. WATER TREATMENT PLANT - MARINE CORPS BASE - CAMP LEJEUNE, NORTH CAROLINA  
CONTRACT NO. NG 2470-81-C-1644

QUOTE NO. 85-1153

ORDER NO. \_\_\_\_\_

*Provide Certification*

**M&H VALVE COMPANY**  
 AMTIC A Division of McWane, Inc.  
 NAVAL FACILITIES ENGINEERING DIVISION BOX 2088 AND  
 NORFOLK ANNISTON, ALABAMA 36202

APPROVED  \_\_\_\_\_  
 APPROVED AS NOTED \_\_\_\_\_  
 DISAPPROVED \_\_\_\_\_  
 SUBJECT TO THE REQUIREMENTS OF \_\_\_\_\_  
 CONTRACT NO. **05-81-1644**  
 APPROVAL OF SUBMITTAL DOES NOT INCLUDE  
 APPROVAL OF ANY DEVIATION FROM THE CON-  
 TRACT REQUIREMENTS UNLESS THE CONTRAC-  
 TOR CALLS ATTENTION TO AND SUPPORTS THE  
 DEVIATION--THE CONTRACTOR SHALL BE  
 RESPONSIBLE FOR PROVIDING PROPER  
 PHYSICAL DIMENSIONS & WEIGHTS, COORDINA-  
 TION OF TRADES ETC. AS REQUIRED

REVIEWER CCS DATE 9 JUL 1985

**FOR OFFICER IN CHARGE OF CONSTRUCTION**

"It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number **470-81-C-1644** is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

Approved for use.  
 Submitted for Government approval.  
 Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_  
 Signature CQC Rep. Phil Pease DATE 6-24-85

and specifications and can be installed in the proposed space  
125-100-104 in compliance with the Contract Drawings  
and proposed to be incorporated into Contract Items  
with this contract, such drawings, notes, etc.  
The contract shall be the (two) (2) sets.

Approved for use \_\_\_\_\_  
Submitted for Government approval \_\_\_\_\_  
Approved for use subject to Government approval for  
specific deviation \_\_\_\_\_  
Proposed Review DATE \_\_\_\_\_  
Signature COE Rev. DATE \_\_\_\_\_

(1) 18" REQ'D. - BACKWASH VALVE FLANGED MARK C01.  
 (3) 18" REQ'D. - WASH VALVES FLANGED MARK C02, C03, C04.  
 (3) 10" REQ'D. - EFFLUENT VALVES FLANGED MARK C05, C06, C07.  
 (3) 6" REQ'D. - REWASH VALVES FLANGED MARK C08, C09, C10.


COATING IN ACCORDANCE WITH APPLICABLE AWWA STANDARD AND FED. SPEC. IT-C-494A OR EQUAL.

VALVE SIZE	A	B	C	J	P	Q	R	S	AA	AB
4	4	7 1/2	7 1/2	5	8	1 1/2	9	1 1/2	4	1-11
6	5	8 3/4	9 1/2	5	8	1 1/2	11	1	4	1-10
8	6	9 3/4	11 1/2	6	8	1 1/2	13 1/2	1 1/2	4	1-10
10	7 1/2	12 1/4	14 1/4	8	12	1 1/2	16	1 3/8	—	—
12	9 1/2	14	17	8	12	1 1/2	19	1 1/2	—	—
14	10 7/8	15 3/8	18 3/4	8	12	1	21	1 1/2	4	1-8
16	12 3/8	17 1/8	21 1/4	8	16	1	23 1/2	1 7/8	4	1-8
18	13 1/8	19 3/8	22 1/2	8	16	1 1/2	25	1 3/8	4	1-7
20	14 1/4	21 1/4	25	8	20	1 1/2	27 1/2	1 1/2	4	1-7
24	17 1/2	24	29 1/2	8	20	1 1/2	32	1 7/8	4	1-7

OPERATOR MODEL CYLINDER & HANDWHEEL	CYLINDER		D	E	F	G	H	K	L	M	N	T	V	W	Y
	BORE	STROKE													
65	5	2 3/4	2 15/16	3 9/16	7 1/4	5 1/2	12 1/4	3 1/4	2 1/4	1 3/8	16 1/2	7 1/2	7 3/4	3 7/16	1 3/8-18
150	5	2 3/4	2 15/16	3 9/16	7 1/4	5 1/2	12 1/4	3 1/4	2 1/4	1 3/8	16 1/2	7 1/2	7 3/4	3 7/16	1 3/8-18
175	6	2 3/4	2 15/16	3 9/16	7 1/4	6 1/2	13	3 1/4	2 1/4	1 3/8	16 1/2	12	7 1/2	3 7/16	1-14
510	6	6	3 3/8	4 1/2	12 5/8	6 1/2	18 3/8	6 1/2	2 3/4	3	36	12	10 3/8	5 7/8	1-14
1250	8	8	4 1/8	5 3/4	17	10	24	7 7/8	3 1/4	4	48	18	12 1/2	8 3/8	1-14
2200	8	12	4 1/8	6 1/4	23	10	30	10 3/4	3 7/8	6	72	18	14 1/2	10 3/8	1-14

NOTE: DE-CLUTCH OPERATION  
 1. TURN HANDWHEEL TO LINE UP HOLE IN OPERATOR SHAFT WITH HOLE IN SLEEVE ON VALVE SHAFT.  
 2. INSERT PIN.  
 3. OPEN BY-PASS VALVE ON CYLINDER.  
 4. OPERATE VALVE BY HANDWHEEL.

VALVE IDENTIFICATION PLATE ATTACHED TO HOUSING COVER (STAMPED WITH VALVE PART NUMBER AT FINAL ASSEMBLY.)




NOTE: FLOW MAY BE IN EITHER DIRECTION.

**M & H VALVE COMPANY**  
 A Division of McWane, Inc.  
 P.O. BOX 2088  
 ANNISTON, ALABAMA 36202




NOTE: VALVE SHAFT WILL MEET OR EXCEED REQUIREMENTS OF SHAFT TABLE PER AWWA STANDARD C-504 FOR APPLICABLE CLASS.




WITH 125° ANSI FLANGES & DRILLING PER AWWA C-504

REVISIONS		DATE		BY		APP		*This drawing, including all amendments and alterations, shall not be used unless authorized in writing by the originator. It is the responsibility of the user to verify that the drawing is the latest issue and that it is intended for the project and that it shall be returned to the originator when it is no longer needed.		<b>ASSEMBLY-STYLE 450 SERIES FLANGED BFV W/CYLINDER OPERATOR &amp; HANDWHEEL DE-CLUTCH</b>		DWG. NO. 99-02079 REV. A	
-----------	--	------	--	----	--	-----	--	---	--	--	--	-----------------------------	--



ITEM NO.	DESCRIPTION	MATERIAL
1	BODY, VALVE	CAST IRON, A-126, B-W/18-8 STN. STL. SEAT
2	VANE	CAST IRON, A-48, CL. 40
3	COVER, END	CAST IRON, A-126, CL. B
4	SEAT RING, VANE	BUNA 'S' W/304 STN. STL. INSERT
5	JOURNAL, VALVE SHAFT	304 STN STL
6	SEAL, SHAFT	BUNA 'S'
7	PACKING, JOURNAL	BUNA 'S'
8	BUSHING, BODY	REINFORCED TEFLON
9	HEX DRIVE SHAFT	CDS-C-1018 STL.
10	CAPSCREW, HEX	18-8 STN STL-W/ 'NYLON' INSERT
11	NUT, HEX	STL., ASTM A-307, GR. B, ELECTRO-ZINC PLATED
12	STUD	STL., ASTM A-307, GR. B, ELECTRO-ZINC PLATED
13	SPACER	CDS-C-1018 STL.
14	CONNECTOR-SLEEVE	CDS-C-1018 STL.
15	PIN-TAPER	BRASS
16	SHAFT, OPERATOR-DE-CLUTCH	CDS-C-1018 STL.
17	PACKING	RUBBER
18	CHAIN-BEAD	STAINLESS STEEL




REVISIONS				DATE		BY		APP	


<small>"This drawing, including all notes and attached or associated sheets, is the property of M&amp;H Valve Company and is loaned to the purchaser for their use only. It is not to be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of M&amp;H Valve Company. If you have any questions, please contact M&amp;H Valve Company at 205-833-2200."         </small>											
<b>SUB-ASSEMBLY-STYLE 450 SERIES FLANGED END BFV W/DE-CLUTCH &amp; BUNA 'S' SEALS</b>				DRAWN BY JLW		CHECKED BY L.S.		FILE NO. 8-29-78		DWG. NO. 99-01395	



**M & H VALVE COMPANY**  
 A Division of McWane, Inc.  
 P.O. BOX 2088  
 ANNISTON, ALABAMA 36202




ITEM NO.	DESCRIPTION	MATERIAL
1	HOUSING, OPERATOR	CAST IRON, A-126, CL. B
2	COVER, HOUSING	CAST IRON, A-126, CL. B
3	HEAD, CYLINDER, ROD END	CAST IRON, A-126, CL. B
4	HEAD, CYLINDER, BLANK END	CAST IRON, A-126, CL. B
5	NUT, CONNECTING	CAST IRON, A-126, CL. B
6	INDICATOR	CAST IRON, A-126, CL. B
7	PISTON HALF	CAST IRON, A-126, CL. B
8	LEVER	DUCTILE IRON, A-536 GR. 65-45-12
9	CROSSHEAD	DUCTILE IRON, A-536 GR. 80-55-06
10	SLEEVE, CROSSHEAD	ALLOY IRON
11	PISTON ROD	18-8 STAINLESS STEEL
12	TAIL ROD	STEEL, C-1040
13	BUSHING, TAIL ROD	BEARING BRONZE, B-144, ALLOY 3B
14	CARTRIDGE, SEAL	BEARING BRONZE, B-144, ALLOY 3B
15	PISTON CUP	BUNA 'N'
16	BARREL, CYLINDER	GLASS FIBER REINFORCED EPOXY TUBING WITH MOLYBDENUM DISULFIDE LINER
17	GUARD, TAIL ROD	COMM. STEEL PIPE
18	INDICATOR PIN	C/D STEEL
19	TIE ROD	STEEL, COMM.
20	NUT, HEX (TIE ROD)	STEEL, COMM.
21	NUT, HEX (PISTON)	STEEL, COMM.-CADMIUM PLATED
22	NUT, HEX (INDICATOR)	STEEL, COMM.
23	CAPSCREW, HEX	STEEL, COMM.
24	PLUG, EXPANSION	BRASS, COMM.
25	RING, RETAINING	SPRING STEEL
26	GASKET, COVER	CORK-NEOPRENE
27	SEAL, ROD	URETHANE, SELF LUBRICATED
28	SEAL (CARTRIDGE)	BUNA 'N'
29	SEAL (PISTON HALF)	BUNA 'N'
30	SEAL (INDICATOR PIN)	BUNA 'N'
31	PLUG, PIPE-SQ. HD.	CAST IRON, COMM.
32	BUSHING	NYLON (MOLY-DISULFIDE FILLED)




REVISIONS				DATE	BY	APP	SUB-ASSEMBLY-CYLINDER OPERATOR				
<small>*This drawing, including all detail and associated or pertinent related material, including specifications, drawings, and data is issued with the understanding that it will not be reproduced or used for any purpose except that for which it was originally prepared unless otherwise indicated in writing by the originator.</small>							<small>DRAWN BY</small> JAM	<small>CHECKED BY</small> ALR	<small>NO. SHEETS</small> 1	<small>DWG. NO.</small> 99-01362	<small>REV.</small> 
							<small>DATE</small> 7-17-78	<small>SCALE</small> 	<small>FILE NO.</small> 8002-1		


**M & H VALVE COMPANY**  
 A Division of McWane, Inc.  
 P.O. BOX 2088  
 ANNISTON, ALABAMA 36202




ITEM NO.	DESCRIPTION	MATERIAL
1	HOUSING, OPERATOR	CAST IRON, A-126 CL. B
2	COVER, HOUSING	CAST IRON, A-126 CL. B
3	CAP, THRUST	CAST IRON, A-126 CL. B
4	AS REQUIRED	CAST IRON, A-126 CL. B
5	LEVER	DUCTILE IRON, A-536 GR 65-45-12
6	CROSSHEAD	DUCTILE IRON, A-536 GR 80-55-06
7	SHAFT, INPUT	C.D. STEEL, 12 L 14
8	SEAL (HOUSING)	BUNA "N"
9	SEAL (CAP)	BUNA "N"
10	GASKET, COVER	CORK-NEOPRENE
11	SHIELD, SHAFT	REINFORCED TEFLON
12	PLUG, EXPANSION	BRASS, COMM.
13	BOLT, HEX. HD (AWWA NUT)	STEEL, COMM.
14	BOLT, HEX. HD (COVER)	STEEL, COMM.
15	SLEEVE, CROSSHEAD	ALLOY IRON
16	RING, RETAINING	SPRING STEEL
17	INDICATOR	CAST IRON, A-126 CL. B
18	PIN, INDICATOR	STEEL, COMM.
19	SEAL, INDICATOR PIN	BUNA "N"
20	NUT, HEX	STEEL, COMM.
21	BEARING, NEEDLE	STEEL, COMM.
22	RACE, THRUST	HARDENED STEEL
23	SPACER	HARDENED STEEL
24	WASHER, THRUST	HARDENED STEEL
25	PIN, INPUT SHAFT	STEEL, COMM.
26	BUSHING	REINFORCED TEFLON



BURIED OPERATOR

INTEGRAL STOP NUT  
MODELS 65 THRU 510 ONLY.


HANDWHEEL AND CRANK  
OPERATOR



AWWA NUT  
OPERATOR

HANDWHEEL AND  
CRANK OPERATOR

THRUST COLLAR AREA  
MODELS 1250 & 2200 ONLY



SECTION A-A  
FOR HANDWHEEL AND  
CRANK OPERATOR ONLY

REVISIONS				DATE				BY				APP							
<small>*This drawing, including all parts and processes is a valuable property of M&amp;H Valve Company. It is to be used only for the purpose stated and is not to be reproduced or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of M&amp;H Valve Company. If you are not an authorized user, you should not use this drawing. If you are an authorized user, you should not use this drawing for any purpose other than that for which it was originally intended. If you are an authorized user, you should not use this drawing for any purpose other than that for which it was originally intended. If you are an authorized user, you should not use this drawing for any purpose other than that for which it was originally intended.</small>																			
SUB-ASSEMBLY MANUAL OPERATOR												DESIGNED BY: LS CHECKED BY: ALB DATE: 5-2-78 DRAWN BY: I DATE: 2025-1				DWG. NO.: 99-01351 REV.:			




M & H VALVE COMPANY

A Division of McWane, Inc.

P.O. BOX 2088

ANNISTON, ALABAMA 36202



C504-85

Approved in

3/85

Item #2

3.8.4.20 Piston-Rod Bushing - bronze or nonmetallic materials suitable for air service.

3.8.4.21 Rod Seals - nonmetallic materials suitable for air service.

3.8.4.22 Piston Seals - nonmetallic materials suitable for air service.

Piston seals shall be of a pressure sensitive type.

3.8.4.23 Nonmetallic Materials for Water and Air Operated Cylinders.

This standard recognizes nonmetallic materials for use in cylinder assemblies. Considering the various properties of nonmetallics such as creep, water absorption, impact resistance, etc., it is not practical to specify general material usage since specific manufacturers' designs limit the use of the many available nonmetallic materials or certain combinations of those materials. The manufacturer of nonmetallic cylinders must have manufactured the assembly for a minimum of five years of satisfactory service and shall provide documentation when requested by the purchaser.

3.8.4.24 For material specifications refer to Section 2 Materials.

#### SECTION 4-WORKMANSHIP AND PAINTING

##### SEC. 4.1 WORKMANSHIP

Valve parts shall be designed, and manufacturing tolerances set, to provide interchangeability of parts between units of the same size and type produced by any one manufacturer. When assembled, valves manufactured in accordance with this standard shall be well fitted and smooth operating, and body and shaft seal shall be watertight.

##### SEC. 4.2 PAINTING

All interior and exterior surfaces except finished or bearing surfaces shall be carefully prepared by removing all dirt, grease, and rust and shall

ATLANTIC DIVISION  
NAVAL FACILITIES ENGINEERING COMMAND  
NORFOLK VIRGINIA 23511

APPROVED \_\_\_\_\_  
APPROVED AS NOTED \_\_\_\_\_  
DISAPPROVED \_\_\_\_\_  
SUBJECT TO THE REQUIREMENTS OF \_\_\_\_\_

CONTRACT NO. **05-81-1644**  
APPROVAL PERMITAL DOES NOT INCLUDE  
APPROVAL OF ANY DEVIATION FROM THE CON-  
TRACT REQUIREMENTS UNLESS THE CONTRAC-  
TOR CALLS ATTENTION TO AND SUPPORTS THE  
DEVIATION THE CONTRACTOR SHALL BE  
RESPONSIBLE FOR PROVIDING PROPER  
PHYSICAL DIMENSIONS & WEIGHTS, COORDINA-  
TION OF TRADES ETC. AS REQUIRED

REVIEWER CCS DATE **9 JUL 1985**

FOR OFFICER IN CHARGE OF CONSTRUCTION

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
 LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

*Hart*

CONTRACT NO <b>81-C-1644</b>	TRANSMITTAL NO <b>84</b>	DATE <b>7-30-85</b>
PROJECT TITLE AND LOCATION <b>Holcomb Blvd Water Treatment Plant</b>		
<b>MCB, Cp Lejeune, North Carolina</b>		

FROM CONTRACTOR  
**Harry Pepper & Associates, Inc.**

TO  
**Henry Von Oesen & Associates, Inc.**

CONTRACTOR USE ONLY	REVIEWER USE ONLY
<p>*List only one specification division per form.</p> <p>List only one of the following categories on each transmittal form, and indicate which is being submitted</p> <p><input checked="" type="checkbox"/> Contractor Approved      <input type="checkbox"/> OICC Approval      <input type="checkbox"/> Deviation/Substitution For OICC Approval</p>	<p>**ACTION CODES</p> <p>A-Approved  D-Disapproved  AN-Approved as noted  RA-Receipt acknowledged.  C-Comments  R-Resubmit</p>

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	<b>11336</b>	<b>WATER TREATMENT EQUIPMENT</b>			
<b>1</b>	<b>6.2.6 b</b>	<b>Manufacturer's Data and Drawing on Diaphragm Valve for Surface Wash</b>	<b>4</b>	<b>RA</b>	<b>[Signature] 7/31/85</b>

CONTRACTOR'S COMMENTS

Certification Conforming to Section 15271 is forthcoming.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC: **ONE COPY TO ROICC**

CONTRACTOR REPRESENTATIVE (Signature): *Phil Reese*

DATE RECEIVED BY REVIEWER: **7/28/85**

FROM (Reviewer): **Henry von Oesen & Assoc., Inc.**

TO: \_\_\_\_\_

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

Contractor's approval appears to be appropriate.

COPIES TO ROICC (2), LANTDIV (1), A-E (1)

DATE: **7/31/85**

SIGNATURE: *[Signature]*

-1 AUG 1985 11 12

CONFIDENTIAL - SECURITY INFORMATION

TO: [Illegible] FROM: [Illegible] SUBJECT: [Illegible]

[Handwritten signature]

CONFIDENTIAL - SECURITY INFORMATION

[Illegible typed text, possibly a memorandum or report body]

[Handwritten notes]

[Handwritten initials]

# Specifications

*I-Term#1*

<b>SIZES</b>	Globe: 3/8" - 3" screwed; 1 1/2" - 16" flanged Angle: 1 1/2" - 3" screwed; 2" - 16" flanged
<b>END DETAILS</b>	Flanged: Cast Iron, 125 & 250 ANSI B16.1 Cast Steel, 150 & 300 ANSI B16.5 Cast Bronze, 150 & 300 ANSI B16.24  Screwed: 250 and 300 ANSI B2.1
<b>PRESSURE RATINGS</b>	125 class 175 psi/150 class 275 psi 250 class 300 psi/300 class 400 psi
<b>TEMPERATURES RANGES</b>	Water, Air, to +180°F. Light Petroleum Products -40 to +180°F.


## MATERIALS

Main valve body & cover:  
Cast Iron ASTM A48  
Cast Steel ASTM A216-WCB  
Cast Bronze ASTM B62  
Cast Aluminum 356-T6

Main valve trim:  
Brass QQ-B-626  
Bronze ASTM B61  
Stainless Steel 303


Rubber Parts:  
Buna N Synthetic Rubber

Available on special order



## OTHER MATERIALS

# Dimensions



# Purchase Specifications

This valve shall be a hydraulically operated, diaphragm-actuated, globe or angle pattern valve. It shall contain a resilient, synthetic rubber disc, having a rectangular cross-section, contained on three and one-half sides by a disc retainer and disc guide, forming a tight seal against a single removable seat insert. The diaphragm assembly containing a valve stem shall be fully guided at both ends by a bearing in the valve cover and an integral bearing in the valve seat. This diaphragm assembly shall be the only moving part and shall form a sealed chamber in the upper portion of the valve, separating operating pressure from line pressure. The diaphragm shall consist of nylon fabric bonded with synthetic rubber and shall not be used as a seating surface. Packing glands and/or stuffing boxes are not permitted and there shall be no pistons operating the valve. All necessary repairs shall be possible without removing the valve from the line.

Valve shall be similar in all respects to the Cla-Val Model 100-01 Hytrol Valve as manufactured by Cla-Val Co., Newport Beach, California, or approved equal.

## WHEN ORDERING PLEASE SPECIFY:

1. Size.
2. Model 100-01 Hytrol (Globe or Angle)
3. Pressure Class.
4. Temperature and fluid to be handled.
5. Static and flowing line pressure.
6. Operating fluid and pressure (if other than line pressure).
7. Body and trim materials.
8. End Details (screwed or flanged).

SIZE	3/8	1/2-3/4	1	1 1/4-1 1/2	2	2 1/2	3	4	6	8	10	12	14	16
<b>A</b> Screwed	2 3/4	3 1/2	5 1/8	7 1/4	9 3/8	11	12 1/2							
<b>AA</b> 125 ANSI				*8 1/2	9 3/8	11	12	15	20	25 3/8	29 3/4	34	39	41 3/8
<b>AAA</b> 150 ANSI														
<b>B</b> 250 ANSI	2 1/2	3 3/8	4 3/8	5 5/8	6 3/8	8	9 1/8	11 1/2	15 3/4	20	23 3/8	28	32 3/4	35 1/2
<b>C</b> 300 ANSI	1 1/2	2 3/8	2 1/2	4 1 3/16	5 3/4	6 7/8	7 1/2	9 1/8	12 1/2	13 7/8	16 3/8	20	23 1/4	25
<b>D</b>	1 1/4	7/8	1 5/8	2	2 1/2	2 7/8	3 1/8	4 1/4	6	7 1/8	9 1/4	10 3/4	12 5/8	15 1/2
<b>E</b> Screwed				3 1/4	4 3/4	5 1/2	6 1/4							
<b>EE</b> 125 ANSI					4 1/4	5 1/2	6	7 1/2	10	12 3/4	14 7/8	17	19 1/2	20 3 1/16
<b>EEE</b> 150 ANSI														
<b>F</b> Screwed				1 7/8	3 1/4	4	4 1/2							
<b>FF</b> 125 ANSI					3 1/4	4	4	5	6	8	8 3/8	13 3/4	14 7/8	15 1 1/16
<b>FFF</b> 150 ANSI														
<b>Cover Tapping N.P.T.</b>	1/8	1/8	1/4	1/4	3/8	1/2	1/2	3/4	3/4	1	1	1	1	1
<b>Body Tapping N.P.T.</b>		1/8	1/4	3/8	3/8	1/2	1/2	3/4	3/4	1	1	1	1	1
<b>Shipping Weight Lbs.</b>	3	3	8	15	35	50	70	140	285	500	780	1165	1600	2265

\*1 1/2 SIZE ONLY

*Provide Certification Per Section 15271*

VALVE SIZE	Cv FACTOR	FLOW OF WATER — GALLONS PER MINUTE — THRU GLOBE PATTERN VALVE																							
		5	10	15	20	30	40	50	60	80	100	150	200	300	400	600	800	1000	2000	3000	4000	6000	10,000		
1/2	6.0	.7	2.7	6.2	11.0																				
3/4	8.5	.3	1.4	3.1	5.5	12.5																			
1	13.3	.14	.57	1.3	2.3	5.1	9.1	14.1	20.4																
1 1/4	30.0		.1	.25	.44	1.0	1.8	2.8	4.0	7.1	11.0														
1 1/2	32.0		.1	.23	.4	.9	1.6	2.4	3.5	6.3	9.8	22.0													
2	54.0				.14	.31	.55	.86	1.23	2.19	3.43	7.72	13.72												
2 1/2	80.0					.14	.25	.4	.6	1.0	1.6	3.5	6.25	14.1											
3	115.0						.12	.19	.27	.48	.76	1.70	3.02	6.81	12.10										
4	200.0							.06	.09	.16	.25	.56	1.0	2.25	4.0	9.0	16.0								
6	500.0										.04	.09	.16	.36	.64	1.44	2.56	4.00	16.00						
8	840.0											.06	.13	.23	.51	.91	1.42	5.67	12.76						
10	1245.0												.10	.23	.41	.65	2.58	5.81	10.32						
12	1725.0													.19	.34	1.34	3.02	5.38	12.10						
14	2300.0														.76	1.70	3.02	6.81	18.90						
16	2940.0															.46	1.04	1.85	4.16	11.57					
GPM →		5	10	15	20	30	40	50	60	80	100	150	200	300	400	600	800	1000	2000	3000	4000	6000	10,000		

FLOW CHART — Pressure drop in pounds per square inch for sizes 1/2" thru 16" Clayton Valves

## LIQUID VOLUME DISPLACED FROM DIAPHRAGM CHAMBER WHEN VALVE OPENS


VALVE SIZE	DISPLACEMENT
3/8"	0.012 Fl. Oz.
1/2"	0.34 Fl. Oz.
3/4"	0.34 Fl. Oz.
1"	0.7 Fl. Oz.
1 1/4"	.020 Gals.
1 1/2"	.020 Gals.
2"	.032 Gals.
2 1/2"	.043 Gals.
3"	.080 Gals.
4"	.169 Gals.
6"	.531 Gals.
8"	1.26 Gals.
10"	2.51 Gals.
12"	4.0 Gals.
14"	6.50 Gals.
16"	9.57 Gals.




The Cla-Val Model 100-01 Hytrol valve is a hydraulically operated, diaphragm actuated, globe, or angle pattern valve. It consists of three major components: the body, diaphragm assembly, and cover. The diaphragm assembly is the only moving part.

The body contains a removable seat insert. The diaphragm assembly (sizes 1 1/4" and larger) is guided top and bottom by a precision machined stem. It utilizes a diaphragm of nylon fabric bonded with synthetic rubber. A resilient, synthetic rubber disc, contained on three and one-half sides by a disc retainer and disc guide, forms a drip-tight seal with the valve seat when pressure is applied above the diaphragm. The diaphragm assembly forms a sealed chamber in the upper portion of the valve, separating operating pressure from line pressure. The valve's packless construction and simplicity of design assures a long life of dependable operation.


The Model 100-01 Hytrol valve is used as the basic valve in almost all Cla-Val automatic valves. It is used in many types of piping systems requiring remote control, pressure regulation, solenoid operation, rate of flow control, liquid level control, or check valve operation. It is available in various materials and in a full range of sizes, with either screwed or flanged ends.




Principle of Operation



TIGHT CLOSING OPERATION



FULL OPEN OPERATION




MODULATING ACTION

When pressure from the valve inlet (or an equivalent independent operating pressure) is applied to the diaphragm chamber the valve is drip-tight.


When pressure in diaphragm chamber is relieved to a zone of lower pressure (usually atmosphere) the line pressure at the valve seat opens the valve. Flow in either direction is permitted.

Valve modulates when diaphragm pressure is held at an intermediate point between inlet and discharge pressure. With the use of a Cla-Val Co., "Modulating" Control, which reacts to line pressure changes, the pressure above the diaphragm is varied, allowing the valve to throttle and compensate for the changes.


Value Models



2" GLOBE, SCREWED



4" GLOBE, FLANGED



4" ANGLE, FLANGED

I hereby certify that the material (equipment) shown and described in this submittal, shop drawings, catalog cut (s), etc., and proposed to be incorporated into Contract Number 100-01-C-1644 is in compliance with the Contract Drawings and Specifications and will be installed in the allocated space.

Approved: *[Signature]*  
 Submitted: *[Signature]*  
 Approved for Government approval: *[Signature]*  
 Specific design: *[Signature]*  
 Authorized Reviewer: *[Signature]*  
 Signature CQC Rep. *[Signature]*  
 DATE: 7-30-85

Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**

LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

FROM CONTRACTOR

Harry Pepper & Associates, Inc.

TO

Henry Von Oesen & Associates, Inc.

CONTRACT NO

81-C-1644

TRANSMITTAL NO

110-A

DATE

12-4-85

PROJECT TITLE AND LOCATION

Holcomb Blvd Water Treatment Plant

MCB, Cp Lejeune, North Carolina

**CONTRACTOR USE ONLY**

\*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

Contractor Approved

OICC Approval

Deviation/Substitution For OICC Approval

**REVIEWER USE ONLY**

\*\*ACTION CODES

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1	6.4	Manufacturer's Data on Lime Solution Pumps	7	AN	CCS 405 12/24/85

**CONTRACTOR'S COMMENTS**

These pumps match the existing pumps now in use at Bldg # 670, and the existing pumps work to the satisfaction of the owners. If this proposed Deviation is approved, there will be no additional cost to the Government and any changes caused by this Deviation, will be at the expense of the Contractor.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

ONE COPY TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

PHIL REESE, COC

DATE RECEIVED BY REVIEWER

20 Dec 85

FROM (Reviewer)

BM

TO

distribution

Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.

Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

**REVIEWER'S COMMENTS**

COPIES TO  
ROICC (2)  
LANTDIV (1)  
A-E (1)

DATE

3 Jan 86

SIGNATURE

15 Bill Mawyer

-6 JAN 1986 12 58

*[Handwritten signature]*

20/1/86

EQUIPMENT LIST

Three (3) Milroyal pumps, by Milton Roy Company, 2-1/2" plunger diameter, 142 strokes per minute, 245 gallons per hour, 316 stainless steel plunger, cast iron head, 316 stainless steel seats, 404 stainless steel balls, 3/4 horsepower, 230volt/460 volt/3 phase/60 hertz.

NOTE: The above pumps are requested by the owner as explained to me in a meeting held in September 1985. The Milton Roy pump is the same manufacturer as those presently used by Camp Lejeune.

The above pumps have stainless steel plungers in lieu of ceramic. The ceramic plungers have been cracking and the owner is presently using 316 stainless steel plungers.

OPERATING RANGE 10:1

DEVIATION ~~AND~~

ATLANTIC DIVISION  
NAVAL FACILITIES ENGINEERING COMMAND  
NORFOLK VIRGINIA 23511

APPROVED \_\_\_\_\_  
APPROVED AS NOTED   
DISAPPROVED \_\_\_\_\_  
SUBJECT TO THE REQUIREMENTS OF  
CONTRACT NO. **05-81-1644**  
APPROVAL OF A SUBMITTAL DOES NOT INCLUDE  
APPROVAL OF ANY DEVIATION FROM THE CON-  
TRACT REQUIREMENTS UNLESS THE CONTRAC-  
TOR CALLS ATTENTION TO AND SUPPORTS THE  
DEVIATION--THE CONTRACTOR SHALL BE  
RESPONSIBLE FOR PROVIDING PROPER  
PHYSICAL DIMENSIONS & WEIGHTS, COORDINA-  
TION OF TRADES, ETC., AS REQUIRED

REVIEWER CCS DATE 24 DEC 1985

FOR OFFICER IN CHARGE OF CONSTRUCTION

"It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

Approved for use.  
 Submitted for Government approval.  
 Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_  
Signature CQC Rep. Phil Reese DATE 12-4-85


Approved for use subject to Government approval  
Special provision

Approved for use  
Government approval


OFFICIAL


8 DEC 1978

MILTON ROY  
**MILROYAL<sup>®</sup>**  
**CONTROLLED**  
**VOLUME**  
**PUMPS**



**...LOOK INTO MILTON ROY LIQUID CONTROL BEFORE YOU BUY.**






Model C

Models A & B\*

Four configurations of the Milroyal are available, designated models A, B, C, and D. Models A and B are the same frame size, differing only in internal gearing. Model C is the largest Milroyal and Model D is a compact version for laboratory use.



Model D


#### FEATURES

- Interchangeable packed plunger, disc diaphragm or tubular double diaphragm liquid ends available
- Capacities range from 0.1 to 1000 gph
- Discharge pressures to 7500 psi
- Minimum maintenance with totally enclosed design
- Capacities adjustable over full range while pump is in operation
- Finished with chemical resistant paint
- All moving drive parts operate in oil
- 24 month warranty on drive, models A, B, C

The Milroyal controlled volume pump is backed by over 35 years of Milton Roy experience. Because of its high quality and dependability, the Milroyal is the recognized leader in the controlled volume pump field.

The Milroyal is designed and built with maximum precision to accurately proportion highly corrosive chemicals, solvents, viscous liquids and slurries in both industrial and laboratory environments. It can deliver flow rates to 1000 gph and is capable of operating against discharge pressures to 7500 psi.

The Milroyal will give you the most accurate, dependable operation available and at a price that makes it a sound, economical investment.



#### ACCURATE, RELIABLE PERFORMANCE

The Milroyal<sup>®</sup> features free-turning, self-cleaning, double ball check valves to ensure accuracy to within  $\pm 1\%$  with the packed plunger and disc diaphragm liquid ends ( $\pm 1.7\%$  for the tubular double diaphragm).

#### EXCEPTIONAL VERSATILITY

Three interchangeable liquid ends in a variety of metallurgies and plastics are available to suit your particular application. Milroyal Models A and B can be equipped with packed plunger, disc diaphragm or tubular diaphragm configurations; Model C is available with either packed plunger or disc diaphragm.

Motors can be replaced or changed to other types and sizes with ease. Plunger sizes also can be changed quickly permitting flow rate changes up to 75 times the original.

Capacity is continuously adjustable from 0 to 100% while the pump is running, manually with a micrometer dial or automatically with pneumatic or electric controls.

#### LOW COSTS, MINIMUM MAINTENANCE

To reduce maintenance and assure long life, all moving drive parts of the Milroyal run in oil and are totally enclosed to prevent dirt, moisture or corrosive vapors from reaching the drive mechanism.

A unique pressurized oil-lubrication system insures long drive mechanism life and permits the Milroyal to operate at high suction and discharge pressures. A magnetic oil cleaner installed at the suction of the lubricating oil pump reduces wear of moving parts and extends oil life.


#### WIDE RANGE OF CAPACITIES AND PRESSURES

Packed plunger liquid ends can deliver from 0.1 to 1000 gph and are capable of operating against discharge pressures to 7500 psi. Capacities for the disc diaphragm liquid end range from 0.2 to 605 gph, against discharge pressures ranging to 3500 psi. The double diaphragm liquid end can deliver from 0.2 to 475 gph and can operate against discharge pressures to 1000 psi. See the Specification Tables on pp. 8-11 for details of size, capacity, discharge pressures and dimensions.


#### MILROYAL D

The Milroyal line also features the Milroyal D—a compact controlled volume pump for accurately delivering small volumes of liquids under both laboratory conditions and industrial environments. See page 9 for capacities and pressures and for more information request Bulletin 36 001.

The Milroyal is only part of the full line of controlled volume pumps and accessories manufactured by Milton Roy Company for use in industrial, pilot plant or laboratory processes. For information on our complete product line, ask for general bulletin 100.13—or call or write your nearest Milton Roy Sales Office. A company representative who is expert in applying these flow control instruments will be pleased to assist you in selecting the best pump for handling your particular liquid and environment.




Milroyals can be ganged and driven by one motor to control several additive operations simultaneously. Up to nine pumps can be "multiplexed" to obtain high output single liquid pumping or for metering of separate streams in precise ratio, depending on process requirements.




# operation

The heart of the Milroyal<sup>®</sup> controlled volume pump is the unique patented polar crank drive. A high speed worm gear connects motor to polar crank and continuously turns the crank assembly. A connecting rod with spherical bearings on each end links the crank to the crosshead and plunger assembly. The force-feed lubrication system insures positive lubrication of these bearings, permitting high bearing loading with exceptionally long bearing life.



(fig. 1) When the pump is at zero stroke, the worm gear is in a vertical position. The crank then rotates in a vertical plane and one end of the connecting rod revolves with it. The crosshead and plunger remain stationary because no reciprocating action is produced.




(fig. 2) Maximum capacity is pumped when the rotating crank is moved to its maximum angle from the vertical axis. At the top of the rotation cycle the connecting rod is pushed forward, moving the crosshead and plunger to discharge the pump. Conversely, the bottom of the rotation cycle pulls the plunger back to generate suction. A cam-like swiveling action is generated by the polar crank which moves the plunger back and forth to produce the pumping action.

The angle of the polar crank can be adjusted in small increments between zero and maximum stroke for extremely accurate controlled volume pumping.


• A DuPont registered trademark

Internal relief valve provides positive protection against overloads.

Patented air bleeding valve automatically removes air from hydraulic fluid to insure accuracy.



Proven hydraulically-operated Teflon diaphragm liquid end is designed for reliable pumping of corrosive liquids.




Elliptical tubular double diaphragm liquid end offers increased versatility in handling high viscosity liquids and slurries and corrosive and costly chemicals without leakage.

Separate lubricating and hydraulic chambers eliminate oil selection compromises and reduce air entrainment on diaphragm models.

Totally enclosed design prevents dirt, moisture or corrosive vapors from reaching drive mechanism.

Positive micrometer adjustment possible over full flow range while operating. Electric and pneumatic capacity adjustment available.



Patented polar crank drive generates smooth plunger action.

Pressurized lubrication at key points promotes long life under high pressure loads.

Magnetic oil cleaner reduces wear of moving parts and extends oil life.

Free turning, self cleaning double ball check valves help to maintain accuracy to within  $\pm 1\%$ .

Accurately controls corrosive chemicals, light solvents, high viscosity liquids and slurries at high pressures.

To achieve a high thrust capacity, the Milroyal uses a crosshead lubricating pump delivering oil under pressure of 80 psi to all load-carrying surfaces in contact. This positive oil pressure lubrication insures long bearing life and permits the Milroyal pump to operate at very high suction and discharge pressures.

As the crosshead moves forward (discharge), oil from the reservoir at the bottom of the pump is drawn up through a ball check into the cavity in the step of the crosshead bore. During the pump's suction stroke the lubricant is trapped and forced through the crosshead into the crosshead connecting rod bearing and finally into and through the hollow connecting rod where it lubricates the crank connecting rod bearing. Every moving part is lubricated during one complete cycle of the pump.

To reduce the wear of moving parts and extend oil life, a magnetic oil cleaner is installed at the suction of the lubricating oil pump.

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author outlines the various methods used to collect and analyze the data. This includes both primary and secondary data collection techniques. The primary data was gathered through direct observation and interviews with key stakeholders.

The analysis phase involved using statistical software to identify trends and correlations within the data set. It is noted that while the data shows a general upward trend, there are significant fluctuations that require further investigation.

Finally, the document concludes with a series of recommendations based on the findings. These include improving data collection processes, enhancing the accuracy of reporting, and implementing more robust internal controls to prevent errors.

# capacities & pressures

MILROYAL A					
Stroke Length 1½"					
Plgr Dia	SPM	Max Cap gph <sup>2</sup>	Max Discharge Pressure (psig) <sup>3</sup>		
			Packed Plunger	Disc Diaphragm	Tubular Diaphragm
5/16	49	1.1	7500	N/A	N/A
	59	1.4			
	72	1.7			
	95	2.2			
	113	2.7			
142	3.4				
7/16	49	2.2	4450	3500	1000
	59	2.7			
	72	3.3			
	95	4.4			
	113	5.3			
142	6.6				
5/8	49	5.0	2190	2190	1000
	59	6.0			
	72	7.3			
	95	9.6			
	113	11.5			
142	14.4				
3/4	49	10.1	1050	1050	1000
	59	12.1			
	72	14.8			
	95	19.6			
	113	23.0			
142	29.0				
1 1/8	49	17.1	620	620	615
	59	21.0			
	72	25.0			
	95	33.0			
	113	39.0			
142	50.0				
1 1/2	49	30.0	335	335	330
	59	37.0			
	72	45.0			
	95	59.0			
	113	70.0			
142	88.0				
1 3/4	49	41.0	240	240	N/A
	59	50.0			
	72	61.0			
	95	80.0			
	113	95.0			
142	120.0				
2 1/2	49	85.5	105	105	105
	59	102.0			
	72	124.0			
	95	164.0			
	113	195.0			
142	245.0				

MILROYAL B					
Stroke Length 1½"					
Plgr Dia	SPM	Max Cap gph <sup>2</sup>	Max Discharge Pressure <sup>3</sup>		
			Packed Plunger	Disc Diaphragm	Tubular Diaphragm
5/16	46	1.1	7500	N/A	N/A
	70	1.6			
	92	2.2			
	140	3.3			
7/16	46	2.1	6450	3500	1000
	70	3.2			
	92	4.3			
	140	6.5			
5/8	46	4.7	3175	3150	1000
	70	7.1			
	92	9.3			
	140	14.2			
3/4	46	9.5	1555	1500	1000
	70	14.4			
	92	19.0			
	140	28.0			
1 1/8	46	16.0	975	900	900
	70	24.0			
	92	32.0			
	140	49.0			
1 1/2	46	28.0	505	500	500
	70	44.0			
	92	57.0			
	140	87.0			
1 3/4	46	39.0	360	360	N/A
	70	59.0			
	92	78.0			
	140	118.0			
2 1/2	46	79.0	165	165	N/A
	70	121.0			
	92	159.0			
	140	242.0			
3 1/2	46	155.0	75	N/A	100
	70	236.0			
	92	310.0			
	140	475.0			

(1) Stroking speeds based on 1750 RPM motor speed.

(2) GPH listed are for simplex packed plunger liquid end pumps. Capacities differ slightly for disc diaphragm and tubular diaphragm liquid ends.

(3) Maximum discharge pressures shown are obtained by using the largest motor available for each particular pump model.


Model A available in 1/4, 1/3, 1/2, 3/4, 1 HP

Model B available in 1/3, 1/2, 3/4, 1, 1-1/2 HP

Model C available in 1, 1-1/2, 2, 3, 5 HP

Pressures decrease when using a lower HP motor.

(4) Use 1750 RPM motors for 70 and 140 SPM and 1140 RPM motors for 46 and 92 SPM. For a given plunger size, 70 and 46 SPM units are the same pumps, just as the 140 and 92 SPM units are the same pumps. The difference in motor speeds results in the difference in output speeds.



Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**

LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO <b>81-C-1644</b>	TRANSMITTAL NO <b>114</b>	DATE <b>10-17-85</b>
---------------------------------	------------------------------	-------------------------

FROM CONTRACTOR  
**Harry Pepper & Associates, Inc.**

TO  
**Henry Von Oesen & Associates, Inc.**

PROJECT TITLE AND LOCATION  
**Holcomb Blvd Water Treatment Plant**

**Cp Lejeune, North Carolina**

**CONTRACTOR USE ONLY**

\*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

- Contractor Approved       OICC Approval       Deviation/Substitution For OICC Approval

**REVIEWER USE ONLY**

**\*\*ACTION CODES**

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit

ITEM NO	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1	6.5	Shop Drawings on Acid Transfer Pumps and Acid Feed Pumps, Control Panel	7	AN	HP 10/17/85

CONTRACTOR'S COMMENTS

NOTE: A/E The panel is not shown on the Drawings. Please advise Contractor of a location and enclosure type.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC  
**ONE COPY TO ROICC**

CONTRACTOR REPRESENTATIVE (Signature)  
**Phil Reese** *Phil Reese*

DATE RECEIVED BY REVIEWER: *10/18/85*

FROM (Reviewer): *Henry Von Oesen & Associates*

TO: *Harry Pepper & Associates*

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

COPIES TO  
ROICC (2)  
LANTDIV (1)  
A-E (1)

DATE: *10/17/85*

SIGNATURE: *[Signature]*

23 OCT 1985

11 24

*[Handwritten signature]*

23 OCT 1985

11 24

OFFICE OF THE DIRECTOR OF NATIONAL INTELLIGENCE

MEMORANDUM FOR THE DIRECTOR, NATIONAL INTELLIGENCE AGENCY

FROM: [Illegible]

SUBJECT: [Illegible]

DATE: 23 OCT 1985

CLASSIFICATION: [Illegible]

CONTROL NUMBER: [Illegible]

FILE NUMBER: [Illegible]

REPORT NUMBER: [Illegible]

REPORT DATE: [Illegible]

REPORT TYPE: [Illegible]

REPORT STATUS: [Illegible]





REPORT NUMBER: [Illegible]

REPORT DATE: [Illegible]

REPORT TYPE: [Illegible]


CONTROL PANEL—LAYOUT AND FABRICATION

1/4" = 1'-0"



FLOW DIAGRAM

ACID TRANSFER PUMP AND ACID METERING PUMP WIRING DIAGRAM



ATLANTIC DIVISION  
NAVAL FACILITIES ENGINEERING COMMAND  
NORFOLK, VIRGINIA 23511

APPROVED AS NOTED  
DISAPPROVED

SUBJECT TO THE REQUIREMENTS OF  
CONTRACT NO. 10-81-6-1044  
APPROVAL OF SUBMITTAL DOES NOT IMPLY  
APPROVAL OF ANY DEVIATION FROM THE CONTRACT  
REQUIREMENTS UNLESS THE CONTRACTOR  
CALLS ATTENTION TO AND SUPPORTS THE  
DEVIATION... THE CONTRACTOR SHALL BE RESPONSIBLE  
FOR PROVIDING PROPER PHYSICAL  
DIMENSIONS & WEIGHTS, COORDINATION OF  
TRADES, ETC., AS REQUIRED.

REVIEWER: *[Signature]* DATE: OCT 21 1985  
FOR OFFICER IN CHARGE OF CONSTRUCTION

*A/E*  
This Panel is not shown on the drawing  
Location and enclosure type need to be  
determined

- 1) Location shown on this sheet is OK
- 2) Enclosure Nema 4X- SEE SPECS PAGE 11360  
*AMS*

I hereby certify that the material (equipment) shown and indicated in this submittal, shop drawings, catalog cut to, etc., and approved/proposed to be incorporated into Contract Number: 10370-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

Approved for use.

Submitted for Government approval.

Approved for use subject to Government approval of specific deviation.

Authorized Reviewer: *[Signature]* DATE: 10-17-85  
Signature Code: *[Signature]* DATE: 10-17-85

COMBS & ASSOCIATES, INC.			
CHARLOTTE, NORTH CAROLINA			
EXPANSION HOLCOMB	SCALE: AS SHOWN	DRAWN BY: DAH	REVISED: 1
BOULEVARD WTP			
ACID FEED AREA CONTROL PANEL			
DATE: 9-10-85	APPROVED BY:	DRAWING NUMBER: HB 102	



**CONTRACTOR'S SUBMITTAL TRANSMITTAL**

LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO. ST-C-7641	TRANSMITTAL NO. 73	DATE 4/16/85
PROJECT TITLE AND LOCATION Holcomb Blvd Water Treatment Plant		

FROM CONTRACTOR  
Harry Pepper & Associates, Inc.

TO  
Henry and Ocean & Associates, Inc.

**CONTRACTOR USE ONLY**

\*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

- Contractor Approved       OICC Approval       Deviation/Substitution For OICC Approval

**REVIEWER USE ONLY**

**\*\*ACTION CODES**

- A-Approved  
D-Disapproved  
AN-Approved as noted  
RA-Receipt acknowledged.  
C-Comments  
R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
11336		WATER TREATMENT EQUIPMENT			
6.2.5		Access Manholes	7	A	HFW/406 18 APR 85

**CONTRACTOR'S COMMENTS**

Contractor requests to use R-5476 Pressure Manhole Frame and Lid per attached Drwg, in lieu of the one as outlined in Para 6.2.5, due to the availability. If this proposed deviation is approved there will be no cost to the Government and any changes caused by the proposed deviation will be the responsibility of the Contractor at no expense to the Government.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC      CONTRACTOR REPRESENTATIVE (Signature)  
ONE COPY TO ROICC      [Signature]

DATE RECEIVED BY REVIEWER      FROM (Reviewer)      TO

4/16/85      LANTDIV      HARRY PEPPER ROICC

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

**REVIEWER'S COMMENTS**

APPROVED. NO CHANGE IN COST OR TIME.

COPIES TO: ROICC (2), LANTDIV (1), A-E (1)      DATE: 4/22/85      SIGNATURE: [Signature]



1 MAY 1985 12 06

## R-6476 Pressure Manhole Frame and Lid

Heavy Duty

Total Weight 550 Pounds

Especially designed for pressure access covers in treatment plants or reservoirs. Cover is bolted with 28 exposed stainless steel hex head cap screws as specified. Note 2" water seal flange.




## R-6485 Series Slab Manhole Frames and Lids with Inside Trough


Light Duty

Specify:

1. Catalog number.
2. Drain pipe tap size.
3. Pickhole or Type G waterproof handle in lid.



Catalog No.	Dimensions in inches					Wt. Lbs.
	A	B	C	E	F	
R-6485-A	16	3/4	13	20	4	125
R-6485-B	24	3/4	19	30	4	190
R-6485-D	32	3/4	25	36 1/2	6	350
R-6485-E	37 1/2	3/4	31	42 1/2	6	345
R-6485-F	44	1	37	48	6	720
R-6485-G	50 1/2	1	43	54	6	930




Lid Removed  
Furnished with open pickhole  
or Type G lift handle.

## R-6490 Series Light Slab Frames and Covers


Light Duty — for Grease Trap, Cesspools

Specify:

1. Complete catalog number.




Solid



Grated

Solid	Grated	Dimensions in inches					Wt.* Lbs.
		A	B	C	E	F	
R-6490-A5	R-6490-AG	13	1/2	12	17	1 1/2	45
R-6490-B1S	R-6490-B1G	18	1/4	17	21	3	50
R-6490-C1S	R-6490-C1G	19	1/2	18	21	3	60
R-6490-D1S	R-6490-D1G	21	1/2	20	23	3	70
R-6490-E1S	R-6490-E1G	25	1/2	24	27	3	95

\*Weights shown apply to solid type.



"It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut(s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

- Approved for use.
- Submitted for Government approval.
- Approved for use subject to Government approval on specific deviation.

Authorized Reviewer Ph. St. Rose DATE 4-4-85  
Signature CQC Rep.

*W. Schenk*  
3-25-85

DEVIATION: APPROVED ✓

DISAPPROVED

ANTDIV REVIEWER

DATE

HFU  
18 Apr 85

ATLANTIC DIVISION  
NAVAL FACILITIES ENGINEERING COMMAND  
NORFOLK, VIRGINIA 23511

APPROVED \_\_\_\_\_ ✓  
APPROVED AS NOTED \_\_\_\_\_  
DISAPPROVED \_\_\_\_\_  
SUBJECT TO THE REQUIREMENTS OF

CONTRACT NO. 81-1644  
APPROVAL OF A SUBMITTAL DOES NOT INCLUDE APPROVAL OF ANY DEVIATION FROM THE CONTRACT REQUIREMENTS UNLESS THE CONTRACTOR CALLS ATTENTION TO AND SUPPORTS THE DEVIATION - THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING PROPER PHYSICAL DIMENSIONS & WEIGHTS, COORDINATION OF TRADES, ETC., AS REQUIRED.

REVIEWER HFU DATE 18 Apr 85

FOR OFFICER IN CHARGE OF CONSTRUCTION

Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO 81-C-1644	TRANSMITTAL NO 166	DATE 2-17-86
--------------------------	-----------------------	-----------------

FROM CONTRACTOR  
**Harry Pepper & Associates, Inc.**

TO  
**Henry Von Oesen & Associates, Inc.**

PROJECT TITLE AND LOCATION  
**Holcomb Blvd Water Treatment Plant**

**MCB, Cp Lejeune, North Carolina**

<b>CONTRACTOR USE ONLY</b> <i>*List only one specification division per form.</i>  <i>List only one of the following categories on each transmittal form, and indicate which is being submitted</i>	<b>REVIEWER USE ONLY</b> <b>**ACTION CODES</b> A-Approved D-Disapproved AN-Approved as noted RA-Receipt acknowledged. C-Comments R-Resubmit
<input checked="" type="checkbox"/> Contractor Approved <input type="checkbox"/> OICC Approval <input type="checkbox"/> Deviation/Substitution For OICC Approval	

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	03302	CAST IN PLACE CONCRETE			
1	2.2.9	Preformed Joint Filler	4	RA	Rob 3/13/86

CONTRACTOR'S COMMENTS

a(1)

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

**ONE COPY TO ROICC**

DATE RECEIVED BY REVIEWER: 2/21/86

FROM (Reviewer): Henry von Oesen & Assoc., Inc.

CONTRACTOR REPRESENTATIVE (Signature): Phil Reese

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

Contractor's approval appears to be appropriate.

COPIES TO  
ROICC (2)  
LANTDIV (1)  
A-E (1)

DATE: 3/18/86

SIGNATURE: [Signature]

14 MAR 1986 11 31

UNITED STATES DEPARTMENT OF JUSTICE

I hereby certify that the above is a true and correct copy of the original as shown to me by the person who produced it.

DATE: \_\_\_\_\_  
BY: \_\_\_\_\_  
TITLE: \_\_\_\_\_

UNITED STATES DEPARTMENT OF JUSTICE

14 MAR 1986



**FIBER EXPANSION JOINT**

2655 Campus Drive • P.O. Box 5818 • San Mateo, CA 94402 • TWX 910-374-2349 (BURKE SMT) • (415) 349-7600

**FIBER EXPANSION JOINT**

**1. PRODUCT NAME** Fiber Expansion Joint ~~Contract~~ Order No. 236

**2. MANUFACTURED BY** The Burke Company

**3. PRODUCT DESCRIPTION**

**Basic Uses**

Burke Fiber Expansion Joint is composed of fibers bonded together, then impregnated with a durable bituminous compound. The impregnation results in a waterproof, resilient expansion joint that is not affected by temperature changes.

Fiber Expansion Joint is a multi-purpose filler used to prevent stresses in concrete that are caused by temperature, moisture or internal shrinkage changes. The compressible fiber expansion joint allows the concrete structure to expand or contract without damage.

Fiber Expansion Joint is particularly useful in highways, streets, runways, curbs, gutters, driveways, piers, bridges, retaining walls, masonry, reinforced concrete buildings.

It can be sealed with a rubberized asphalt sealer to insure proper joint function.

**Size**

Standard sheets are 3 ft. wide by 10 ft. long (0.9m x 3m) or 4 ft. wide by 10 ft. long (1.2m x 3m) in thicknesses of 1/4", 3/8", 3/4" and 1" (6mm, 9mm, 13mm, 19mm, and 25mm).

Strips available in 1/2" (13mm) increments from 2" to 48" (51mm to 1219mm) widths in thicknesses of 3/8", 1/2", 3/4" and 1" (9mm, 13mm, 19mm and 25mm).

**Precaution**

Store Fiber Expansion Joint on a flat surface to protect against warping.


**4. SPECIFICATIONS**

- ASTM D 1751-73
- AASHTO M 213-74
- HHF 341F, Type 1
- CRD C508-72
- FAS P501-2.4, P610-217
- ANSI A37, 113/1964
- NAVFAC TS 03300, 6.10

I hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

- Approved for use.
- Submitted for Government approval.
- Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_  
 Signature CQC Rep. Phil Fene DATE 2-17-86



Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO 81-C-1644	TRANSMITTAL NO 21-B	DATE 8-16-85
--------------------------	------------------------	-----------------

FROM CONTRACTOR  
 Harry Pepper & Associates, Inc.  
 TO  
 Henry Von Oesen & Associates, Inc.

PROJECT TITLE AND LOCATION  
 Holcomb Blvd Water Treatment Plant  
 MCB, Cp Lejeune, North Carolina

CONTRACTOR USE ONLY	REVIEWER USE ONLY
<p>*List only one specification division per form.</p> <p>List only one of the following categories on each transmittal form, and indicate which is being submitted</p> <p><input checked="" type="checkbox"/> Contractor Approved      <input type="checkbox"/> OICC Approval      <input type="checkbox"/> Deviation/Substitution For OICC Approval</p>	<p>**ACTION CODES</p> <p>A-Approved  D-Disapproved  AN-Approved as noted  RA-Receipt acknowledged.  C-Comments  R-Resubmit</p>

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1	6.2.6	Manufacturer's Data on Hydraulically Operated Filter Valves	4	RA	JPB 8/20/85
	15271	PLANT PIPING			
1	5.4.B (3)	Manufacturer's Data on Hydraulically Operated Valves	4	RA	JPB 8/20/85

CONTRACTOR'S COMMENTS

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC	CONTRACTOR REPRESENTATIVE (Signature) Phil Reese <i>Phil Reese</i>
ONE COPY TO ROICC	
DATE RECEIVED BY REVIEWER 8/20/85	FROM (Reviewer) Henry von Oesen and Assoc., Inc.

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

CONTRACTOR'S APPROVAL APPEAR TO BE APPROPRIATE.

COPIES TO ROICC (2) LANTDIV (1) A-E (1)	DATE 8/20/85 ST VNC 10/43	SIGNATURE <i>Henry von Oesen</i>
--	---------------------------------	-------------------------------------

21 AUG 1985 13 03

COMMUNICATIONS SECTION

UNITED STATES AIR FORCE

OFFICE OF THE

CHIEF OF STAFF

*[Handwritten signature]*

ATTENTION

OPERATIONAL SUPPORT

COMMUNICATIONS

OPERATIONAL SUPPORT

OPERATIONAL SUPPORT

UNITED STATES AIR FORCE

OPERATIONAL SUPPORT

OPERATIONAL SUPPORT

*Item #1*



# M & H VALVE COMPANY


A Division of McWane, Inc.


P. O. Box 2088

Anniston, Alabama 36202

**Drawings and/or**

**Installation, Operating & Maintenance Instructions**





CUSTOMERS NAME: HARRY PEPPER & ASSOCIATES

CUSTOMERS P.O. NO. 642-0009

JOB NAME: EXPANSION OF THE HOLCOMB BLVD. WATER TREATMENT PLANT - MARINE CORPS BASE - CAMP LE JEUNE, NORTH CAROLINA  
CONTRACT NO. NG 2470-81-C-1644

QUOTE NO. 85-1153

ORDER NO. \_\_\_\_\_



**M & H VALVE COMPANY**  
A Division of McWane, Inc.  
P.O. BOX 2088  
ANNISTON, ALABAMA 36202

*1. Provide Letter of Certification  
That Valve Meets AWWA C-504*

It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number NG2470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

- Approved for use.
- Submitted for Government approval.
- Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_

Signature CQC Rep. Phil Rowe DATE 8-16-85




- (1) 18" REQ'D. - BACKWASH VALVE FLANGED MARK C01.
- (3) 18" REQ'D. - WASH VALVES FLANGED MARK C02, C03, C04.
- (3) 10" REQ'D. - EFFLUENT VALVES FLANGED MARK C05, C06, C07.
- (3) 6" REQ'D. - REWASH VALVES FLANGED MARK C08, C09, C010.

COATING IN ACCORDANCE WITH APPLICABLE AWWA STANDARD AND FED. SPEC. IT-C-494A OR EQUAL.

VALVE SIZE	A	B	C	J	P	Q	R	S	AA	AB
4	4	7 1/2	7 1/2	5	8	1 1/2	9	1 1/2	4	1-11
6	5	8 1/2	9 1/2	5	8	1 1/2	11	1 1/2	4	1-10
8	6	9 1/2	11 1/2	6	8	1 1/2	13 1/2	1 1/2	4	1-10
10	7 1/2	12 1/2	14 1/2	8	12	1 1/2	16	1 1/2	—	—
12	9 1/2	14	17	8	12	1 1/2	19	1 1/2	—	—
14	10 1/2	15 1/2	18 1/2	8	12	1 1/2	21	1 1/2	4	1-8
16	12 1/2	17 1/2	21 1/2	8	16	1 1/2	23 1/2	1 1/2	4	1-8
18	13 1/2	19 1/2	22 1/2	8	16	1 1/2	25	1 1/2	4	1-7
20	14 1/2	21 1/2	25	8	20	1 1/2	27 1/2	1 1/2	4	1-7
24	17 1/2	24	29 1/2	8	20	1 1/2	32	1 1/2	4	1-7

OPERATOR MODEL CYLINDER & HANDWHEEL	CYLINDER		D	E	F	G	H	K	L	M	N	T	V	W	Y
	BORE	STROKE													
65	5	2 3/4	2 1/8	3 9/16	7 1/4	5 1/2	12 1/4	3 7/16	2 1/4	1 3/8	16 1/2	7 1/2	7 3/4	3 7/16	1/2-18
150	5	2 3/4	2 1/8	3 9/16	7 1/4	5 1/2	12 1/4	3 7/16	2 1/4	1 3/8	16 1/2	7 1/2	7 3/4	3 7/16	1/2-18
175	6	2 3/4	2 1/8	3 9/16	7 1/4	6 1/2	13	3 7/16	2 1/4	1 3/8	16 1/2	12	7 3/4	3 7/16	1/2-14
510	6	6	3 3/8	4 1/2	12 5/8	6 1/2	18 3/8	6 1/2	2 3/4	3	36	12	10 7/8	5 7/8	1/2-14
1250	8	8	4 1/8	5 3/4	17	10	24	7 7/8	3 1/4	4	48	18	12 1/2	8 3/4	1/2-14
2200	8	12	4 1/8	6 1/4	23	10	30	10 3/4	3 7/8	6	72	18	14 1/2	10 3/4	1/2-14

NOTE: DE-CLUTCH OPERATION  
 1. TURN HANDWHEEL TO LINE UP HOLE IN OPERATOR SHAFT WITH HOLE IN SLEEVE ON VALVE SHAFT.  
 2. INSERT PIN.  
 3. OPEN BY-PASS VALVE ON CYLINDER.  
 4. OPERATE VALVE BY HANDWHEEL.




VALVE IDENTIFICATION PLATE ATTACHED TO HOUSING COVER (STAMPED WITH VALVE PART NUMBER AT FINAL ASSEMBLY.)

NOTE: FLOW MAY BE IN EITHER DIRECTION.

**M & H VALVE COMPANY**  
 A Division of McWane, Inc.  
 P.O. BOX 2088  
 ANNISTON, ALABAMA 36202



NOTE: VALVE SHAFT WILL MEET OR EXCEED REQUIREMENTS OF SHAFT TABLE PER AWWA STANDARD C-504 FOR APPLICABLE CLASS.




WITH 125° ANSI FLANGES & DRILLING PER AWWA C-504

REV. NO. 3818	DATE 8/11/77	BY JPP	ASSEMBLY-STYLE 450 SERIES FLANGED BFW/CYLINDER OPERATOR & HANDWHEEL DE-CLUTCH	SCALE 1/2"=1'-0"	DWG. NO. 99-02079	REV. A
---------------	--------------	--------	---	------------------	-------------------	--------



ITEM NO.	DESCRIPTION	MATERIAL
1	BODY, VALVE	CAST IRON, A-126, B-W/18-8 STN. STL. SEAT
2	VANE	CAST IRON, A-48, CL. 40
3	COVER, END	CAST IRON, A-126, CL. B
4	SEAT RING, VANE	BUNA 'S' W/304 STN. STL. INSERT
5	JOURNAL, VALVE SHAFT	304 STN STL
6	SEAL, SHAFT	BUNA 'S'
7	PACKING, JOURNAL	BUNA 'S'
8	BUSHING, BODY	REINFORCED TEFLON
9	HEX DRIVE SHAFT	CDS-C-1018 STL.
10	CAPSCREW, HEX	18-8 STN STL-W/ 'NYLOK' INSERT
11	NUT, HEX	STL, ASTM A-307, GR. B, ELECTRO-ZINC PLATED
12	STUD	STL, ASTM A-307, GR. B, ELECTRO-ZINC PLATED
13	SPACER	CDS-C-1018 STL.
14	CONNECTOR-SLEEVE	CDS-C-1018 STL.
15	PIN-TAPER	BRASS
16	SHAFT, OPERATOR-DE-CLUTCH	CDS-C-1018 STL.
17	PACKING	RUBBER
18	CHAIN-BEAD	STAINLESS STEEL



SECTION A-A


REVISIONS	DATE	BY	APP

"This drawing includes all detail and provides all necessary information for the manufacture of the part. It is to be used in conjunction with the manufacturing data on this part. It is the responsibility of the manufacturer to ensure that the part is manufactured to the specifications shown on this drawing, and that it is checked against the drawing before use."


SUB-ASSEMBLY-STYLE 450 SERIES FLANGED END BFV W/DE-CLUTCH & BUNA 'S' SEALS				DWG. NO.	REV.
DESIGNED BY	CHECKED BY	DATE	SCALE	99-01395	
J.L.W.	L.C.	8-29-78	FULL		



**M & H VALVE COMPANY**  
A Division of McWane, Inc.  
P.O. BOX 2088  
ANNISTON, ALABAMA 36202




ITEM NO	DESCRIPTION	MATERIAL
1	HOUSING, OPERATOR	CAST IRON, A-126, CL. B
2	COVER, HOUSING	CAST IRON, A-126, CL. B
3	HEAD, CYLINDER, ROD END	CAST IRON, A-126, CL. B
4	HEAD, CYLINDER, BLANK END	CAST IRON, A-126, CL. B
5	NUT, CONNECTING	CAST IRON, A-126, CL. B
6	INDICATOR	CAST IRON, A-126, CL. B
7	PISTON HALF	CAST IRON, A-126, CL. B
8	LEVER	DUCTILE IRON, A-536 GR. 65-45-12
9	CROSSHEAD	DUCTILE IRON, A-536 GR. 80-55-06
10	SLEEVE, CROSSHEAD	ALLOY IRON
11	PISTON ROD	18-8 STAINLESS STEEL
12	TAIL ROD	STEEL, C-1040
13	BUSHING, TAIL ROD	BEARING BRONZE, B-144, ALLOY 3B
14	CARTRIDGE, SEAL	BEARING BRONZE, B-144, ALLOY 3B
15	PISTON CUP	BUNA 'N'
16	BARREL, CYLINDER	<b>BRONZE</b>
17	GUARD, TAIL ROD	COMM. STEEL PIPE
18	INDICATOR PIN	C/D STEEL
19	TIE ROD	STEEL, COMM.
20	NUT, HEX (TIE ROD)	STEEL, COMM.
21	NUT, HEX (PISTON)	STEEL, COMM.-CADMIUM PLATED
22	NUT, HEX (INDICATOR)	STEEL, COMM.
23	CAPSCREW, HEX	STEEL, COMM.
24	PLUG, EXPANSION	BRASS, COMM.
25	RING, RETAINING	SPRING STEEL
26	GASKET, COVER	CORK-NEOPRENE
27	SEAL, ROD	URETHANE, SELF LUBRICATED
28	SEAL (CARTRIDGE)	BUNA 'N'
29	SEAL (PISTON HALF)	BUNA 'N'
30	SEAL (INDICATOR PIN)	BUNA 'N'
31	PLUG, PIPE-SQ. HD.	CAST IRON, COMM.
32	BUSHING	NYLON (MOLY-DISULFIDE FILLED)




REVISIONS				DATE	BY	APP.	<small>This drawing, including all detail and general or otherwise given, unless otherwise indicated, shall be used for the manufacture of the product and is loaned with the understanding that it will not be reproduced nor be used for any purpose except that for which, based on the express permission is granted by the owner, and that it shall be returned on demand.</small>				<b>SUB-ASSEMBLY-CYLINDER OPERATOR</b>		DWG. NO. <b>99-01362</b>	REV. <b>1</b>
							DRAWN BY <b>JAM</b>	CHECKED BY <b>ALR</b>	HD. DESIGNED <b>T</b>	DATE <b>11-17-78</b>	FILE NO. <b>2056-1</b>			


**M & H VALVE COMPANY**  
 A Division of McWane, Inc.  
 P.O. BOX 2088  
 ANNISTON, ALABAMA 36202



ITEM NO.	DESCRIPTION	MATERIAL
1	HOUSING, OPERATOR	CAST IRON, A-126 CL. B
2	COVER, HOUSING	CAST IRON, A-126 CL. B
3	CAP, THRUST	CAST IRON, A-126 CL. B
4	AS REQUIRED	CAST IRON, A-126 CL. B
5	LEVER	DUCTILE IRON, A-536 GR 85-45-12
6	CROSSHEAD	DUCTILE IRON, A-536 GR 80-55-06
7	SHAFT, INPUT	C.D. STEEL, 12 L 14
8	SEAL (HOUSING)	BUNA "N"
9	SEAL (CAP)	BUNA "N"
10	GASKET, COVER	CORK-NEOPRENE
11	SHIELD, SHAFT	REINFORCED TEFLON
12	PLUG, EXPANSION	BRASS, COMM.
13	BOLT, HEX. HD (AWWA NUT)	STEEL, COMM.
14	BOLT HEX HD (COVER)	STEEL, COMM.
15	SLEEVE, CROSSHEAD	ALLOY IRON
16	RING, RETAINING	SPRING STEEL
17	INDICATOR	CAST IRON, A-126 CL. B
18	PIN, INDICATOR	STEEL, COMM.
19	SEAL, INDICATOR PIN	BUNA "N"
20	NUT, HEX	STEEL, COMM.
21	BEARING, NEEDLE	STEEL, COMM.
22	RACE, THRUST	HARDENED STEEL
23	SPACER	HARDENED STEEL
24	WASHER, THRUST	HARDENED STEEL
25	PIN, INPUT SHAFT	STEEL, COMM.
26	BUSHING	REINFORCED TEFLON



OPERATOR MODELS  
510 THRU 2200 ONLY

15

16


5

7


1

HANDWHEEL AND CRANK OPERATOR

INTEGRAL STOP NUT  
MODELS 65 THRU 510 ONLY.




THRUST COLLAR AREA  
MODELS 650 & 2200 ONLY





SECTION A-A  
FOR HANDWHEEL AND  
CRANK OPERATOR ONLY

REVISIONS				DATE				BY				APP				
<small>*This drawing, including all parts and accessories, is the property of M &amp; H Valve Company. It is to be used only for the purposes intended and is not to be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of M &amp; H Valve Company. If you are not the original purchaser of this drawing, you should contact M &amp; H Valve Company for a copy of this drawing.</small>																
SUB-ASSEMBLY MANUAL OPERATOR												DRAWN BY L.S.	CHECKED BY A.L.R.	NO. SHEETS 1	DWG. NO. 99-01351	REV. 
												DATE 5-2-78	SCALE 	P&M NO. 2096-1		

**M & H VALVE COMPANY**  
A Division of McWane, Inc.  
P.O. BOX 2088  
ANNISTON, ALABAMA 36202







**CONTRACTOR'S SUBMITTAL TRANSMITTAL**

LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO. 81-C-1644	TRANSMITTAL NO. 30	DATE 5-1-85
---------------------------	-----------------------	----------------

FROM CONTRACTOR

Harry Pepper & Associates, Inc.

PROJECT TITLE AND LOCATION

Holcomb Blvd Water Treatment Plant

TO

Henry Von Oesen & Associates, Inc.

MCB, Cp Lejeune, North Carolina

**CONTRACTOR USE ONLY**

\*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

Contractor Approved

OICC Approval

Deviation/Substitution  
For OICC Approval

**REVIEWER USE ONLY**

\*\*ACTION CODES

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1	6.2.6 (a)	Manufacturers Data and Drawings on Filter			
		Valves	4		
2	6.5. (a)	Manufacturers Data and Shop Drawings on Acid Storage Tank	4		
3	6.5. (c)	Manufacturers Data and Shop Drawings on Acid Day Tank	4		

CONTRACTOR'S COMMENTS

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

ONE COPY TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

*John Fave*

DATE RECEIVED BY REVIEWER

FROM (Reviewer)

TO

Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.

Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS

Contractor's approval appears to be appropriate.

COPIES TO:  
ROICC (2)  
LANTDIV (1)  
A-E (1)

DATE

SIGNATURE

*W. Brown*

11 79

27 MAY 1965 11 48



*[Handwritten signature]*

CO. 1000  
1000-1000

EXHIBIT 1000

Item #1 PARA 6.2.6 A


# GOLDEN-ANDERSON



**HEYWARD INCORPORATED**  
717 East Boulevard  
Charlotte, North Carolina 28203  
(704) 372-5805

**GA** *Industries Inc.*

**AUTOMATIC VALVE SPECIALISTS**  
9025 MARSHALL RD., MARS, PA 16046 (412) 776-1020  
TELEX: 86-6490



It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut(s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

- Approved for use.
- Submitted for Government approval.
- Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_  
Signature CQC Rep. Phil Reese DATE 5-1-85

*W. Schrock* 3-25-85

# DRAWING SUBMITTAL

VALVE SIZE (3) 20"

FIGURE NO. 1890-LC

SERIAL NO. 850197

PLEASE FURNISH THE FOLLOWING DATA:

MAXIMUM INLET Pressure: \_\_\_\_\_ ?

MAXIMUM CYLINDER OPERATING Pressure: \_\_\_\_\_ ?

MINIMUM Cylinder Operating Pressure \_\_\_\_\_ ?

Back Pressure ON Valve \_\_\_\_\_ ?

*P/E  
PLEASE VERIFY*


JOB HOLCOMB BLVD WATER TREATMENT PLANT

ENGINEERS \_\_\_\_\_

CONTRACTOR HARRY PEPPER & ASSOC

G.A. INDUSTRIES INC.  
MARS, PA.


Handwritten text, possibly a signature or date, located in the middle of the page.



NOTE! CYLINDER SUITABLE FOR MAX. WORKING PRESSURE OF 150 PSIG

F - SIZE M-NUMBER

ROUND OUTLET FLANGE FF (D 125 ASA)



PARTS LIST	
1	DRAIN VALVE BODY
2	BODY COVER
3	PISTON
4	PISTON CUPS (2)
5	PISTON NUT
6	PISTON GASKET
7	STEM CUPS (2)
8	LANTERN RING
9	STEM CUP RETAINER
10	SEAT WASHER
11	SEAT RETAINER FOLLOWER
12	SEAT SCREWS
14	DISC
15	COVER BOLTS
16	INDICATOR
17	INDICATOR GLAND
18	INDICATOR GLAND SEAL
19	INDICATOR BUSHING
20	CLEVIS
21	CYLINDER
22	CYLINDER NUTS
23	CYLINDER STUDS
24	CYLINDER COVER
25	CYLINDER GASKETS (2)
26	STEM RETAINER GASKET
27	STEM BUSHING
28	STEM
30	COVER GASKET
31	INDICATOR LOCKNUT
32	SEAT RING
33	STEM-DISC GASKET
34	CLEVIS SET SCREW
35	INDICATOR SEAL

Per Pat 6,216 A

GENERAL DIMENSIONS									
	0	12	14	16	20	24	30		
A	11	12	14	15	16.3	18	22	23	
E	26.5	27	30	27	35	42	42	50	
C	15.5	18	20	25	29	29			
D	15	17	19	20.5	28	29	32	37	
E	6.8	7.5	9.1	7	14	18	18	18	
F	3/4	3/4	3/4	3/8	3/8	3/8	3/8	3/8	
G	1	1	1	1	1	1	1	1	
H	3	3	3	3	3	3	3	3	
J	8	8	8	8	8	8	8	8	
M	8	8	9	12	12	12	16		
N	3	3	3	3	3	3	3		
P	3/8	3/8	3/8	3/8	3/8	3/8	3/8		
Q	4	6	6	5	11	12			
R	3/8	3/8	3/8	3/8	3/8	3/8			

MAXIMUM INLET PRESSURE \_\_\_\_\_  
 MINIMUM & MAXIMUM CYLINDER PRESSURE \_\_\_\_\_  
 CYLINDER OPERATING FLUID \_\_\_\_\_


NOTE: WHEN ORDERING PARTS SPECIFY PART NUMBER, NAME OF PART, SIZE OF VALVE FOR WHICH REQUIRED AND MENTION TRADE SERIAL NUMBER FROM VALVE IDENTIFICATION PLATE.

GOLDEN-ANDERSON VALVE SPECIALTY CO., PITTSBURGH, PA.


DATE	REV	BY	CHKD

K 1/2" AIR LINE DRAIN VALVE  
 SQUARE INLET, ROUND OUTLET  
 CYLINDER OPERATED  
 GENERAL ARRANGEMENT


DRAWN: K-11  
 CHECKED: JSC  
 DATE: 7/24/62  
 SCALE: 1/2" = 1"  
 97116







850197



F-SIZE  
M-NUMBER

NOTE  
CUSTOMER TO  
ADVISE DIMENSIONS  
A, B, & J.

GENERAL DIMENSIONS


SIZE	10"	12"	14"	16"	18"	20"	24"	30"
A						28 1/4		
B						36		
C	7/8	3/4	1	1 1/4	1 1/2	1 1/4	1 1/4	1 1/4
D	15	17	19	23 1/2	28	29	32	37
E	6 1/4	7 3/8	8 1/2	7	8 1/4	8 1/2	9 1/8	8 9/16
F	5/8-11NC	5/8-11NC	5/8-11NC	3/4-10NC	3/4-10NC	3/4-10NC	5/8-11NC	3/4-10NC
G	10	12	14	16	18	20	24	30
H	5/8	1/2	3/4	1	1	1	1	1
J						5 1/2		
K	11	13	15 1/4	17 3/4	20	21 3/4	25 1/2	31 1/2
L	14	15	18	22 3/4	24	26 3/4	30	34
M	8	8	8	12	12	12	12	16


NOTE:  
10", 12", 14" & 30"  
VALVE HOLES  
ARE ON CENTER  
LINE & DO NOT  
STRADDLE C.

FIELD VERIFY

ITEM  
1159

GOLDEN-ANDERSON VALVE SPECIALTY CO., PITTSBURGH, PA. 10" TO 30" SQUARE OPENING WALL THIMBLE IRON ~ GENERAL ARRANGEMENT	REFERENCES:	SCALE:	DRAWN BY: R.H.L.
		FIG. NO.:	DATE: 7-25-62
	II 0.04F1890	FILE: 33 140	DWG. NO.: 78327










W Schock 4-3-85





Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO <b>81-C-1644</b>	TRANSMITTAL NO <b>160</b>	DATE <b>1-28-86</b>
---------------------------------	------------------------------	------------------------

FROM CONTRACTOR  
**Harry Pepper & Associates, Inc.**

TO  
**Henry Von Oesen & Associates, Inc.**

PROJECT TITLE AND LOCATION  
**Holcomb Blvd Water Treatment Plant**

**MCB, Cp Lejeune, North Carolina**

<p align="center"><b>CONTRACTOR USE ONLY</b></p> <p align="center"><i>*List only one specification division per form.</i></p> <p align="center"><i>List only one of the following categories on each transmittal form, and indicate which is being submitted</i></p> <p><input checked="" type="checkbox"/> Contractor Approved      <input type="checkbox"/> OICC Approval      <input type="checkbox"/> Deviation/Substitution For OICC Approval</p>	<p align="center"><b>REVIEWER USE ONLY</b></p> <p align="center"><b>**ACTION CODES</b></p> <p>A-Approved D-Disapproved AN-Approved as noted RA-Receipt acknowledged. C-Comments R-Resubmit</p>
--	--

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1	6.2.6 a	Manufacturer's Certification on Filter Drain Valves	4	RA	JUB

CONTRACTOR'S COMMENTS

---

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

**ONE COPY TO ROICC**

CONTRACTOR REPRESENTATIVE (Signature)  
**Phil Reese** *Phil Reese*

DATE RECEIVED BY REVIEWER: **1/29/86**

FROM (Reviewer): **Henry von Oesen & Assoc.**

TO:

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

Contractor's approval appears to be appropriate.

*Carson*

COPIES TO ROICC (2) LANTDIV (1) A-E (1)	DATE <b>30 JAN 1986</b> <b>1/29/86</b>	SIGNATURE <i>Phil Reese</i>
--	--	--------------------------------

30 JAN 1986 13 09

CONFIDENTIAL - SECURITY INFORMATION

THIS DOCUMENT CONTAINS UNCLASSIFIED INFORMATION EXCEPT WHERE SHOWN OTHERWISE

CONFIDENTIAL - SECURITY INFORMATION

*Handwritten signature or initials*

CONFIDENTIAL - SECURITY INFORMATION

# GA Industries Inc.

AUTOMATIC VALVE SPECIALISTS

9025 MARSHALL ROAD  
PHONE (412) 776-1020

MARS, PA 16046  
TELEX 86-6490

December 10, 1985

Harry Pepper & Associates  
119 West Eighth Street  
P.O. Box 3007  
Jacksonville, FL 32206

### Letter of Certification

Harry Pepper & Associates P/O #C642-0010  
GAI S/N 850197

(3) 20" 1890-LC Filter Drain Valves Plus Thimbles

We hereby certify that the above mentioned valves are in strict compliance with the most recent ANSI & AWWA specifications covering these items. Furthermore, we certify that the items furnished in this contract are in full compliance with the Purchaser's contract conditions, in our best interpretation thereof.

Sincerely,

GA INDUSTRIES, INC.

*Ted Soens*

Ted Soens  
Valve Department

TS/tr

Sworn - before me on this  
date 1-10-86

*Juanita M. Scharf*

JUANITA M. SCHARF, NOTARY PUBLIC  
CRANBERRY TWP., BUTLER COUNTY  
MY COMMISSION EXPIRES JULY 11, 1989  
Member, Pennsylvania Association of Notaries

"It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:


- Approved for use.  
 Submitted for Government approval.  
 Approved for use subject to Government approval of specific deviation.

Authorized Reviewer

DATE

Signature CQC Rep. *Phil Peere*

DATE 1-28-86



16/11/2011

Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO. 81-C-1644 TRANSMITTAL NO. 16 DATE 4-2-85

FROM CONTRACTOR  
HARRY KOPPEL & ASSOCIATES INC.

PROJECT TITLE AND LOCATION  
Wolcomb Blvd WTP  
MCB, Cp Lejeune, North Carolina

TO  
HENRY VON OESSEN ASSOCIATES INC.

**CONTRACTOR USE ONLY**

**REVIEWER USE ONLY**

\*List only one specification division per form.

\*\*ACTION CODES

List only one of the following categories on each transmittal form, and indicate which is being submitted

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit

Contractor Approved

OICC Approval

Deviation/Substitution For OICC Approval

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
113316		Water Treatment Equipment			
1 4.2 A		Water Softener Shop Drawings	5	RA	JB 4/12/85

**CONTRACTOR'S COMMENTS**

MANUFACTURERS DATA + Certification ON WATER SOFTENERS to be forwarded at a later date -

**COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC**

**CONTRACTOR REPRESENTATIVE (Signature)**

One Copy to ROICC

Phil Fene -

**DATE RECEIVED BY REVIEWER**

**FROM (Reviewer)**

**TO**

4/5/85

HENRY VON OESSEN & ASSOC

ROICC

Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.

Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

**REVIEWER'S COMMENTS**

CONTRACTOR'S APPROVAL APPEARS TO BE APPROPRIATE

4-23-85

COPIES TO:  
ROICC (2)  
LANTDIV (1)  
A-E (1)

**DATE**

**SIGNATURE**

4/12/85

15 24 Phil Fene

15 APR 1965 12 54

One bottle of KOIGG

APR 1965

APR 1965  
APR 1965  
APR 1965

APR 1965  
APR 1965

APR 1965  
APR 1965  
APR 1965

"It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut (s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

- Approved for use.
- Submitted for Government approval.
- Approved for use subject to Government approval of specific deviation.


Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_  
Signature CQC Rep. Phil Reese DATE 4-2-85



J. Schock 3-11-85

11336 4.1.9  
4.2.9









ASSEMBLY - CATALYST CHARGING HOPPER

- NOTE:-
- 1- ALL PIPING SHOWN SHADED BY OTHERS
  - 2- ALL PIPE & NIPPLES TO BE SCH. 40 C.S.
  - 3- ALL FITTINGS TO BE 125 LB. C.I. SCR. EXCEPT AS NOTED.

JOB NO. A141D43225

REV.	BY	DATE	REVISIONS


**PERMUTIT**<sup>®</sup>  
A COMPANY

SCALE NONE DATE 3-4-85

101-40197



REPRO 101-08796

MADE A. WHITE CHECKED



NOTE: DO NOT SCALE

DRAWING. USE DIMENSIONS ONLY.



**NOTES**

1. ROUND OFF TOP EDGE OF TANK.
2. FABRICATION TO BE AWWA D100 & PERMUTIT CO. SPEC. 106.
3. ALL COUPLINGS TO BE PLUGGED BEFORE WELDING W/PLUGS LEFT IN PLACE.
4. SHIP TANK SET-UP FULLY SHOP FABRICATED AS SHOWN.
5. NO SHOP PAINT REQUIRED.

**DETAILS OF 3'-0" I.D. x 9" I.D. 2'-6" HG. CATALYST HOPPER**

PROVIDE CERT. PER 4.3.16

31357

DRAWN BY	WHITE
CHECKED BY	WAKEFIELD
APPR'D. BY	
12046	

Job No. A141D43225


REV.	BY	DATE	REVISIONS


**PERMUTIT**  
WATER AND WASTE TREATMENT

SCALE 1/2" = 1'-0"

DATE 2-26-85


DRAWING NO.	REV.
157-33575	0





PLAN

Should be 55.67



ELEVATION

REFERENCE DRAWINGS:  
 TANK DETAIL — 156-18931  
 ANCHOR BOLT — 184-18862  
 PERMIT PIPING JOI-38378  
 TERMINAL POINTS  
 ASSY CATALYST HOPPER 101-40197  
 CATALYST HOPPER-157-33575  
 TANK.

CARRY OPERATING CHAINS TO 4'-0" ABOVE THE OPERATING FLOOR.  
 EL. 28.33' TOP OPERATING FLOOR (REF.)  
 CONCRETE FOUNDATION PADS (BY OTHERS)

**DO NOT SCALE THIS DRAWING  
 USE DIMENSIONS ONLY**  
 THIS PRINT AND THE IDEAS CONTAINED HEREIN ARE THE EXCLUSIVE PROPERTY OF THE PERMUTIT COMPANY, INC. AND ARE TO BE USED ONLY IN ACCORDANCE WITH THE PROPOSAL, JOB, OR CONTRACT OF THE PERMUTIT COMPANY, INC. IF THE PROPOSAL IS NOT ACCEPTED, THIS PRINT IS TO BE RETURNED TO THE PERMUTIT COMPANY, INC.  
 THE USE OR DISTRIBUTION OF THIS PRINT OR THE IDEAS CONTAINED IN THIS PRINT BY ANY PERSON, FIRM OR CORPORATION WITHOUT THE PERMUTIT COMPANY, INC.'S WRITTEN APPROVAL SHALL BE DEEMED BY THE PERMUTIT COMPANY, INC. AS A VIOLATION OF ITS RIGHTS.

REV.	BY	DATE	REVISIONS

EXPANSION OF HOLCOMB BOULEVARD W.T.P. MARINE CORP BASE CAMP LEJEUNE N.C.  
 JOB NO. A141D43225

DRAWN A. WHITE  
 CHECKED  
 APPRD  
 DATE 3-4-85  
 SCALE 3/8" = 1'-0"


TYPICAL LAYOUT (3)  
 10'-0" TOP D. x 2'-6" BOTT. D.  
 x 23'-3" HG. MODEL 12 S  
 SPIRATORS.


**PERMUTIT**  
 A ZURN COMPANY

DRAWING NO.	REV.
157-33607	0
SHEET 1	OF 1











**NOTE**  
 PERMUTIT CO. ASSUMES NO RESPONSIBILITY FOR DESIGN, MATERIAL AND OR LABOR FOR CONCRETE FOUNDATION & PADS.

PLAN OF ANCHOR BOLT LOCATIONS




ELEVATION OF CONCRETE PADS



ENLARGED DET. "A"  
(REF.)

<p>DO NOT SCALE THIS DRAWING USE DIMENSIONS ONLY</p> <p>THIS PRINT IS THE PROPERTY OF THE PERMUTIT COMPANY. IT IS TO BE USED ONLY FOR THE PURPOSE FOR WHICH IT WAS LENT, AND MUST NOT BE USED IN ANY WAY DETRIMENTAL TO THE INTEREST OF THIS COMPANY, AND IS SUBJECT TO RETURN UPON REQUEST.</p>	REV.	BY	DATE	REVISIONS	<p>EXPANSION OF HOLCOMB BOULEVARD W. T. P. MARINE CORP BASE CAMP LEJEUNE, N.C.</p> <p>JOB NO. A141D43225</p>	<p>DRAWN A.W.L.T.E</p> <p>CHECKED S.W.A.F.E.D</p> <p>APPR'D R.T.</p> <p>DATE 2-25-35</p> <p>SCALE 1/4" = 1"</p>	<p>CONCRETE FOUNDATION DETAILS (3) SPIRACTORS</p>	<p>PERMUTIT</p>	
						DRAWING NO.		REV.	
						184-18862		0	
						SHEET		OF	1





Heint

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**

LANTDIV NORFOLK 4-43553 (Rev. 11-80)

CONTRACT NO. 61-C-1644	TRANSMITTAL NO. 42	DATE 5-13-85
---------------------------	-----------------------	-----------------

FROM CONTRACTOR  
**Harry Pepper & Associates, Inc.**  
 TO  
**Henry Von Oesen & Associates, Inc.**

PROJECT TITLE AND LOCATION  
**Holcomb Blvd Water Treatment Plant**  
**MCB, Co Lajeme, North Carolina**

**CONTRACTOR USE ONLY**

**REVIEWER USE ONLY**

\*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

**\*\*ACTION CODES**

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit

- Contractor Approved       OICC Approval       Deviation/Substitution For OICC Approval

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1		Letter from Warminster Fiberglass Company on Design Features	7	A	CCS 405 5/21/85
2	6.2.2	Manufacturers Data on Wash Troughs	7	↓	↓
3	6.2.2	Shop Drawings on Wash Troughs	7	↓	↓

**CONTRACTOR'S COMMENTS**

If this proposed deviation is approved, there will be no additional cost to the Government and any changes caused by this deviation/substitution will be the responsibility of the Contractor, at no expense to the Government.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

ONE COPY TO ROICC

*Phil Rice*

DATE RECEIVED BY REVIEWER

FROM (Reviewer)

TO

5/13/85

LANTDIV

ROICC/HARRY PEPPER

Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.

Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

**REVIEWER'S COMMENTS**

APPROVED A NO CHANGE IN COST OR TIME.

COPIES TO:  
ROICC (2)  
LANTDIV (1)  
A-E (1)

DATE

SIGNATURE

31 5/13/85

*Heint*

31 MAY 1985 11 36

# WARMINSTER FIBERGLASS COMPANY

P.O. BOX 188 • COUNTY LINE ROAD • SOUTHAMPTON, PENNSYLVANIA 18966 • U.S.A.  
(215) 674-6900

CUSTOM MOLDERS OF REINFORCED FIBERGLASS PRODUCTS



Harry Pepper & Associates  
P. O. Box 3007  
Jacksonville, FL. 32206

Date: April 26, 1985

*Item #1*

Sub: Shop drawings on wash troughs for Camp LeJeune, your P.O. 642-0013

Attention: Mr. James R. Schock

Ref: Our S.O. 24151-1

Dear Mr. Schock:

Thank you for your order #642-0013 for the fiberglass wash troughs in the filters of Camp LeJeune, and for subsequently sending plan details for our shop drawings. We are pleased to enclose 11 copies of our drawing #24151-1 with proposed details of the wash troughs, and wish to comment on a couple design features, for which reason we urge you include a copy of this letter with your transmittal to the engineers:

1) Since we do not have a mold for the 16" trough width shown in the engineer's plans, we propose our next largest width of 18", which will provide greater capacity and should cause no hydraulic problems. Assuming this to be acceptable, please note the larger box-out size that would be necessary through the gullet wall, for which we would recommend 24" minimum.

2) The end mounting with the blind end of the trough fastened firmly against the filter wall, with stainless steel straps and wedge anchors, is one that has worked for over 20 years and in thousands of wash troughs. It is extremely rigid, and with the grouting-in of the gullet end will provide the firmest possible hold and best control over deflection and vibration.

3) The design incorporating steel angles molded into the top edges of the trough and completely encapsulated in fiberglass is one we have used for 20 years and provides extreme rigidity. Its use can also be seen in our trough specification sheet #WFT1000, of which 6 copies are enclosed.

If there are any questions please let us know and thanks again for your order and cooperation.

Very truly yours,

*Paul Sanford*  
PAUL E. SANFORD

President & General Manager



PES:ef

Encl: Drawings  
6 - Trough brochures

CC: Tony Combs, Combs & Associates  
P.O. Box 32185, Charlotte, N. C. 28232-2185

"It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut(s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:

- Approved for use.
- Submitted for Government approval.
- Approved for use subject to Government approval of specific deviation.

Authorized Reviewer Phil Reese DATE 5-13-85  
 Signature CQC Rep. \_\_\_\_\_ DATE \_\_\_\_\_

*W Schork* 5/3/85

**ATLANTIC DIVISION**  
**NAVAL FACILITIES ENGINEERING COMMAND**  
 NORFOLK, VIRGINIA 23511

APPROVED  \_\_\_\_\_  
 APPROVED AS NOTED \_\_\_\_\_  
 DISAPPROVED \_\_\_\_\_

SUBJECT TO THE REQUIREMENTS OF  
 CONTRACT NO. **05-81-1644**

APPROVAL OF A SUBMITTAL DOES NOT INCLUDE  
 APPROVAL OF ANY DEVIATION FROM THE CON-  
 TRACT REQUIREMENTS UNLESS THE CONTRAC-  
 TOR CALLS ATTENTION TO AND SUPPORTS THE  
 DEVIATION--THE CONTRACTOR SHALL BE  
 RESPONSIBLE FOR PROVIDING PROPER  
 PHYSICAL DIMENSIONS & WEIGHTS COORDINA-  
 TION OF TRADES, ETC., AS REQUIRED

REVIEWER CCS DATE **21 MAY 1985**

FOR OFFICER IN CHARGE OF CONSTRUCTION



## Fiberglass Reinforced-Plastic Troughs

Fiberglass reinforced polyester troughs, manufactured by Warminster Fiberglass Company, are designed for use in water and sewage treatment plants. They are furnished for use as wash troughs in the backwashing of gravity filters, or as collection troughs or launders in structures such as clarifiers, aeration tanks and setting basins.


Warminster Fiberglass troughs are available in a wide variety of widths and depths with round or flat bottoms. They can be molded in a circular configuration to mount against a round tank wall or inboard from the tank wall to double the weir edge footage.

### DESIGN FEATURES

- **Corrosion Resistance:** The tough gel-coated surface of the fiberglass trough, with color molded in, is unexcelled in resistance to corrosion, normal abrasion, sunlight, and atmospheric conditions. Special materials are available for highly corrosive chemical applications. Painting, sandblasting and other costs of maintaining steel troughs are eliminated with fiberglass.
- **Light Weight:** The light weight of fiberglass troughs permits easy installation without special lifting equipment and reduces handling, shipping and storage costs.
- **Precision Molded:** Precision molding of fiberglass troughs provides straight edges for ease of leveling and good flow distribution. Weir edges are molded straight to within 1/8 of an inch and the edges are molded in. No cutting and resealing is necessary.
- **Strong and Rigid:** Molded-in steel stiffening ribs provide strength and rigidity and prevent twisting. The use of steel ribs on many trough styles permits long spans without center hangers or supports. Successful wash trough installations prove that with up to 24 feet span, an  $\frac{1}{1000}$  vertical deflection is achieved with water to the weir edges and the trough empty. Also for long spans, allowance for thermal expansion can be incorporated by special designs.

### OPTIONS

- Factory-set weir plates to proper elevation.
- Special sizes, shapes, transitions outlet flanges, drop boxes.
- Stainless steel spacer rods.
- Adjustable weir plates, straight edge or V-notch.
- Selection of colors
- Resins for severe chemical or high temperature applications.
- Wall anchors or mounting brackets.
- Stainless steel cable sets to prevent trough oscillation.



### WASH TROUGHS

The Warminster Fiberglass Company trough design, with steel angle molded into the weir edge, provides the most rigid trough available with the least vertical deflection. Final leveling of troughs is accomplished by use of slots in the blind end which is held by stainless steel straps and anchors. A grouting rib on the trough outlet provides firm anchoring and a water-stop. In addition, straight-edge weir plates are available with stainless steel fasteners to permit adjustment to different elevations. Sufficient plastic spacer rods are provided to maintain a uniform width over the length of each trough.

# SUGGESTED WASH TROUGH SPECIFICATION

All necessary wash troughs shall be supplied and installed as shown on the plans. The troughs shall be manufactured by Warminster Fiberglass Company, Southampton, PA. Troughs shall be laminated of fiberglass reinforced polyester resin to an average thickness of 1/4". The inside surface of each trough shall have a smooth gel coat finish. The outside surface of each trough shall be resin sealed with no exposed glass fibers. Color shall be molded in and an ultraviolet inhibitor shall be used.

Troughs shall have round bottoms and vertical sides. Top edges of the troughs shall be straight with no more than 1/8-inch deviation from a true plane. Longitudinal steel stiffening ribs shall be integrally molded on the outside of the troughs to assure rigidity. Sufficient plastic spacer rods shall be included to maintain a uniform width over the length of each trough. Troughs shall be designed to

support the applied water loadings at each location and shall be made of laminate with the following minimal physical properties: Tensile strength—14,000 psi; Flexural strength—25,000 psi; Flexural modulus— $1.0 \times 10^6$  psi.

A 2-inch wide, 1/2-inch thick wall grouting rib shall be molded to the outside of each trough at the gullet end to act as a water stop when the trough is grouted in place. Slotted holes shall be provided in the closed end of each trough to allow a minimum vertical level adjustment of one inch. Stainless steel wall anchors and flat bars shall be provided.


Troughs shall be set in place with weir edges at elevations shown on the plans. Weir edges should be leveled to within 1/8-inch of level over their entire length. Troughs shall be grouted in place after leveling.

## ROUND BOTTOM TROUGHS

DIMENSIONS TABLE					
WIDTH					
W	12	18	21	24	30
R	6	9	10-1/2	12	15
A	4	4	4	4	6
B	2	3	3	5	7
C	3-1/2	6-1/2	8	9	12
D	2-1/2	5	6	7	9
E	9	15	18	20	26
F	7	12	14	16	20
H	AS REQUIRED				
L	AS REQUIRED				

Item No.	Quantity	BILL OF MATERIAL
		DESCRIPTION
1	1	Trough-Fiberglass & Steel Ribs
2	"X" + 1	Spacer Rods-pvc w/1" OD Solid "W" Long
3	Double Item 2	Spacer Bolts-Stainless-3/8-16NC x 1-1/4 Hex Head
4	Double Item 2	Spacer Washers-Stainless-3/8 ID Flat
5	1	End Bar-Stainless-1/4 x 1-1/4 x "E" Long
6	1	End Bar-Stainless-1/4 x 1-1/4 x "F" Long
7	5	Anchor Bolts-Stainless-1/2-13 NC x 4-1/4" Long
8	5	End Washers-Stainless 1/2 ID Flat
9	5	End Nuts-Stainless 1/2-13 NC -Hex

## DIMENSIONS




## COLLECTION AND EFFLUENT TROUGHS

A variety of standard trough sizes are supplied in many different configurations by Warminster Fiberglass Company for collection trough applications. These troughs are often flat bottomed and supplied with adjustable V-notch fiberglass weir plates. The troughs are equipped with spacer rods and reinforcing members to maintain uniform size, shape, and rigidity over the full length of the trough. The troughs may be fastened to steel or concrete tank walls, or supported by braces, hangers or piers.


Weir plates when required are preassembled to trough walls. Scum baffles are frequently supported from the wall of the trough. Weir plates shall be field adjusted by the contractor after installation to compensate for deflection and mounting of troughs.

Special transition pieces, "T" sections, flanged outlets and drop boxes are available. To provide additional weir footage, the troughs may be mounted inboard from the wall of circular or rectangular tanks, with weir plates along both sides of the trough. In circular tank applications, troughs may be molded circular, concentric with the tank walls, providing a more economical installation than with straight chordal troughs. This produces more uniform flow, and simplified, more precise erection. The molded circular shape also utilizes a single size support bracket, a single size scum baffle support bracket, and a scum baffle which is concentric with the trough because of the uniform spacing of the circular trough from the tank wall.

Standard Flat Bottom Trough Widths:  
12", 15", 18", 21", 24", 36"




Typical Side View with Hangers



1 Trough to have Smooth Gel-Coated Inside Surface, Backed by Fiberglass Reinforced Polyester Resin

1/4 Thickness Nominal Except as Noted

BILL OF MATERIAL	
Item No	DESCRIPTION
1	Trough - Fiberglass & Steel Ribs
2	Spacer Rods - pvc - 1" OD Solid x "W" Long
3	Weir Plates - Fiberglass
4	Gasket - 1/2" Neoprene Sponge
5	Weir & Spacer Bolts - Stainless - 3/8" - 16 NC - 1-1/2 Hex
6	Weir & Spacer Washer Stainless
7	Weir Nuts Stainless
8	Drill Anchors - Stainless 1/2 - 13 NC x 4-1/4" Long
9	Hanger Bracket & Hardware Stainless
10	Hanger Rods Stainless 3/4"
11	Hanger Angles & Hardware - Stainless



## SUGGESTED COLLECTION TROUGH SPECIFICATION


All necessary effluent (collection) troughs (launders) shall be supplied and installed as shown on the plans. The troughs shall be manufactured by Warminster Fiberglass Company, Southampton, PA. Troughs shall be laminated of fiberglass reinforced polyester resin to an average thickness of 1/4-inch. The inside surface of each trough shall have a smooth white (or other) gel coat finish. The outside surface of each trough shall be resin sealed with no exposed glass fibers. Color shall be molded in and an ultra-violet inhibitor shall be used.

Troughs shall have flat (round) bottoms and vertical sides. Top edges of the troughs shall be straight with no more than 1/8-inch deviation from a true plane. Longitudinal stiffening ribs shall be integrally molded on the outside of the troughs to assure rigidity. Sufficient plastic spacer rods shall be included to maintain a uniform width over the length of each trough.

Spacer rods shall be spaced to prevent buckling, and to provide maximum resistance to water loading on the sidewalls of the trough. The troughs shall be fabricated of fiberglass reinforced polyester resin, with fiberglass constituting a nominal 30% by weight. The resin shall be of a general purpose high

quality. The glass reinforcement shall be random chopped-strand type with a minimum strand length of 1-inch, and adequate contact molding pressure to provide complete wet-out of the glass fibers. The material shall have the following minimum physical properties: Tensile strength—14,000 psi; Flexural strength—25,000 psi; Flexural modulus— $1.0 \times 10^6$  psi.

Fiberglass adjustable weir plates shall be pre-assembled to the troughs when shown on the drawings. Trough layout, outlet, and support system shall be as shown on the drawings. All anchors and fasteners shall be Type 304 (316) stainless steel. The support system shall allow 1-inch minimum adjustment of the trough, horizontally and vertically, and shall allow no greater than  $\frac{L}{1000}$  upward deflection with the trough empty and water to the weir edge. Stabilizers (cable sets) shall be provided where necessary to restrict lateral movement (oscillation). Final weir plate adjustment shall be performed by the contractor after installation of troughs. Weir plates shall be adjusted to compensate for designed upward deflection and to bring weir plates to correct crest elevation. Design deflection shall be  $\frac{L}{1000}$  between supports.



### Formula for height:

$$\text{gpm} = 857 W H_a^{3/2}$$

Where gpm = flow in trough in gallons/min (max)

W = width inside in feet

H<sub>a</sub> = basic height in feet

Total height (H<sub>b</sub>), Flat bottom = H<sub>a</sub> + 2" (allows 2" for freeboard)

Total height (H<sub>b</sub>), Round bottom trough = H<sub>a</sub> + 4" (allows for round bottom plus approx. 2" of freeboard)

### Example:

Each trough to take 2,000 gpm max (round bottom)

Trough width of 18" = 1.5 ft desired

$$2,000 = 857 \times 1.5 H_a^{3/2}$$

$$H_a^{3/2} = 1.556$$

$$H_a = 1.343 \text{ ft} = 16\text{-}1/8 \text{ in}$$

$$H_b, \text{ Actual trough height} = 16\text{-}1/8 + 4" = 20\text{-}1/8"$$

NOTE: Specifications are subject to change without notice.

1 2 3 4 5 6 7

1/2 x 1 1/2 x 1/4 GALVANIZED STEEL ANGLES  
MOLDED IN FIBERGLASS -  
FULL LENGTH - BOTH SIDES


MOLDED WEIR  
EDGES

BILL OF MATERIAL

Item # 3


ITEM NO.	QUANTITY	DESCRIPTION
1	1	TROUGH - FIBERGLASS, POLYESTER & GALVANIZED STEEL
2	"S"+1	SPACER RODS - PVC - 1" OD SOLID X "W" LG. - TAPPED 3/8-16 NC
3	DOUBLE ITEM 2	SPACER BOLTS - STAINLESS - 3/8-16 NC X 1 1/2" - HEX HEAD
4	DOUBLE ITEM 2	SPACER WASHERS - " - 3/8" ID - FLAT
5	1	END BAR - " - 1/4 X 2 X "E" LG. - 5/8 HOLES
6	1	END BAR - " - 1/4 X 2 X "F" LG. - 5/8 HOLES
7	5	DRILL ANCHORS " - 1/2-13 NC - PHILLIPS # WY-1242
8	5	ANCHOR NUTS - " - 1/2-13 NC - HEX
9	5	ANCHOR WASHERS - " - 1/2" ID - FLAT

INDUSTRY STANDARD



1/4 THICK,  
EXCEPT RIBS  
& BLIND END

"S" SPACES  
OF 36" SPACER  
RODS



SYMMETRICAL  
ABOUT  $\bar{e}$   
SECTION TOWARD  
BLIND END


5/8 x 1/2 SLOTS IN  
① TROUGH, & 5/8 HOLES  
IN BARS ⑤ & ⑥ FOR  
⑦ ANCHORS - 5 PLACES

ON BLIND  
END

REQUEST DEVIATION SEE  
ATTACHED LETTER

DIMENSION TABLE

"W"	12	18	24	30
"R"	6	9	10 1/2	15
"A"	4	6	8	8
"B"	2	3	4	7
"C"	3 1/2	6 1/2	9	12
"D"	2 1/2	5	7	9
"E"	9	15	20	26
"F"	7	12	16	20



GROUTING RIB SECTION

SIDE ELEVATION

SPECIFY FOR EACH PROJECT

WIDTH "W" = 18" QUANTITY OF TROUGHS - 12  
 HEIGHT "H" = 19" SPACES "S" - 5  
 LENGTH "L" = 18'-8" COLOR - WHITE

ADAPTED TO CAMP LEJEUNE, N.C. ORIGINAL: MAY, '67 REVISION DESCRIPTION REDRAWN APR. 29 '83 - PEP APR. 23 '85 - PEP

REV. W.O. R.N. D.P. AUTHORIZATION MODEL NO. SCALE REF. DWG. DATE BY

FIBERGLASS WASH TROUGHS FOR HARRI PEPPER ASSOC. CAMP LEJEUNE, N.C. WTP 24151-1

WARMINSTER FIBERGLASS CO. A SUBSIDIARY OF FISCHER & PORTER COUNTY LINE RD., SOUTHAMPTON, PA. 17050



Hent

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**

LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO. 81-C-1644	TRANSMITTAL NO. 65	DATE 6-17-85
---------------------------	-----------------------	-----------------

FROM CONTRACTOR  
**Harry Pepper & Associates, Inc.**  
 TO  
**Henry Von Oesen & Associates, Inc.**

PROJECT TITLE AND LOCATION  
**Holcomb Blvd Water Treatment Plant**  
**MCB, Cp Lejeune, North Carolina**

**CONTRACTOR USE ONLY**

**REVIEWER USE ONLY**

\*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

- Contractor Approved       OICC Approval       Deviation/Substitution For OICC Approval

- \*\*ACTION CODES**  
 A-Approved  
 D-Disapproved  
 AN-Approved as noted  
 RA-Receipt acknowledged.  
 C-Comments  
 R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1	6.1	Manufacturer's Data on Water Softener System Bukletin # 5852 <i>SPIRATOR</i>	4	RA	<i>JMB</i>

CONTRACTOR'S COMMENTS

See Transmittal # 16, dated 4-2-85 on Shop Drawings on Spiractor.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC  
**ONE COPY TO ROICC**

CONTRACTOR REPRESENTATIVE (Signature)  
*Phil Reese*

DATE RECEIVED BY REVIEWER: *6/18/85*      FROM (Reviewer): **Henry von Oesen & Assoc., Inc.**      TO:

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.

REVIEWER'S COMMENTS

Contractor's approval appears to be appropriate.

**HENRY VON OESEN AND ASSOCIATES, INC.**  
Consulting Engineers & Planners

COPIES TO: ROICC (2) LANTDIV (1) A-E (1)	DATE <i>6/18/85</i>	SIGNATURE <i>Phil Reese</i>
---	------------------------	--------------------------------

STATE OF CALIFORNIA  
COUNTY OF LOS ANGELES  
IN SENATE  
January 12, 1954  
REPORT OF THE  
COMMISSIONERS OF THE  
STATE BOARD OF CONTROL  
ON THE  
REVENUE ACCOUNTS FOR THE YEAR  
ENDING DECEMBER 31, 1953

*Handwritten signature*

STATE OF CALIFORNIA  
COUNTY OF LOS ANGELES  
IN SENATE  
January 12, 1954  
REPORT OF THE  
COMMISSIONERS OF THE  
STATE BOARD OF CONTROL  
ON THE  
REVENUE ACCOUNTS FOR THE YEAR  
ENDING DECEMBER 31, 1953

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

*Roicc Hunt*

CONTRACT NO 81-C-1644	TRANSMITTAL NO 115-A	DATE 6-24-86
--------------------------	-------------------------	-----------------

FROM CONTRACTOR  
Harry Pepper & Associates, Inc.  
TO  
Henry Von Oesen & Associates, Inc.

PROJECT TITLE AND LOCATION  
Holcomb Blvd Water Treatment Plant  
MCB, Cp Lejeune, North Carolina

CONTRACTOR USE ONLY				REVIEWER USE ONLY	
*List only one specification division per form.				**ACTION CODES	
List only one of the following categories on each transmittal form, and indicate which is being submitted				A-Approved D-Disapproved AN-Approved as noted RA-Receipt acknowledged C-Comments R-Resubmit	
<input type="checkbox"/> Contractor Approved		<input type="checkbox"/> OICC Approval		<input checked="" type="checkbox"/> Deviation/Substitution For OICC Approval	
ITEM NO	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES	REVIEWER'S INITIALS CODE AND DATE
	11336	WATER TREATMENT EQUIPMENT			
1	6.5	Letter from Combs and Associates to Harry Pepper and Associates, Inc.	7	RA	ccs 405 7/9/86
2	6.5	Shop Drawings	7	R	" "
3	6.5	Manufacturer's Data and Shop Drawings on Glass-Ball Valves	7	A	" "

CONTRACTOR'S COMMENTS

If this proposed Deviation is approved, there will be no additional cost to the Government, and any changes caused by this Deviation will be at the expense of the Contractor.

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC  
ONE COPY TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)  
Phil Reese *Phil Reese*

DATE RECEIVED BY REVIEWER: 6/30/86 FROM (Reviewer): *Bm* TO: *distr*

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS

*Item # 1 - RA*

*# 2 - resubmit, indicate material to be used for flexible hose. Rubber hose is not acceptable for acid resistance. Proposed diffuser is acceptable.*

*# 3 - approved at no addnl time or cost.*

COPIES TO ROICC (2) LANTDIV (1) A-E (1)

DATE: 7/10/86

SIGNATURE: *Bill Mawyer*

14 JUL 1986 14 00

Item #1

COMBS & ASSOCIATES, INC.

POST OFFICE BOX 32185 · CHARLOTTE, NORTH CAROLINA 28232-2185

(704) 376-0450

June 17, 1986

Harry Pepper & Associates, Inc.  
Attention: Mr. Jim Schock  
P.O. Box 3007  
Jacksonville, Florida 32206

Re: Acid Diffuser

Dear Jim:

Attached you will find the diffuser which we must specially fabricate for the acid diffuser on the Holcomb Boulevard project.

Felker Brothers Corporation is a specialty stainless steel fabricator who will be fabricating this unit for us. Lab-Crest manufactures the ball valve which is all glass with teflon seats.

Please note that we are using a 1" 316L stainless steel schedule 40 pipe inside of a 1-1/2" 316L stainless steel pipe.

Basically you will use rubber hose to connect to the diffuser to the main stainless steel feed line. If the owner would like to remove this unit, the unit will be unbolted from the right hand side of the page and the 1" stub will be pulled from the 1-1/2" pipe. The flexible hose will be necessary in order to disconnect the unit and put it out of the way.

Washers on the inside will guide the tube in and out. It would not appear that there is a standard diffuser available in the market. The unit is quite expensive to build, and I can not see the Navy or the engineer turning down this particular unit. Would you please submit it and return it to me as quickly as possible?

Thanks for your help in this matter.

Very truly yours,

*A.R. Combs*  
A.R. "Tony" Combs, P.E.  
Charlotte Office  
Combs & Associates, Inc.

enclosures

cc: Mr. John Muter

ARC/bl

It is hereby certified that the (material) (equipment) shown and marked in this submittal, shop drawings, catalog cut(s), etc., and approved/proposed to be incorporated into Contract Number N62470-81-C-1644 is in compliance with the Contract Drawings and Specifications and can be installed in the allocated space, and is:



Approved for use.

Submitted for Government approval.

Approved for use subject to Government approval of specific deviation.

Authorized Reviewer \_\_\_\_\_ DATE \_\_\_\_\_

Signature CQC Rep. Ph. J. Reese DATE 6-24-86



ITEM # 2



**GLASS-BALL VALVES**


**(Lab-Crest)**

The rugged Lab-Crest Glass Ball Valve combines inert wetted parts of borosilicate glass, ceramic alumina, and fluorocarbons to assure resistance to practically every corrosive chemical. The flow direction can be repeatedly reversed without affecting the leak-proof operation of the valve. The transparent, highly polished glass ball and fusion-fabricated tempered-glass body permits ready visual inspection for color, clarity and direction of flow. These parts are resistant to media build-up, and will not contaminate the flowing fluid. All parts are highly resistant to thermal shock.


Considerably longer trouble-free service is achieved by using the Lab-Crest Glass Ball Valve than with many corrosion-resistant metal and plastic valves. Virtually indestructible under compressive load, these valves offer unusually long cycle life, thus solving the problem of replacing TFE components used in diaphragm valves, and assuring quick and positive shut-off characteristics not found in other types of glass or ceramic valves.

**Design Features**

- Thermal shock resistance
- Wetted parts inert to most chemicals
- Non-contaminant glass surfaces
- Glass body—serves as sight glass
- Pneumatic and electronic operators available



Glass-ball valve with manual operator.



Glass-to-metal mounting (ANSI Flanges)

**Engineering Specifications**

**Sizes and Pressure Ratings**


Size	3/4"	1"	1-1/2"	2"	3"
Pressure Rating	150 psi		100 psi		50 psi

**Materials:**

Flanges—Aluminum, carbon steel or stainless steels; PVC coating optional, on carbon steel.  
 Body—Borosilicate glass; Fiberglass armor optionally available, for external shock resistance.  
 Other wetted parts—Ceramic aluminum and TFE.

**Mounting Methods:**

150-lb ANSI metal flanges (built-in TFE envelope makes gasket unnecessary).  
 Flanged glass piping.  
 Wall, column or support bracket.



Glass-to-glass mounting (cast-iron Flanges)

ATLANTIC DIVISION  
NAVAL FACILITIES ENGINEERING COMMAND  
NORFOLK, VIRGINIA 23511-6287

APPROVED  Item #3 only  
APPROVED AS NOTED \_\_\_\_\_  
DISAPPROVED \_\_\_\_\_  
SUBJECT TO THE REQUIREMENTS OF

CONTRACT NO. \_\_\_\_\_  
APPROVAL OF A SUBMITTAL DOES NOT INCLUDE  
APPROVAL OF ANY DEVIATION FROM THE CON-  
TRACT REQUIREMENTS UNLESS THE CONTRACTOR  
CALLS ATTENTION TO AND SUPPORTS THE DEVI-  
ATION—THE CONTRACTOR SHALL BE RESPONSIBLE  
FOR PROVIDING PROPER PHYSICAL DIMENSIONS  
& WEIGHTS, COORDINATION OF TRADES, ETC., AS  
REQUIRED.

REVIEWER CCS DATE 7/9/86  
FOR OFFICER IN CHARGE OF CONSTRUCTION