

THIS ORDER HAS BEEN
SHORT-SHIPED

MATERIAL NOT SHIPPED HAS
BEEN PLACED ON A BACK ORDER
SCHEDULED FOR 10-9-62

WALLACE & TIERNAN

FORM 2820

ORDER HAS BEEN
SHORT-TERMINED
MATERIAL NOT SHIPPED HAS
BEEN PLACED ON A BACKORDER
SCHEDULED FOR
WALLACE THOMAS

WALLACE & TIERNAN INC.

25 MAIN STREET, BELLEVILLE, NEW JERSEY

TELEPHONE: PLYMOUTH 9-8000 • CABLE ADDRESS: WALTIERNAN NEWARK • TWX BELLEVILLE 220

JOB NUMBER

PROD. CODE & DIVISION

DF 4

JOB **CAMP LE JEUNE CAMP LE JEUNE, NORTH CAROLINA** THE SCHEDULE DATE **9/14/62(683)**

ORDER ENTRD ON **8/17/62** AUTH. FOR ORDER **N67001-7023 DTD 6/15/62** APPROVED BY **KEMPER** TYPED BY **BD** O. D. BILLED

ROUTING & SHIPPING DEPT. INFO. **MOTOR FRT. PREPAID**



SHIP TO **FREIGHT TRAFFIC BRANCH N67001-7023 BLDG. NO. 1011**

CITY **CAMP LE JEUNE,** STATE **NORTH CAROLINA**

MARKS **FREIGHT TRAFFIC N67001-7023 BLDG. NO 1011**

REMARKS

NOTICE TO CONSIGNEE

SHORT SHIPMENTS
Items 8, 9, and 10

This order has been triple-checked, both as to contents and condition of same. Shortages or breakage should be reported at once to Express or Freight Agent, securing notation on express receipt or bill of lading as to damages, so that you can enter claim.

| ITEM | QUAN. | ✓ | MATERIAL | DWG. NO. | ✓ | Packed in Box No. |
|------|-------|---|---|---|---|-------------------|
| 1 | ONE | | VOLUMETRIC DRY CHEMICAL FEEDER FOR SODIUM FLUORIDE DENSITY 70 LBS CU. FT. FEED RATE 0.6 TO 12 LBS/HR WITH HOPPER AGITATION 1" DIA. 1" STROKE FEED SCREW 1/4HP 115V 1 PH 60CY TE MOTOR PULLEY RATIO 1 TO 7 WITH 35 GAL SOLUTION TANK & FLOAT VALVE SERIAL# *TAG: CONTRACT NO. N67001-7023" | (A690521) (UXM19012) (U19918) (P41150) (DRIVE U) (P40440) (DRIVEN) (CP39095) (U19217) | | D.B. 19620 |
| 2 | ONE | | CAN OIL | U10198 | | |
| 3 | FIVE | | SET INSTRUCTIONS A690 | WIA-690-1-3 | | |
| 4 | ONE | | 35 GAL. JET AGITATED FIBREGLOSS SOL. CHAMBER | (U19676) (U19261) | | |
| 5 | ONE | | SET ACCESSORIES 1000# SCALE MOUNTED FEEDER | AF810 | | |
| 6 | ONE | | FLEXIBLE CONNECTION | U13312 | | |
| 7 | ONE | | A-B MAGNETIC STARTER CAT#709AADE WITH NEMA 1 ENCLOSURE HAND-OFF -AUTO SWITCH PAIR OF N-23 HEATER ELEMENT TO OPERATE 1/4HP 115V 1 PH 60CY 1750 RPM MOTOR F.L. CURRENT 4.60 AMPS OPERATING COIL 115V60CY FOR USE WITH FEEDER | (UXH18822) (UXC18826) | | |
| 8 | ONE | | COVER FOR A690 SHIP WITH ORD/24002-BG | XP 9383 | | |
| 9 | ONE | | 24" X 22" CONV. HOPPER | XU77251 | | |
| 10 | ONE | | 6" SQ. EXT. HOPPER | UXB186P7 | | |

