

11800
BOSM

FEB 10 1987

From: Assistant Chief of Staff, Base Operational Support
Management Assistance
To: Donald R. Gurganus, Base Maintenance Division
Via: (1) Assistant Chief of Staff, Facilities *AWC 2/11/87*
→ (2) Base Maintenance Officer

Subj: MODEL INSTALLATION PROGRAM PROPOSAL

Encl: (1) MIP #87-CLNC-045-FAC, Hydrostatic Testing of Unfired
Pressure Vessels

1. This office is in receipt of your submission to the Model Installation Program, and has assigned it the number identified in the enclosure. The proposal is currently being staffed and processed. You will be notified as soon as a decision has been made.

2. We appreciate your participation in the Model Installation Program and ask for your continued support. Good ideas will make the Camp Lejeune community a better place to work and live.

H. F. SMITH

FEB 10 1987

ENC 21187





MODEL INSTALLATION PROGRAM

PROPOSAL

MARINE CORPS BASE
CAMP LEJEUNE



INSTRUCTIONS:

1. COMPLETE ALL INFORMATION REQUESTED.
2. PLEASE PRINT OR TYPE LEGIBLY.
3. USE ADDITIONAL SHEETS IF NECESSARY.
4. FORWARD COMPLETED PROPOSAL TO AC/S, BOSMAD, MCB

DO NOT WRITE IN THIS SPACE

DATE RECEIVED

3 Feb 87

TITLE OR SUBJECT OF PROPOSAL

Hydrostatic Testing of Unfired Pressure Vessels

PROPOSAL NUMBER

87-CLNC-045-FAC

NAME, TITLE, GRADE/RANK, UNIT OF SUBMITTER(S)

Donald R. Gurganus, Transportation General Foreman, WS-13,
Heavy Equipment Unit

PHONE

451-5909

CURRENT PROCEDURE

Unfired Pressure Vessels, Air Compressors, are inspected on Marine Corps Base and New River Air Station in accordance with NAVFAC MO-324. They also have been and are hydrostatic tested at regular frequencies. The majority of this equipment has a working pressure from 15-250 psi.

PROPOSED PROCEDURE (If a directive/order must be waived to implement proposal-Identify the specific reference.)

Request a waiver of NAVFAC MO-324 and abide by regulations as set forth in OSHA Safety and Health Standards, 29 CFR 1910, General Industry, Revised 11 March 1983, section 1910.169.

BENEFITS/ADVANTAGES

Benefits and advantages would not require the internal nor the hydrostatic test. There are a minimum of 104 Air Receivers located on Marine Corps Base and New River Air Station. Significant amount of time is required to disassemble the plumbing, fill with water and to test these Air Receivers internally and hydrostatically. After the test has been conducted the plumbing has to be reconnected for use. This procedure in the past has required the assistance of the Tester/Inspector, Plumber, and an Electrician. While this test is in progress the using unit is unable to use the equipment until the test has been completed.

I (WE) UNDERSTAND THAT THE ACCEPTANCE OF A CASH AWARD FOR THE USE OF THIS PROPOSAL BY THE UNITED STATES GOVERNMENT SHALL NOT FORM THE BASIS OF A FURTHER CLAIM OF ANY NATURE UPON THE UNITED STATES BY ME (US), MY (OUR) HEIRS, OR ASSIGNS.

Donald R. Gurganus 2-2-87
(SIGNATURE AND DATE)


(SIGNATURE AND DATE)

MODEL INSTALLATION PROPOSAL

MCBCL 11800

ENCL (1)

Excellent Installations — The Foundation Of Defense



Memorandum

DATE: 04 MAR 1987

11800
MAIN

FROM: Thomas Lanier, P&E Section

TO: Director, Operations Branch

SUBJ: MIP #87-CLNC-045-FAC, HYDROSTATIC TESTING OF UNFIRED PRESSURE VESSELS

1. The Model Installation Proposal No. 87-CLNC-045-FAC covering hydrostatic testing of Unfired Pressure Vessels is addressed in the following paragraphs.

a. Unfired Pressure Vessels are potentially dangerous vessels and the procedures for inspection come under NAVFAC MO-324, December 1984, updated June 1986. Exception to these requirements will not be made without the formal concurrence of the NAVFACENGCOM Boiler Inspection Certification Board as per NAVFAC MO-324 Page 1-1.

b. The majority of air receivers have small openings (usually 1 1/2" pipe size or less) for internal inspection. Trying to determine the amount of corrosion and pitting inside the tank is poor at best. I believe that a hydrostatic test every few years is the best way to safely say a tank is good for a specific working pressure. Most of the Unfired Pressure Vessels on Marine Corps Base Camp Lejeune and New River Air station operate at a pressure between 100-175 PSI. I recommend that the testing procedure for Unfired Pressure Vessels not be changed.

c. Being the Inspector of boilers and Unfired Pressure Vessels, I feel better about issuing a certificate to operate the unit if I have the option to hydrostatically test at my discretion.

T. L. Lanier
T. L. LANIER

Thomas Lanier, 1st Section

Director, Operations Branch

MIR 045-CLIC 045 FAC, HYDROSTATIC TESTING OF UNFURRED PRESSURE VESSELS

1. The Model Installation Proposal No. B7-CLIC-045-FAC covering hydrostatic testing of Unfurred Pressure Vessels is addressed in the following paragraphs.

2. Unfurred Pressure Vessels are potentially dangerous vessels and the procedure for inspection comes under NAVAF 045-324, December 1984, updated June 1985. Exception to these requirements will not be made without the formal consent of the Navy Academy of Naval Inspection Certification Board at NAVAF 045-324 Page 1-1.

3. The majority of air receivers have small openings (usually 1/2" pipe size or less) for internal inspection. Trying to determine the amount of corrosion and pitting inside the tank is poor practice. I believe that a hydrostatic test every five years is the best way to safely say a tank is good for a specific working pressure. Most of the Unfurred Pressure Vessels on Marine Corps Base Camp Lejeune and New River Air Station operate at a pressure between 100-175 PSI. I recommend that the testing procedure for Unfurred Pressure Vessels not be changed.

4. Being the Inspector of Ballast and Unfurred Pressure Vessels, I feel better about issuing a certificate to operate the vessel if I have the vessel hydrostatically tested at my discretion.

T. L. LANIER

Memorandum

11800
FAC

DATE: FEB 19 1987

FROM: Assistant Chief of Staff, Facilities, Marine Corps Base, Camp
Lejeune
TO: Base Maintenance Officer

SUBJ: MODEL INSTALLATION PROGRAM PROPOSALS

Ref: (a) AC/S BOSMAD memo 11800 BOSM dtd 10 Feb 87

Encl: (1) MIP #87-CLNC-045-FAC; Hydrostatic Testing of Unfired
Pressure Vessels
(2) MIP #87-CLNC-046-FAC; Reducing Water Pressure in Family
Housing

1. Please review the enclosed MIP proposals in accordance with established procedures and reference (a). Response is requested by 6 March 1987.


K. J. KIRIACOPOULOS
By direction

11000
170

11000

MEMORANDUM FOR THE CHIEF OF BUREAU OF INVESTIGATION, FEDERAL BUREAU OF INVESTIGATION
FROM: SAC, [illegible]

FOOT PRINTS OF [illegible]

TO: SAC, [illegible]

- (1) [illegible]
- (2) [illegible]

It is requested that you advise this office of any leads developed in connection with the above information.

Very truly yours,
[illegible]

11800
BOSM

FEB 10 1987


MEMORANDUM

From: Assistant Chief of Staff, Base Operational Support
Management Assistance
To: Assistant Chief of Staff, Facilities
Subj: MODEL INSTALLATION PROGRAM PROPOSAL

Encl: (1) MIP #87-CLNC-045-FAC, Hydrostatic Testing of Unfired
Pressure Vessels
(2) MIP #87-CLNC-046-FAC, Reducing Water Pressure in
Family Housing

1. Enclosures (1) and (2) are forwarded for review and comment. Request recommendation for approval or disapproval be returned to this office with an excerpt from the applicable directive within ten working days from date of receipt. Recommendation for disapproval should be accompanied by a written rationale.
2. This office will forward proposals recommended for approval directly to the Commanding General for decision. Proposals recommended for disapproval will be reviewed by the Model Installation Steering Committee prior to forwarding to the Commanding General.
3. It is recommended that any other Marine Corps Base department that may be affected by the approval or disapproval of the enclosed proposals be contacted during your review.
4. BOSMAD POC is D. Martin, 5521/1577.


H. F. SMITH



[The following text is extremely faint and largely illegible. It appears to be a series of lines of text, possibly a letter or a report, but the characters are too light to transcribe accurately.]



MODEL INSTALLATION PROGRAM

PROPOSAL

MARINE CORPS BASE CAMP LEJEUNE

**INSTRUCTIONS:**

1. COMPLETE ALL INFORMATION REQUESTED.
2. PLEASE PRINT OR TYPE LEGIBLY.
3. USE ADDITIONAL SHEETS IF NECESSARY.
4. FORWARD COMPLETED PROPOSAL TO AC/S, BOSMAD, MCB

DO NOT WRITE IN THIS SPACE

DATE RECEIVED

3 Feb 87

TITLE OR SUBJECT OF PROPOSAL

Hydrostatic Testing of Unfired Pressure Vessels

PROPOSAL NUMBER

87-CLNC-045-FAC

NAME, TITLE, GRADE/RANK, UNIT OF SUBMITTER(S)Donald R. Gurganus, Transportation General Foreman, WS-13,
Heavy Equipment Unit

PHONE

451-5909

CURRENT PROCEDURE

Unfired Pressure Vessels, Air Compressors, are inspected on Marine Corps Base and New River Air Station in accordance with NAVFAC MO-324. They also have been and are hydrostatic tested at regular frequencies. The majority of this equipment has a working pressure from 15-250 psi.

PROPOSED PROCEDURE (If a directive/order must be waived to implement proposal-Identify the specific reference.)

Request a waiver of NAVFAC MO-324 and abide by regulations as set forth in OSHA Safety and Health Standards, 29 CFR 1910, General Industry, Revised 11 March 1983, section 1910.169.

BENEFITS/ADVANTAGES

Benefits and advantages would not require the internal nor the hydrostatic test. There are a minimum of 104 Air Receivers located on Marine Corps Base and New River Air Station. Significant amount of time is required to disassemble the plumbing, fill with water and to test these Air Receivers internally and hydrostatically. After the test has been conducted the plumbing has to be reconnected for use. This procedure in the past has required the assistance of the Tester/Inspector, Plumber, and an Electrician. While this test is in progress the using unit is unable to use the equipment until the test has been completed.

I (WE) UNDERSTAND THAT THE ACCEPTANCE OF A CASH AWARD FOR THE USE OF THIS PROPOSAL BY THE UNITED STATES GOVERNMENT SHALL NOT FORM THE BASIS OF A FURTHER CLAIM OF ANY NATURE UPON THE UNITED STATES BY ME (US), MY (OUR) HEIRS, OR ASSIGNS.

Donald R. Gurganus 2-2-87
(SIGNATURE AND DATE)

(SIGNATURE AND DATE)

MODEL INSTALLATION PROPOSAL

MCBCL 11800

Excellent Installations — The Foundation Of Defense

ENCL (1)

Handwritten marks or scribbles in the top right corner.

A small, faint handwritten mark or scribble on the left side of the page.

11 MAR 1987

11800
MAIN

Base Maintenance Officer, Marine Corps Base, Camp Lejeune
Assistant Chief of Staff, Facilities, Marine Corps Base

MIP 87-CLNC-045-FAC

1. The heart of the problem is NAVFAC MO-324 that requires an internal inspection of unfired pressure vessels (UPV) not less than once every two years for any tank that has an operating pressure in excess of 15 PSI or a volume of more than five cubic feet. Many of the air compressors aboard Camp Lejeune fall into that requirement but have no openings sufficiently large enough to conduct an internal inspection. Accordingly, NAVFAC MO-325 states a hydrostatic pressure test (fill up with water and pressurize at 1.5 times the maximum working pressure) may be substituted for internal inspection. Hence, we are required to hydrostatically test these unfired pressure vessels because of no means to inspect internally. We concur with the MIP that this is an unnecessary frequency and unnecessary work.

2. It is suggested that the MIP be forwarded to NAVFACENCOM via our Engineering Field Division (LANTDIV) for review to determine the following:

a. Are there satisfactory techniques for conducting internal inspections on UPV's that have very limited internal access?

b. Can the minimum thresholds (five cubic feet & 15 PSI) for UPV inspection requirements be adjusted upward?

c. Can UPV's in non-utility type applications be completely exempt from inspections? This would typically be shop type air compressors.

3. We feel the MIP has merit, but requires relief from existing Department of Navy directives, specifically NAVFAC MO-324. It is recommended relief be pursued.

C. G. POWELL

Blind copy to:
Dir, Ops
T. Lanier, P&E
D. Gurganus, M&R
MIP Files

Writer: C. Powell, MAIN, X2511
Typist: S. Schmitz, 09 Mar 87

Memorandum

11800
FAC

DATE: FEB 19 1987

FROM: Assistant Chief of Staff, Facilities, Marine Corps Base, Camp
Lejeune
TO: Base Maintenance Officer


SUBJ: MODEL INSTALLATION PROGRAM PROPOSALS

Ref: (a) AC/S BOSMAD memo 11800 BOSM dtd 10 Feb 87

Encl: (1) MIP #87-CLNC-045-FAC; Hydrostatic Testing of Unfired
Pressure Vessels
(2) MIP #87-CLNC-046-FAC; Reducing Water Pressure in Family
Housing

1. Please review the enclosed MIP proposals in accordance with established procedures and reference (a). Response is requested by 6 March 1987.


K. J. KIRIACOPOULOS
By direction



11800
BOSM

FEB 10 1987

MEMORANDUM

From: Assistant Chief of Staff, Base Operational Support
Management Assistance

To: Assistant Chief of Staff, Facilities

Subj: MODEL INSTALLATION PROGRAM PROPOSAL


Encl: (1) MIP #87-CLNC-045-FAC, Hydrostatic Testing of Unfired
Pressure Vessels
(2) MIP #87-CLNC-046-FAC, Reducing Water Pressure in
Family Housing

1. Enclosures (1) and (2) are forwarded for review and comment. Request recommendation for approval or disapproval be returned to this office with an excerpt from the applicable directive within ten working days from date of receipt. Recommendation for disapproval should be accompanied by a written rationale.


2. This office will forward proposals recommended for approval directly to the Commanding General for decision. Proposals recommended for disapproval will be reviewed by the Model Installation Steering Committee prior to forwarding to the Commanding General.

3. It is recommended that any other Marine Corps Base department that may be affected by the approval or disapproval of the enclosed proposals be contacted during your review.

4. BOSMAD POC is D. Martin, 5521/1577.



H. F. SMITH





MODEL INSTALLATION PROGRAM



PROPOSAL
MARINE CORPS BASE
CAMP LEJEUNE

INSTRUCTIONS:

1. COMPLETE ALL INFORMATION REQUESTED.
2. PLEASE PRINT OR TYPE LEGIBLY.
3. USE ADDITIONAL SHEETS IF NECESSARY.
4. FORWARD COMPLETED PROPOSAL TO AC/S, BOSMAD, MCB

DO NOT WRITE IN THIS SPACE

DATE RECEIVED

3 Feb 87

TITLE OR SUBJECT OF PROPOSAL

PROPOSAL NUMBER

Hydrostatic Testing of Unfired Pressure Vessels

87-CLNC-045-FAC

NAME, TITLE, GRADE/RANK, UNIT OF SUBMITTER(S)

PHONE

Donald R. Gurganus, Transportation General Foreman, WS-13,
Heavy Equipment Unit

451-5909

CURRENT PROCEDURE

Unfired Pressure Vessels, Air Compressors, are inspected on Marine Corps Base and New River Air Station in accordance with NAVFAC MO-324. They also have been and are hydrostatic tested at regular frequencies. The majority of this equipment has a working pressure from 15-250 psi.

PROPOSED PROCEDURE (If a directive/order must be waived to implement proposal-Identify the specific reference.)

Request a waiver of NAVFAC MO-324 and abide by regulations as set forth in OSHA Safety and Health Standards, 29 CFR 1910, General Industry, Revised 11 March 1983, section 1910.169.

BENEFITS/ADVANTAGES

Benefits and advantages would not require the internal nor the hydrostatic test. There are a minimum of 104 Air Receivers located on Marine Corps Base and New River Air Station. Significant amount of time is required to disassemble the plumbing, fill with water and to test these Air Receivers internally and hydrostatically. After the test has been conducted the plumbing has to be reconnected for use. This procedure in the past has required the assistance of the Tester/Inspector, Plumber, and an Electrician. While this test is in progress the using unit is unable to use the equipment until the test has been completed.

I (WE) UNDERSTAND THAT THE ACCEPTANCE OF A CASH AWARD FOR THE USE OF THIS PROPOSAL BY THE UNITED STATES GOVERNMENT SHALL NOT FORM THE BASIS OF A FURTHER CLAIM OF ANY NATURE UPON THE UNITED STATES BY ME (US), MY (OUR) HEIRS. OR ASSIGNS.

Donald R. Gurganus 2-2-87
(SIGNATURE AND DATE)


(SIGNATURE AND DATE)

MODEL INSTALLATION PROPOSAL

MCBCL 11800

Excellent Installations — The Foundation Of Defense

ENCL (1)



22 OCT 1987

11800
MAIN

Deputy Base Maintenance Officer

Assistant Chief of Staff, Facilities

MIP PROPOSAL 87-CLNC-045-FAC, HYDROSTATIC TESTING OF
UNFIRED PRESSURE VESSELS

Ref: (a) Your memo 11800 FAC of 15 Oct 87

Encl: (1) BMO memo 11800 MAIN of 11 Mar 87

1. The reference requested review and comments on the subject MIP. This MIP has already undergone review and comments were forwarded by memo on 11 March of this year. A copy of that memo is provided as the enclosure.

C. G. POWELL

WRITER: C. G. POWELL, X2511
TYPIST: C. KOWALSKI, 21 OCT 87

UNITED STATES DEPARTMENT OF JUSTICE

INVESTIGATION OF THE ACTS OF VIOLENCE
COMMITTED BY THE ORGANIZATION OF
BLACK PANTHER PARTY

MEMORANDUM FOR THE DIRECTOR

DATE: 10/15/68

1. The Bureau has received information that the
Organization of Black Panther Party (OBPP) has
been active in the area of [redacted] and
has been involved in the activities of [redacted].

Very truly yours,
[Signature]

UNITED STATES DEPARTMENT OF JUSTICE

Beneficial Suggestion No. 40-87 - Install Intercom on Lower Deck, Bldg. 1700

EVALUATION GUIDE FOR SAFETY IMPROVEMENTS

		EVALUATION POINTS				SCORE	
1. LIKELIHOOD OF ACCIDENT BEFORE IMPROVEMENT WAS INSTALLED:							
(a) Exposure frequency	0	Slight	3	Appreciable	6 X	Considerable	9 7
(b) No. employees exposed	0	Less than 5	3	5 to 25	6 X	Over 25	9 7
(c) Possibility of accident	0	Unlikely	3	Probable	6 X	Very likely	9 7
2. EXTENT OF APPLICATION:		0	9	18			27
(a) Number of locations or area covered		One or two machines, tools, or operations in one shop or office X		A group of machines, tools, or operations in a shop or office		General application throughout a large activity	2
3. DEGREE OF HAZARD:		0	9	18			27
(a) Extent of possible injury and/or damage to property		Minor defects or lack of safeguards that may cause non-disabling injury and/or slight damage to property		Major defects or lack of safeguards that may cause disabling injuries and/or heavy damage to property X		Extreme defects or lack of safeguards that may cause a permanent injury or fatality and/or extensive damage to property	10
4. EFFECTIVENESS OF IMPROVEMENT:		0	9	18			27
(a) To what extent will the improvement reduce the possibility of an accident?		Minimizes the hazard slightly		Appreciably limits the hazard or the effects of the hazard X		Eliminates the hazard, or possibility of disabling injury, or damage to property	10
						TOTAL SCORE	43

Encl (11)

1870
1871
1872
1873
1874
1875
1876
1877
1878
1879
1880

11 MAR 1987

11800
MAIN

Base Maintenance Officer, Marine Corps Base, Camp Lejeune
Assistant Chief of Staff, Facilities, Marine Corps Base

MIP 87-CLNC-045-FAC

1. The heart of the problem is NAVFAC MO-324 that requires an internal inspection of unfired pressure vessels (UPV) not less than once every two years for any tank that has an operating pressure in excess of 15 PSI or a volume of more than five cubic feet. Many of the air compressors aboard Camp Lejeune fall into that requirement but have no openings sufficiently large enough to conduct an internal inspection. Accordingly, NAVFAC MO-325 states a hydrostatic pressure test (fill up with water and pressurize at 1.5 times the maximum working pressure) may be substituted for internal inspection. Hence, we are required to hydrostatically test these unfired pressure vessels because of no means to inspect internally. We concur with the MIP that this is an unnecessary frequency and unnecessary work.

2. It is suggested that the MIP be forwarded to NAVFACENGCOM via our Engineering Field Division (LANTDIV) for review to determine the following:

a. Are there satisfactory techniques for conducting internal inspections on UPV's that have very limited internal access?

b. Can the minimum thresholds (five cubic feet & 15 PSI) for UPV inspection requirements be adjusted upward?

c. Can UPV's in non-utility type applications be completely exempt from inspections? This would typically be shop type air compressors.


3. We feel the MIP has merit, but requires relief from existing Department of Navy directives, specifically NAVFAC MO-324. It is recommended relief be pursued.

C. G. POWELL

Blind copy to:
Dir, Ops
T. Lanier, P&E
D. Gurganus, M&R
MIP Files

Encl (/)

Writer: C. Powell, MAIN, X2511
Typist: S. Schmitz, 09 Mar 87



ROUTING SLIP

16 OCT 1987

ACTION

INFO

INITIAL

BMO

✓

DBMO

✓

CP 10/18

DIR, ADMIN

DIR, OPS

DIR, M&R

DIR, UTIL

SECRETARY


COMMENTS:

? CP 10/18

*Carroll
Havent we
replied already*

Suspense

30 Oct



Memorandum

11800

FAC

DATE: OCT 15 1987


FROM: Assistant Chief of Staff, Facilities, Marine Corps Base, Camp
Lejeune
TO: Base Maintenance Officer

SUBJ: MIP PROPOSAL NO. 87-CLNC-045-FAC, HYDROSTATIC TESTING OF
UNFIRED PRESSURE VESSELS

Encl: (1) Subject Proposal

1. The enclosure is forwarded for review and comment. Comments will include a recommendation for approval or disapproval. Recommendations for disapproval must be accompanied by written rationale.

2. Please return comments to this office NLT 30 October 1987.


K. J. KIRIACOPOULOS
By direction

1987
100

OCT 1 2 1987

Regional Office of Health, Education and Welfare
Regional
Public Health Service

VIA REGISTERED MAIL - RETURN RECEIPT REQUESTED
MAILING LABELS ATTACHED

Enclosure (1) - Subject: [illegible]

The enclosed is forwarded for review and comment.
Comments will include a recommendation for approval or
disapproval, and recommendations for improvement, to be
accompanied by written rationale.

Please return comments to this office by [illegible] 1987.

[illegible]
[illegible]



MODEL INSTALLATION PROGRAM

PROPOSAL

MARINE CORPS BASE CAMP LEJEUNE

**INSTRUCTIONS:**

1. COMPLETE ALL INFORMATION REQUESTED.
2. PLEASE PRINT OR TYPE LEGIBLY.
3. USE ADDITIONAL SHEETS IF NECESSARY.
4. FORWARD COMPLETED PROPOSAL TO AC/S, BOSMAD, MCB

DO NOT WRITE IN THIS SPACE

DATE RECEIVED

3 Feb 87

TITLE OR SUBJECT OF PROPOSAL

Hydrostatic Testing of Unfired Pressure Vessels

PROPOSAL NUMBER

87-CLNC-045-FAC

NAME, TITLE, GRADE/RANK, UNIT OF SUBMITTER(S)

Donald R. Gurganus, Transportation General Foreman, WS-13,
Heavy Equipment Unit

PHONE

451-5909

CURRENT PROCEDURE

Unfired Pressure Vessels, Air Compressors, are inspected on Marine Corps Base and New River Air Station in accordance with NAVFAC MO-324. They also have been and are hydrostatic tested at regular frequencies. The majority of this equipment has a working pressure from 15-250 psi.

PROPOSED PROCEDURE (If a directive/order must be waived to implement proposal-Identify the specific reference.)

Request a waiver of NAVFAC MO-324 and abide by regulations as set forth in OSHA Safety and Health Standards, 29 CFR 1910, General Industry, Revised 11 March 1983, section 1910.169.

BENEFITS/ADVANTAGES

Benefits and advantages would not require the internal nor the hydrostatic test. There are a minimum of 104 Air Receivers located on Marine Corps Base and New River Air Station. Significant amount of time is required to disassemble the plumbing, fill with water and to test these Air Receivers internally and hydrostatically. After the test has been conducted the plumbing has to be reconnected for use. This procedure in the past has required the assistance of the Tester/Inspector, Plumber, and an Electrician. While this test is in progress the using unit is unable to use the equipment until the test has been completed.

UNDERSTAND THAT THE ACCEPTANCE OF A CASH AWARD FOR THE USE OF THIS PROPOSAL BY THE UNITED STATES GOVERNMENT SHALL NOT BE THE BASIS OF A FURTHER CLAIM OF ANY NATURE UPON THE UNITED STATES BY ME (US), MY (OUR) HEIRS, OR ASSIGNS.


Donald R. Gurganus 2-2-87
(SIGNATURE AND DATE)

(SIGNATURE AND DATE)

MODEL INSTALLATION PROPOSAL

MCL 11800

Excellent Installations — The Foundation Of Defense



TS000
87-045

11 MAR 1987

11800
MAIN

Base Maintenance Officer, Marine Corps Base, Camp Lejeune
Assistant Chief of Staff, Facilities, Marine Corps Base

MIP 87-CLNC-045-FAC

1. The heart of the problem is NAVFAC MO-324 that requires an internal inspection of unfired pressure vessels (UPV) not less than once every two years for any tank that has an operating pressure in excess of 15 PSI or a volume of more than five cubic feet. Many of the air compressors aboard Camp Lejeune fall into that requirement but have no openings sufficiently large enough to conduct an internal inspection. Accordingly, NAVFAC MO-325 states a hydrostatic pressure test (fill up with water and pressurize at 1.5 times the maximum working pressure) may be substituted for internal inspection. Hence, we are required to hydrostatically test these unfired pressure vessels because of no means to inspect internally. We concur with the MIP that this is an unnecessary frequency and unnecessary work.

2. It is suggested that the MIP be forwarded to NAVFACENGCOM via our Engineering Field Division (LANTDIV) for review to determine the following:

- a. Are there satisfactory techniques for conducting internal inspections on UPV's that have very limited internal access?
- b. Can the minimum thresholds (five cubic feet & 15 PSI) for UPV inspection requirements be adjusted upward?
- c. Can UPV's in non-utility type applications be completely exempt from inspections? This would typically be shop type air compressors.

3. We feel the MIP has merit, but requires relief from existing Department of Navy directives, specifically NAVFAC MO-324. It is recommended relief be pursued.

C. G. POWELL

Blind copy to:
Dir, Ops
T. Lanier, P&E
D. Gurganus, M&R
MIP Files

Writer: C. Powell, MAIN, X2511
Typist: S. Schmitz, 09 Mar 87

