


- LEGEND**
- BUILDINGS AND STRUCTURES
  - ROADS AND HIGHWAYS
  - ROADS (Unpaved)
  - FENCE
  - 5' CONTOUR (Source - USGS Maps)
  - AIR STATION BOUNDARY
  - SWAMP OR MARSH
  - QUANTITY, SIZE, VOLTAGE (KV-KILOVOLT)(N-NEUTRAL)(MATERIAL COPPER UNLESS NOTED)  
3# 1/0, 12-477.2 KV, #1/0N  
OVERHEAD PRIMARY POLE LINE 3 PHASE UNLESS SINGLE PHASE NOTED.
  - I-B-10  
POLE IDENTIFICATION NUMBER
  - OVERHEAD DISTRIBUTION TRANSFORMER  
3-25 KVA  
QUANTITY, CAPACITY (KVA)
  - FUSED CUTOUT (CLOSED POSITION UNLESS INDICATED BY N.O.)
  - QUANTITY, SIZE, VOLTAGE (KV), INSULATION  
3# 2, 15 KV, XLP  
1/0-4  
MH-3 OF 2 W 4"  
UNDERGROUND PRIMARY LINE, 3 PHASE, UNLESS SINGLE PHASE NOTED  
DUCT WAY AND SIZE (INCHES) (DB-DIRECT BURIED)  
MANHOLE IDENTIFICATION NUMBER
  - PAD MOUNTED TRANSFORMER  
750 KVA-3  
CAPACITY KVA THREE PHASE OR SINGLE PHASE
  - CIRCUIT BREAKER  
1200 A  
RATING AMPS
  - METER
  - GENERATOR  
200 KW  
CAPACITY KILOWATTS



NO.	DESCRIPTION OF REVISION	DATE	INT.

DEPARTMENT OF THE NAVY  
MARINE CORPS BASE  
CAMP LEJEUNE, NORTH CAROLINA

**ELECTRICAL DISTRIBUTION  
EXISTING CONDITIONS**

DATE 31 JULY 84	SCALE: GRAPHIC	SHEET D-3 OF 73
APPROVED / DATE	00000206	

THIS DRAWING HAS BEEN FIELD VERIFIED

