

NREAD/DDS/jc  
6280  
22 May 1984

From: Director  
To: Base Maintenance Officer (Attn: Director, Utilities Division)  
Subj: Storm Water Storage Tank S-1747; modification of  
Ref: (a) On-site Inspection of Pollution Abatement Facilities at Bldg. 1750 on 15 May 1984 by Mr. K. Jolly, NREAD; GySgt Anderson, SSgt Niehoff, and Lt Smith, 2d LAV Bn

1. During the reference it was noted that 2d Light Armored Vehicle (LAV) Battalion equipment will be arriving at Building 1750 starting 1 June 1984. Use of the equipment, as designed, dictates that substantial amounts of grit/sand will be entering the present grit chamber/storm water storage tank facilities. At present, pumps on the floor of the storm water storage tank are not protected from grit/sand entering the tank and resultant blockages which will occur over time.

2. It is recommended that the subject tank be modified in the same manner as the 900 Area wash racks were recently modified. The work involves constructing a masonry block wall around pumps and modifying inlet pipe. Point of contact in this matter is Mr. Ken Jolly, extensions 5003/2083.

J. I. WOCTEN

Copy to:  
S-40ff, 2dLAVBn, 2dMarDiv  
Dir, OpnsDiv, BMO

