

T-6280

NREAD/DDS/jc
6280
17 May 1984

From: Director
To: Assistant Chief of Staff, Facilities

Subj: Pollution Abatement Facilities at Old Hospital Complex;
lack of

Ref: (a) CMC Washington DC R161346Z Sep 1983
(b) On-site Inspection of old Hospital Complex Facilities
on 17 Feb1984 and 23 Apr 1984 by Mr. Ken Jolly, NREAD

1. Reference (a) designated buildings/facilities in the old Hospital complex which were to be retained for use. Reference (b) was conducted to determine the adequacy/lack of existing pollution abatement facilities in the subject area.

2. Based on reference (b), it is recommended that the following action be initiated:

- a. Construct consolidated wash apron/grease rack facilities in the vicinity of Building H-36 (6th WAB MotorT).
- b. Install waste oil tank with funnel at Building H-36.
- c. Construct curbing and containment basin for Filling Station H-114.
- d. Deadline existing wash apron at Building H-18 or correct discrepancies in same (existing wash pad has no oil/water separator. It drains to storm drain system).

3. Point of contact in this matter is Mr. Ken Jolly, telephone 5003/2083.

J. I. WOOTEN



