

T-6280
NREAD/DDS/jc
6240
15 Mar 1984

From: Director
To: Base Maintenance Officer

Subj: 1800 and 900 Area Consolidated Grease Rack and Wash Pad
Facilities; repair of

Ref: (a) Onsite Inspection of 1800 and 900 Area Consolidated
Grease Rack and Wash Pad Facilities on 9 March 1984
by Mr. K. JOLLY, NREAD
(b) BO 11090.3

1. During reference (a) numerous components of the subject facilities were noted to be damaged, missing, or malfunctioning (i.e., missing oil drain funnels, damaged oil drain funnels and/or oil drain piping, broken/damaged water spigots, damaged/missing waste oil tank fuel level indicators, etc.).
2. As provided for in reference (b), it is requested that the subject facilities be inspected and necessary repairs be initiated.
3. Point of contact in this matter is Mr. Ken JOLLY, telephone 5003/2083.

J. I. WOOTEN

Copy to:
AC/S FAC

12 7

