

To Danny
& Tim
JSH



UNITED STATES MARINE CORPS
MARINE CORPS BASE
CAMP LEJEUNE, NORTH CAROLINA 28542

IN REPLY REFER TO
FAC/JSH/ed
6280
12 Nov 1982

From: Commanding General
To: Commanding General, 2d Marine Division, Fleet Marine Force,
Camp Lejeune, North Carolina 28542 (Attn: Fac0)

Subj: Concrete Slab, construction of

Ref: (a) CG, 2d MarDiv Work Request #002-83 of 6 Oct 82

1. The reference requested authorization to construct a concrete slab adjacent to the oil and water separation units near Building 1750 for a POL storage site. Said storage site to be 40'x11'x6" reinforced with wire mesh.
2. Review of the proposed project relative to current oil spill prevention and containment guidelines indicates the proposed action is an appropriate solution to the POL storage problem.
3. The pad should not be placed on top of the 18" drain line or associated manholes located in the vicinity of the proposed site. Subject to this restriction the proposed project is approved.
4. As noted in the reference, all materials, labor and other associated costs will be provided by the requestor.
5. It is requested that upon completion of the project a sketch of the project, and funded and unfunded costs be provided to permit capitalization of the asset and inclusion in the Base Plant Account.

J. S. HACK
By direction

Copy to:
BMO
PWO
NREAD



