

DATE OF INSPECTION
 17-24 JUNE 1987

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
**BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.
 NAVFACENCOM
 NORFOLK, VA**

2. TO

14. CERTIFICATE ISSUED YES NO
 EXPIRES 17 JUNE 1988
 15. BOILER INSPECTOR
Thomas L. Lanier
 NAVY OR NATIONAL BOARD NO
 NAVFAC 239
 16. REASON FOR NOT ISSUING CERTIFICATE

BOILER DATA

3. MANUFACTURER
CLEAVER BROOKS

| | | |
|--|--|---------------------------------|
| 4. PROPERTY NO. 65 | 5. MFG. SERIAL NO. C-80611 | 6. MFG. MODEL NO. N.B. 61798 |
| 7. BUILDING NO. BA-106 | 8. YEAR BUILT 1986 | 9. CAPACITY 6,900 LB/HR. |
| 10. FUEL (Check) <input type="checkbox"/> COAL <input checked="" type="checkbox"/> OIL <input type="checkbox"/> GAS | 11. PRESSURE DESIGNED OPERATING TEST 150 psi 50 psi 90 psi | |
| 12. FEED WATER TREATMENT <input type="checkbox"/> SATISFACTORY <input checked="" type="checkbox"/> UNSATISFACTORY | 13. TYPE <input type="checkbox"/> WATER TUBE <input checked="" type="checkbox"/> FIRE TUBE <input type="checkbox"/> C. I. | |

17. BOILER USE
EXPORT

18. COMBUSTION CONTROL (Mfg. Name)
FIRE VE

19. COMBUSTION
 12.5 % CO₂ 6.0 % EXCESS O₂

20. FLUE GAS TEMPERATURE
 AFTER BOILER 300 °F AFTER HEAT TRAP °F

SAFETY DEVICES
 SAFETY VALVES

| | | | |
|-----------------------------------|-----------------------------|--------------------------|-----------------------|
| 21. MANUFACTURER KUNKLE | 22. NUMBER AND SIZE 2-2" | 23. PSI SETTING 65-70 | 24. CONDITION SAT. |
|-----------------------------------|-----------------------------|--------------------------|-----------------------|

25. MANUFACTURER
CLEAVER BROOKS

26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED


FIRING EQUIPMENT

| ITEM | IN SERVICE | ALTERNATE |
|------------------|---------------------------------|-----------|
| 28. MANUFACTURER | CLEAVER BROOKS | |
| 29. TYPE | NOZZLE SPRAY - AIR ATOM. | |
| 30. FUEL GRADE | #2 | |

31. INSPECTOR'S COMMENTS
 W/S HEAVY SCALE (SLUDGE) IN LOWER HALF OF BOILER, ADJUST CHEMICAL PROGRAM TO CLEAN UP BOILER.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
Timothy J. [Signature] 6/26/87
 BY DIRECTION



DATE: 1-23-87

ACTIVITY: MERC

BUILDING NO: BA 106

BOILER NO: 65

Based on the existing condition and present rate of deterioration, it is estimated that the boiler has a remaining life of

5 or more years

() years

The following corrective action is recommended:


WATER LEAKING FROM BACK DOOR OF BOILER, INSPECTION
DOOR WAS OPEN AND SEVERAL TUBES WERE LEAKING
AT 2ND PASS. THE 2ND PASS TUBES HAD BEEN
RE-ROLLED ON 1-9-87. SEVERAL TUBES WERE SEPERATED
FROM TUBE SHEET AND STICKING THROUGH TUBE SHEET
ABOUT 1/8" PAST BEAD WHERE ROLLED BEADED.

ALL TUBES WERE SEAL WELDED BY HARRIS CONST. CO.
(PERRY SHAW) WHO INSTALLED BOILER. HYDRO AT 225 PSI
NO LEAKS AT TUBE ENDS. (RETESTED) BOILER 3 TIMES TO GET SATIS-
FACTORY TEST DUE TO 4 OR 5 WETPS AT WELDS.) ALL TUBES IN
2ND PASS WERE WELDED (46).

1-26-87

BOILER ON LINE AND STEAMING ABOUT 1/3-1/2 CAPACITY.
STACK TEMP. 350-400 °F. BOILER IS NOW HOT AND HAS EX-
PANDED ABOUT 3/32-4/32 AS CLOSE AS I CAN MEASURE.

Tom Lanier





UNITED STATES MARINE CORPS
BASE MAINTENANCE DIVISION
MARINE CORPS BASE
CAMP LEJEUNE, NORTH CAROLINA 28542-5000

IN REPLY REFER TO

4335
MAIN

23 JAN 1987

Harris Construction Co.
P. O. Box 1499
Morcks Corner, SC 29461

Re: Contract # 47470-84-7393
Replace Boiler, Bldg BA-106
Marine Corps Base,
Camp Lejeune, NC

Gentlemen:

As discussed during the telephone conversation on January 22, 1987 between Mr. Bob Anderson of your company and Mr. David Southerland of Utilities, Base Maintenance, Marine Corps Base, Camp Lejeune, North Carolina and pursuant to the warranty clause of the contract the following warranty item is being brought to your attention:


Boiler in Bldg BA-106 - The tubes are leaking in the boiler, which is caused by inefficient expansion capabilities in the boiler itself.

Point of contact is Greg Snowden, Contracts Manager, (110) 451-5794.

Please notify by letter when repairs have been made.

Sincerely,

T. D. JEWELL
Director of Operations



HARRIS CONSTRUCTION COMPANY, INC.
BOILERS, PRESSURE VESSELS & PIPING SYSTEMS
P.O. BOX 1499
MONCK'S CORNER, SOUTH CAROLINA 29461
(803) 761-3890

January 27, 1987

Sub: Contract # N62470-84-C-7893

Ref: Model 100-200-150# Steam Boiler w/Feed Pump
CB S.O. CU 8501819-01

Gentlemen;

After receiving a call from Mr. David Southerland at Camp Lejeune at 3:40 p.m. on 1-22-87 concerning boiler at BA-106.

I attempted to contract Applied Engineering in NC and did get their answering service and they said they would contact the Manager and have him call me.

I did not receive an answer from Applied Engineering, so I called Mr. Southerland and he informed me that if we did not come up and fix the boiler, they would get a contractor to fix it and bill us whatever they were charged.

At this point I told them we would have someone there in the morning of 1-23-87.


Mr. Anderson and a welder were at Camp Lejeune at 0800, 1-23-87.

Mr. Tom Lanier the Base Boiler Inspector recommended the hot pass be seal welded as they already had been rerolled by Applied Engineering.

At this time a phone call was made to Mr. Robert Howell of Applied Engineering of Greensboro NC. Lt. King of ROICC Camp Lejeune, NC, was on the phone with me, the government was concerned if welding these tubes would void the warranty on the boiler. Mr. Howell informed us that if the job was done properly it would not affect the warranty.

At this point we commenced preparation to seal weld the hot pass. Which was completed at approximately 2100 with the acceptance of a 1½ design Hydro-Test by Mr. Tom Lanier, Base Boiler Inspector.

Base personnel still insists that this is a warranty problem caused by the (tubes expanding and the boiler not expanding). I, Robert Anderson tried explaining to them, that it was caused by low water again and pointed out to them that their make up feed system was inadequate for this boiler at full power. ie (Cleaver-Brooks Rep. Cleave Beasley & Robert Anderson experienced inadequate water supply to make up feed tank during full power test and made reports of same to ROICC and in their daily reports.) The feed make up system starts out at the demineralizer with 1½" pipe and reduces down to 3/4" pipe, then through a 3/4" electric operated solenoid valve which further restricts the flow to the make up tank.



HARRIS CONSTRUCTION COMPANY, INC.
BOILERS, PRESSURE VESSELS & PIPING SYSTEMS
P.O. BOX 1499
MONCK'S CORNER, SOUTH CAROLINA 29461
(803) 761-3890

This pipe is old and possibly has lime build up inside, further restricting the flow of make up water. Still after having all this pointed out plus the fact that they had two feed water check valve failures prior to these two casualities. Base personnel still insists this has nothing to do with the problem.

I am submitting this letter along with our invoice for repairs to Cleaver Brooks Boiler Inc., and Camp Lejeune.

Date of written report of feed tank problem 8-21-86.

Base personnel present during meeting

Mr. David Southerland

Mr. Greg Shumaker


Lt. King ROICC

Mr. Tom Lanier, Base Boiler Inspector

Mr. Ray Hunt, ROICC Inspector

Mr. Robert B. Anderson, Harris Construction Company, Inc.
Respectfully yours,

Harris Construction Company, Inc.


James W. Harris
Vice President/ Gen. Mgr.

JWH/swg


Encl.

Letter-Applied Engineering Co. 19 Jan. 87

Letter- U.S. Marine Corps, Camp Lejeune, NC, 22 Jan. 87

cc: Mr. David Southerland
Mr. Greg Shumaker
Lt. King,
Mr. Tom Lanier
Mr. Ray Hunt
Applied Engineering
Cleaver Brooks Boiler Inc.
T.D. Jewell

P.S. Encl. Copy of Daily Report To Inspector, 8-21-86



Applied Engineering Company

INDUSTRIAL SERVICES DIVISION

51 Industrial Avenue, Greensboro, North Carolina 27406
P.O. Box 16266 • 919/275-1631

Mr. Bruce Hoffman
Base Maintenance Operations Division
Building 1202
Marine Corp Base
Camp Lejeune, NC 28542

January 19, 1987

Re: Building BA-106
Cleaver-Brooks Boiler, Model CB 100-200, Unit L-80611

Dear Mr. Hoffman,

On January 8, 1987 we responded to a request for immediate service on the boiler which is the subject of this letter. We were advised that the boiler was shut down with "water running out the front and rear." Our serviceman, Mark Kimbro, was diverted from another job and arrived at Camp Lejeune at approximately 6:00 PM.

Upon inspection, Kimbro determined that the second pass tubes were leaking where they joined the tube sheet. Some of the tubes had separated from the tube sheet by as much as 1/8 of an inch. Kimbro worked until after 11:00 PM re-rolling all the second pass tubes. He returned the following morning and the boiler was hydrostatically tested under the supervision of the base inspector, Mr. Lanier. The test was conducted at 225 psi for fifteen minutes, and was satisfactory.

The main purpose in writing this letter, Mr. Hoffman, is to advise those who are involved with the operation of this boiler that, from what we observed, it is apparent that the boiler has been subjected to some extreme and unusual operating conditions. To have a boiler develop leaking tubes after only about six months of service is very rare. To find a boiler with tube separation to the extent observed by our serviceman is indicative of the unit having been subjected to some extreme conditions.

What these conditions are, we do not know. However, from our experience we know what commonly causes tubes to expand away from the tube sheet. One cause is improper water treatment which results in scale forming on the tube. Scale prevents the transmission of heat through the tube, and ultimately the tube will overheat and expand away from the tube sheet. Another possible cause is thermal shock which results from the rapid introduction of cold feed water into a hot boiler. There are other reasons, certainly, but these two are common.



The secondary purpose of this letter is to advise you that we will invoice Camp Lejeune for our labor and expenses to repair this unit.

Startup on this boiler was completed on July 31, 1986. Before startup, the pressure vessel was subjected to a hydrostatic test, and met this test satisfactorily. If there had been a defect in the manufacture of this unit, it would have shown up here, and the repairs to correct any defect would have been covered by the manufacturer's warranty. The pressure vessel, then, was sound when the boiler was put into service. The leaking tubes developed after the boiler had been in service for almost six months. The leaks were the result of the conditions under which this boiler was operated. They were not caused by a defect in manufacturing, and, as such, the repairs to correct the leaks are not covered under warranty.

We incurred a great deal of labor and travel expenses to repair this pressure vessel, Mr. Hoffman, and we believe we justifiably deserve to be compensated for our service. Accordingly, herewith is our invoice at our standard labor rates. Will you please forward it for processing?

Very truly yours,
APPLIED ENGINEERING COMPANY




Robert W. Howell
Branch Manager

RWH/kh

cc: Rick Jackson

Bob Anderson-Harris Construction Co.





SPECIFICATION AND PLAN NO.

LOCATION AND DESCRIPTION OF DEFICIENCIES (Materials, Equipment, Safety, and/or Workmanship) ACTION TAKEN OR TO BE TAKEN

| |
|--|
| |
| |
| |

| DEFICIENCIES CORRECTED THIS DATE | REFERENCE | |
|----------------------------------|------------|-----------------------|
| | REPORT NO. | COMPLIANCE NOTICE NO. |
| | | |
| | | |
| | | |

CONSTRUCTION AND PLANT EQUIPMENT LEFT ON JOB SITE UNTIL USE IS COMPLETED

| DESCRIPTION | DATE FIRST ON JOB (First time only) | HOURS WORKED THIS DATE | HOURS IDLED | DATE OF FINAL REMOVAL FROM JOB SITE |
|-------------|-------------------------------------|------------------------|-------------|-------------------------------------|
| | | | | |
| | | | | |
| | | | | |

CONSTRUCTION AND PLANT EQUIPMENT NOT LEFT ON JOB SITE PERMANENTLY (This will include pickup trucks and mobile mounted items, such as compressor, that are also used for transportation to and from the job)

| DESCRIPTION | HOURS WORKED | HOURS IDLED |
|-------------|--------------|-------------|
| | | |
| | | |
| | | |

REMARKS (Include directions received from ROICC/AROICC, visitors, compliance notices received, errors and/or omission in P/S; pertinent information)

no show on employees make up water had to be hand fed as automatic feeder was inadequate

CONTRACTOR/SUPERINTENDENT _____ DATE _____

CONSTRUCTION REPRESENTATIVE'S REMARKS AND/OR EXCEPTIONS TO THIS REPORT

CONSTRUCTION REPRESENTATIVE _____ DATE _____

Rockwell Edward Globe & Angle (Return) Valves


Class 300 FN 50 740 psi 51 bar

29 AUG-84
 BA-100
 # 65
 NEW BOILER




Globe and angle; bolted bonnet integral stainless hard surfacing alloy on body seating surface and backseat integral hardfaced alloy disk seating surface; disk body-guided, equipped with Equalizer, flanged or buttwelding ends

FIGURE NUMBERS

| | |
|-------|---|
| Globe | Fig. 302 - Flanged Fig. 302Y - Buttwelding Ends* |
| Angle | Fig. 303 - Flanged Fig. 303Y - Buttwelding Ends* |



DWG. FOR 2 1/2 VALVE ONLY



GLOBE & ANGLE VALVES - SIZE 2 1/2 THRU 12


Bold face numerals are in inches and pounds.
 Orange numerals are in millimeters and kilograms

| SIZE | NPS DN | 2 1/2 65 | 3 800 | 4 100 | 5 125 | 6 150 | 8 250 | 10 250 | 12 300 |
|--|-----------|--------------------|--------------------|--------------------|---------------------|--------------------|--------------------|---------------------|---------------------|
| C Contact Face to Contact Face, (Globe)* | | 11.5 292 | 12.5 318 | 14 356 | 15.76 400 | 17.5 445 | 22 559 | 24.5 622 | 28 711 |
| D Center to Contact Face, (Angle)* | | 5.75 146 | 6.25 159 | 7 178 | 7.88 200 | 8.75 222 | 11 279 | 12.25 310 | 14 356 |
| E Center to Top, Globe | | 16 406 | 16.2 411 | 16.7 424 | 20.1 510 | 24.8 630 | 28.4 721 | 34.3 871 | 39.7 1008 |
| F Center to Top, Angle | | 13.6 345 | 14.4 366 | 19.6 371 | 17.7 450 | 21.4 544 | 24.2 615 | 28.8 731 | 32.9 836 |
| G Handwheel Diameter† | | 11 279 | 11.5 292 | 11.5 292 | 15 381 | 18 457 | 22 559 | 22 559 | 26 660 |
| H Clearance for Equalizer** | | 5.9 150 | 8.7 221 | 8.5 216 | 10 254 | 9.6 244 | 11 279 | 13.7 348 | 15 381 |
| Weight, Globe (Flanged) | | 70 32 | 100 45 | 139 63 | 226 103 | 370 168 | 525 238 | 890 404 | 1500 680 |
| Weight, Globe (Welding) | | 56 25 | 75 34 | 94 43 | 172 78 | 295 134 | 400 181 | 720 327 | 1270 576 |
| Weight, Angle (Flanged) | | 65 29 | 94 43 | 126 57 | 206 93 | 300 136 | 450 204 | 700 318 | 1200 544 |
| Weight, Angle (Welding) | | 51 23 | 69 31 | 81 37 | 152 69 | 225 102 | 325 147 | 530 240 | 970 440 |

*See table (pages 52 and 53) for buttwelding end dimensions
 †Regular handwheel standard on all sizes except 12" has impactor handwheel

**Center to end or end to end dimensions for welding end valves same as center to contact face or contact face to contact face dimensions for flanged end valves

2 1/2" has impactor handle
 • Equalizer pipe standard
 Drain plug on application at extra charge
 Material specifications page 48
 Pressure drop data pages 54 and 55
 Pressure-temperature ratings for Rockwell Edward valves pages 46 and 47








Valves

Class 300 FN 30 7.0 at 51 bar

Globe and angle, bolted bonnet, integral stainless steel surfacing alloy on body seating surface and backseat, integral hardfaced alloy disk seating surface, disk body-guided, equipped with Equalizer, flanged or butt welding ends.

FIGURE NUMBERS

| | |
|-------|--|
| Globe | Fig 302 - Flanged Fig 302Y - Butt welding Ends* |
| Angle | Fig 303 - Flanged Fig 303Y - Butt welding Ends* |




GLOBE & ANGLE VALVES - SIZE 2 1/2 THRU 12

Bold face numerals are in inches and pounds.
Orange numerals are in millimeters and kilograms.

| SIZE | NPS DN | 2 1/2 65 | 3 800 | 4 100 | 5 125 | 6 150 | 8 250 | 10 250 | 12 300 |
|--|-----------|--------------------|--------------------|--------------------|---------------------|--------------------|--------------------|---------------------|---------------------|
| C Contact Face to Contact Face, (Globe)* | | 11.5 292 | 12.5 318 | 14 356 | 15.76 400 | 17.5 445 | 22 559 | 24.5 622 | 28 711 |
| D Center to Contact Face, (Angle)* | | 5.75 146 | 6.25 159 | 7 178 | 7.88 200 | 8.75 222 | 11 279 | 12.25 310 | 14 356 |
| E Center to Top, Globe | | 16 406 | 16.2 411 | 16.7 424 | 20.1 510 | 24.8 630 | 28.4 721 | 34.3 871 | 39.7 1006 |
| F Center to Top, Angle | | 13.6 345 | 14.4 366 | 19.6 371 | 17.7 450 | 21.4 544 | 24.2 615 | 28.8 731 | 32.9 836 |
| G Handwheel Diameter† | | 11 279 | 11.5 292 | 11.5 292 | 15 381 | 18 457 | 22 559 | 22 559 | 26 660 |
| H Clearance for Equalizer** | | 5.9 150 | 8.7 221 | 8.5 216 | 10 254 | 9.6 244 | 11 279 | 13.7 348 | 15 381 |
| Weight, Globe (Flanged) | | 70 32 | 100 45 | 139 63 | 226 103 | 370 168 | 525 238 | 890 404 | 1500 680 |
| Weight, Globe (Welding) | | 56 25 | 75 34 | 94 43 | 172 78 | 295 134 | 400 181 | 720 327 | 1270 576 |
| Weight, Angle (Flanged) | | 65 29 | 94 43 | 126 57 | 206 93 | 300 136 | 450 204 | 700 318 | 1200 544 |
| Weight, Angle (Welding) | | 51 23 | 69 31 | 81 37 | 152 69 | 225 102 | 325 147 | 530 240 | 970 440 |

* See table pages 40 and 49 for butt welding end dimensions
 † Regular handwheel size, odd or all sizes except 12" has impactor handwheel
 ** Equalizer is not standard
 ‡ Drawing on application with all charges
 § For details of valves see pages 40 and 49
 ¶ For details of valves see pages 40 and 49
 †† See table page 40 for details of valves. Enlarge view pages 40 and 47

* Center to end or end to end dimensions for welding and valves same as center to contact face or contact face to contact face dimensions for flanged end valves








Valves

300 PN 50 140, 51 bar

Globe and angle, bolted bonnet, integral stainless steel surfacing alloy on body seating surface and backseat, integral hardfaced alloy disk seating surface, disk body-guided, equipped with Equalizer; flanged or butt welding ends

FIGURE NUMBERS

| | |
|-------|--|
| Globe | Fig. 302 - Flanged Fig. 302Y - Butt welding Ends* |
| Angle | Fig. 303 - Flanged Fig. 303Y - Butt welding Ends* |




GLOBE & ANGLE VALVES - SIZE 2 1/2 THRU 12

Bold face numerals are in inches and pounds.
Orange numerals are in millimeters and kilograms.

| SIZE | NPS DN | 2 1/2 65 | 3 800 | 4 100 | 5 125 | 6 150 | 8 250 | 10 250 | 12 300 |
|--|-----------|--------------------|--------------------|--------------------|---------------------|--------------------|--------------------|---------------------|---------------------|
| C Contact Face to Contact Face, (Globe)* | | 11.5 292 | 12.5 318 | 14 356 | 15.76 400 | 17.5 445 | 22 559 | 24.5 622 | 28 711 |
| D Center to Contact Face, (Angle)* | | 5.75 146 | 6.25 159 | 7 178 | 7.88 200 | 8.75 222 | 11 279 | 12.25 310 | 14 356 |
| E Center to Top Globe | | 16 406 | 16.2 411 | 16.7 424 | 20.1 510 | 24.8 630 | 28.4 721 | 34.3 871 | 39.7 1006 |
| F Center to Top, Angle | | 13.6 345 | 14.4 366 | 19.6 371 | 17.7 450 | 21.4 544 | 24.2 615 | 28.8 731 | 32.9 836 |
| G Handwheel Diameter† | | 11 279 | 11.5 292 | 11.5 292 | 15 381 | 18 457 | 22 559 | 22 559 | 26 660 |
| H Clearance for Equalizer** | | 5.9 150 | 8.7 221 | 8.5 216 | 10 254 | 9.6 244 | 11 279 | 13.7 348 | 15 381 |
| Weight, Globe (Flanged) | | 70 32 | 100 45 | 139 63 | 226 103 | 370 168 | 525 236 | 890 404 | 1500 680 |
| Weight, Globe (Welding) | | 56 25 | 75 34 | 94 43 | 172 76 | 295 134 | 400 181 | 720 327 | 1270 576 |
| Weight, Angle (Flanged) | | 65 29 | 94 43 | 126 57 | 206 93 | 300 136 | 450 204 | 700 316 | 1200 544 |
| Weight, Angle (Welding) | | 51 23 | 69 31 | 81 37 | 152 69 | 225 102 | 325 147 | 530 240 | 970 440 |

* See table pages 52 and 53 for butt welding end dimensions
† Regular handwheel size, 12" has impactor handle
‡ 2" has impactor handle
** Equalizer 1/2" stainless steel
Drain plug on top of valve
Material and vendor info page 45
Pressure class on page 46 and 47
Pressure temp. and material on page 46 and 47

* Center to end or end to end dimensions for welding end valves same as center to contact face or contact face to contact face dimensions for flanged end valves



DATE: 1-23-87

ACTIVITY: MERCCL

BUILDING NO: BA 106

BOILER NO: 65

Based on the existing condition and present rate of deterioration, it is estimated that the boiler has a remaining life of

5 or more years

() years

The following corrective action is recommended:


WATER LEAKING FROM BACK DOOR OF BOILER, INSPECTION
DOOR WAS OPEN AND SEVERAL TUBES WERE LEAKING
AT 2ND PASS. THE 2ND PASS TUBES HAD BEEN
RE-ROLLED ON 1-9-87. SEVERAL TUBES WERE SEPERATED
FROM TUBE SHEET AND STICKING THROUGH TUBE SHEET
ABOUT 1/8" PAST BEAD WHERE ROLLED BEAD.

ALL TUBES WERE SEAL WELDED BY HARRIS CONST. CO.
(PERRY SHAW) WHO INSTALLED BOILER. HYDRO AT 225 PSI
NO LEAKS AT TUBE ENDS. (RETESTED BOILER 3 TIMES TO GET SATIS-
FACTORY TEST DUE TO 4 OR 5 WEGPS AT WELDS.) ALL TUBES IN
2ND PASS WERE WELDED (46).

1-26-87

BOILER ON LINE AND STEAMING ABOUT 1/3-1/2 CAPACITY.
STACK TEMP. 350-400 °F. BOILER IS NOW HOT AND HAS EX-
PANDED ABOUT 3/32-4/32 AS CLOSE AS I CAN MEASURE.

Tom Lanier



DATE: 1-9-87

ACTIVITY: MCRCL

BUILDING NO: BA-106

BOILER NO: 105

Based on the existing condition and present rate of deterioration, it is estimated that the boiler has a remaining life of

5 or more years

() years

The following corrective action is recommended:

WATER LEAKING FROM BOTH ENDS OF BOILER,
18 PSI ON PRESSURE GAGE AND NORMAL WATER
LEVEL IN WATER GAGE GLASS, BOILER WAS NOT
RUNNING, LOCKED OUT ON PROGRAMER.

OPEN FIRE SIDE OF BOILER, WATER IS STANDING
IN FIRE BOX AND TUBES ARE WGT ALSO WATER
IS SPRAYING FROM SOME OF THE TUBE AT TUBE-
SHEET REAR OF BOILER AT 2ND PASS.

FACTORY REPRESENTATIVE REROLLED ALL TUBE IN 2ND
PASS (46 TUBES) HYDRO BOILER AT 214 PSI,
TWO (2) TUBE HAS VERY SMALL WEEP, DON'T RECOMMEND
ANY MORE ROLLING. AT PRESENT TIME TUBES ARE SATISFACTORY

1. ONE LEAK LEFT SIDE, TOP ROW 3RD TUBE FROM LEFT.
2. ONE LEAK RIGHT SIDE 3RD ROW FROM TOP, 4TH TUBE FROM R/SIDE


Tom Quinn

Cleaver's Brooks
PACKAGED BOILER SYSTEMS

MARK D. KIMBRO

SERVICE REPRESENTATIVE
APPLIED ENGINEERING COMPANY
GREENSBORO, NC

919/275-1631
800/772-9072



Applied Engineering Company

INDUSTRIAL SERVICES DIVISION

151 Industrial Avenue, Greensboro, North Carolina 27406
P.O. Box 16266 • 919/275-1631

Mr. Bruce Hoffman
Base Maintenance Operations Division
Building 1202
Marine Corp Base
Camp Lejeune, NC 28542

January 19, 1987

Re: Building BA-106
Cleaver-Brooks Boiler, Model CB 100-200, Unit L-80611

Dear Mr. Hoffman,


On January 8, 1987 we responded to a request for immediate service on the boiler which is the subject of this letter. We were advised that the boiler was shut down with "water running out the front and rear." Our serviceman, Mark Kimbro, was diverted from another job and arrived at Camp Lejeune at approximately 6:00 PM.

Upon inspection, Kimbro determined that the second pass tubes were leaking where they joined the tube sheet. Some of the tubes had separated from the tube sheet by as much as 1/8 of an inch. Kimbro worked until after 11:00 PM re-rolling all the second pass tubes. He returned the following morning and the boiler was hydrostatically tested under the supervision of the base inspector, Mr. Lanier. The test was conducted at 225 psi for fifteen minutes, and was satisfactory.

The main purpose in writing this letter, Mr. Hoffman, is to advise those who are involved with the operation of this boiler that, from what we observed, it is apparent that the boiler has been subjected to some extreme and unusual operating conditions. To have a boiler develop leaking tubes after only about six months of service is very rare. To find a boiler with tube separation to the extent observed by our serviceman is indicative of the unit having been subjected to some extreme conditions.

What these conditions are, we do not know. However, from our experience we know what commonly causes tubes to expand away from the tube sheet. One cause is improper water treatment which results in scale forming on the tube. Scale prevents the transmission of heat through the tube, and ultimately the tube will overheat and expand away from the tube sheet. Another possible cause is thermal shock which results from the rapid introduction of cold feed water into a hot boiler. There are other reasons, certainly, but these two are common.






The secondary purpose of this letter is to advise you that we will invoice Camp Lejeune for our labor and expenses to repair this unit.

Startup on this boiler was completed on July 31, 1986. Before startup, the pressure vessel was subjected to a hydrostatic test, and met this test satisfactorily. If there had been a defect in the manufacture of this unit, it would have shown up here, and the repairs to correct any defect would have been covered by the manufacturer's warranty. The pressure vessel, then, was sound when the boiler was put into service. The leaking tubes developed after the boiler had been in service for almost six months. The leaks were the result of the conditions under which this boiler was operated. They were not caused by a defect in manufacturing, and, as such, the repairs to correct the leaks are not covered under warranty.

We incurred a great deal of labor and travel expenses to repair this pressure vessel, Mr. Hoffman, and we believe we justifiably deserve to be compensated for our service. Accordingly, herewith is our invoice at our standard labor rates. Will you please forward it for processing?

Very truly yours,
APPLIED ENGINEERING COMPANY




Robert W. Howell
Branch Manager

RWH/kh

cc: Rick Jackson

Bob Anderson-Harris Construction Co.







Applied Engineering Company

151 Industrial Avenue
Greensboro, N. C. 27406

Invoice Date: 1-19-87

Customer No.

INVOICE

Invoice No. 8791

Our Order No. _____ Your Order No. _____ Date Shipped _____ Via _____

From _____ F. O. B. _____ Collect _____ Prepaid _____ Terms _____

Ref. No.

To: Base Maintenance Operations Division

Shipped to: Camp Lejeune, NC

Building 1202

Building BA-106


Marine Corps Base, Camp Lejeune, NC

ATTN: Mr. Bruce Hoffman

| Cost | Quan. | Shipped | B. O. | Part No. | Description | Unit Price | Amount |
|--|-------|---------|-------|----------|---|------------|---------------|
| | | | | | Service by our representative, M. Kimbro, on your Cleaver-Brooks Boiler Model CB 100-200, Unit L-80611, on January 8,9,1987 Building BA-106 | | |
| | | | | | 5 RT Job Hours @ 40.00 | | 200.00 |
| | | | | | 5 OT Job Hours @ 60.00 | | 300.00 |
| | | | | | 4.0 Travel Hours @ 36.00 | | 144.00 |
| | | | | | 230 Miles @ 0.40 | | 92.00 |
| | | | | | Motel @ 48.60 | | 48.60 |
| | | | | | Meals @ 10.20 | | 10.20 |
| Copies to Cus. <u>2</u> Copies to Salesman _____ Total <u>794.80</u> | | | | | | Tax | |
| Sales Tax Exemption Certificate # _____ | | | | | | Total | <u>794.80</u> |

| AMOUNT | | State Code | Sales Code | GENERAL Led. Acct. # | Func. or Dept. | OTHER DETAIL | |
|--------|--------|------------|------------|-------------------------|----------------|--------------|-----------|
| DEBIT | CREDIT | | | | | Job # | Cost code |
| | | 3 2 | | 8 6 0 1 0 5 2 | | | |
| | | 3 2 | | 5 2 7 0 2 0 0 | | | |
| | | 3 2 3 7 | | 8 6 1 1 0 5 2 | | | |
| | | 3 2 3 7 | | 1 3 4 3 1 0 0 | | | |
| | | 3 2 3 7 | | 8 6 1 1 0 5 2 | | | |
| | | 3 2 3 7 | | 8 6 0 9 0 4 2 0 0 3 4 8 | | | |
| | | 3 2 3 7 | | 8 6 1 9 0 5 2 | | | |

Approved by: _____





Applied Engineering Company

151 Industrial Avenue
Greensboro, N. C. 27406

Customer No.

Invoice Date: 1-19-87

Our Order No. Your Order No.

INVOICE

Invoice No. 8791

From F. O. B.

Date Shipped Via

Terms

To: Base Maintenance Operations Division

Ref. No.

Building 1202

Shipped to: Camp Lejeune, NC

Marine Corps Base, Camp Lejeune, NC


Building BA-106

ATTN: Mr. Bruce Hoffman, NC

| Cost | Quan. | Shipped | B. O. | Part No. | Description | Unit Price | Amount |
|--|-------|---------|-------|----------|---|------------|--------|
| | | | | 0 | Service by our representative, M. Kimbro, on your Cleaver-Brooks Boiler Model CB 100-200, Unit L-80611, on January 8, 9, 1987 Building BA-106 | 6 | |
| | | | | | 5 RT Job Hours @ 40.00 | | 200.00 |
| | | | | | 5 OT Job Hours @ 60.00 | | 300.00 |
| | | | | | 4.0 Travel Hours @ 36.00 | | 144.00 |
| | | | | | 230 Miles @ 0.40 | | 92.00 |
| | | | | | Motel @ 48.60 | | 48.60 |
| | | | | | Meals @ 10.20 | | 10.20 |
| | | | | | | Tax | |
| Copies to Cus. <u>2</u> Copies to Salesman <u> </u> Total <u>794.80</u> | | | | | | | |
| Sales Tax Exemption Certificate # <u> </u> | | | | | | | |
| | | | | | | Total | 794.80 |

| AMOUNT | | State Code | Sales Code | GENERAL Led. Acct. # | Func. or Dept. | OTHER DETAIL | |
|--------|--------|------------|--------------|----------------------|----------------|--------------|-----------|
| DEBIT | CREDIT | | | | | Job # | Cost code |
| | | 32 | | 8601052 | | | |
| | | 32 | | 5270200 | | | |
| | | 3237 | 8611052 | | | | |
| | | 3237 | 1343100 | | | | |
| | | 3237 | 8611052 | | | | |
| | | 3237 | 860904200348 | | | | |
| | | 3237 | 8619052 | | | | |

Approved by: _____



APPLIED ENGINEERING COMPANY

INDUSTRIAL SERVICES DIVISION

P.O. Box 16266, Greensboro, N.C. 27406
151 Industrial Avenue 919/275-1631

P.O. Box 1327, Orangeburg, S.C. 29116-1327
1525 Charleston Road 803/534-2424

P.O. Box 17303, Greenville, S.C. 29606
28 Doolittle Rd. 803/297-1783

P.O. Box 450046, Atlanta, GA. 30345
2004 Weems Road, Tucker, GA. 404/934-0420

Customer Camp Lejeune Date 1-9-87
 Street Bldg. BA-106 City JACKSONVILLE State N.C.
 Model No. CTS 101-200 Unit No. L-80611
 Contract Time and Material Warranty Start-up


| DATE | TIME | | FROM - TO | MILES | TRAVEL TIME | | JOB TIME | |
|--------|-------|--------|---------------------------|-----------------|-------------|----------------|----------|-----|
| | Start | Finish | | | RT | OT | RT | OT |
| 1-8-87 | 5:00 | 11:30 | New Bern - Jacksonville | 5100 | | 1.5 | | 5.0 |
| 1-9-87 | 8:00 | 5:00 | JACKSONVILLE - Greensboro | 230 | 3.0 | 1.0 | 5.0 | |
| | | | | | | | | |
| | | | | | | | | |

Expenses: Motel 48⁶⁰ Meals 10²⁰ Other _____

| QTY | PART NO. | PARTS USED | | |
|-----|----------|------------|--|--|
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Work Performed: 1-8-87 Rolled All 2ND pass tubes. 1-9-87
Hydrostatically tested boiler to 225 lb. under the
supervision of B&E Equipment inspector @ 225 lb for 15 min.
Tested good.

Service Man: M.D. K Accepted by: _____ P.O. # _____



Cleaver Brooks

DIVISION OF AQUA-CHEM, INC.
PO BOX 421
MILWAUKEE, WISCONSIN 53201

FIELD REPORT INFORMATION SHEET

Date 8-29-86 (Job Concluded) 1986
Model No. CB101-200
Serial No. L-80611
Design Pressure 150#
Working Pressure: Steam 50#
Hot Water _____

BA-106
#65

Name MARINE CORPS BASE Bld. BA-106

Address Onslow Beach

City, State and Zip Camp Lejeune, North Carolina

Name & Initials & Title of Person in Charge (Print) Bob Anderson

Company Represented HARRIS Construction

Operating Instructions Given To: R.H. Weston, Steven Parson, Frank Bowling, Bobby Meadows, Bobby Edens, Seth Mills

Company Represented MARINE CORPS BASE, BASE MAINTENANCE

Who Has The Manual? Bob Anderson Manual No. 750- 91

Company Represented HARRIS Construction Co.

Boiler Water Treatment Discussed With: Name (Print) Ray Hunt

Company Contract office, Camp Lejeune, Bld 1005

TIME AND TRAVEL DATA

| Date | From City | To City | Miles | Travel Time | Job Time |
|------------------------|-----------|---------|-------|-------------|----------|
| From 7-29 thru 8-29-86 | | Total | 891 | 740 | 26.0 |
| | | | | | |
| | | | | | |
| | | | | | |

Is call to be paid for by customer? No Other? _____

ACCEPTED: Name Robert Anderson
Signed 8-29-86

STARTING SERVICE

OIL GAS

PLEASE ATTACH APPROPRIATE SUPPLEMENTAL FORMS

General Form C10-1275A

Oil Fuel Form C10-1269A

Gas Fuel Form C10-1270A

Model 3 Form C10-1283A

Model 4 Form C10-1487A

Deaerator Form C10-1267A

Water Conditioner Form C10-1268A


Company HARRIS CONST. CO. INC

Print Name ROBERT ANDERSON

This unit received complete start-up, operator trained, and equipment operating satisfactorily.

SERVICES BY: Clive Beasley
Field Representative
Applied Engineering Co.
Company

APPROVED BY: _____
Service Manager




1. What is general condition of boiler room at time of starting? _____
New Construction Damp Dusty Clean Roof Only Outdoor
 2. At time of start-up is there an adequate supply of combustion air? yes 2A. Boiler Room Ambient Temperature 90
 3. Is boiler level? yes 4. Are blow down valves provided on boiler shell? Front yes Rear yes
 5. Are water column and/or level control drain valve tight? yes
 6. Are all blow down valves piped to a safe point of discharge? _____
 7. Have all hand hole covers, yokes, and gaskets been checked for tightness? yes Man hole cover? yes
 8. Has unit been boiled out? yes if not, has this been discussed with party signing this report? _____
(Boil-out is owner's responsibility since the requirement is necessitated by system condition. Cleanliness of pressure vessel is of extreme importance to boiler owner.)
 - 8A. Was boiler used for temporary heat during construction period? _____
 9. Electrical Characteristics:
 - a. Blower motor connected for 208 volts. b. 'T' terminal voltage at blower motor starter during high fire _____
 - c. Blower motor name plate amperage rating at connected voltage 29.3 ; draw (each leg at high fire) 28.0 28.5 28.0
 - d. Lowest actual control circuit voltage during starting cycle 120
 - e. 'T' terminal voltage at air pump motor starter during high fire N/A
 - f. Air pump motor name plate amperage rating at connected voltage N/A ; draw (each leg at high fire) _____
 - g. Electric oil heater voltage during operation N/A ; heater amperage (each leg) _____
- If control circuit transformer furnished, is it properly wired for existing voltage condition? yes

| CIRCUIT | FUSE | | STARTER OVERLOADS |
|-----------------|-----------------|--------------------|-------------------|
| | SIZE | TYPE | |
| Blower Motor | <u>FLNR35</u> | <u>Little Fuse</u> | <u>FH 53</u> |
| Air Pump Motor | <u>N/A</u> | | |
| Oil Heater | <u>N/A</u> | | |
| Oil Pump Motor | | | |
| Control Circuit | <u>ELNR61/4</u> | <u>Little Fuse</u> | <u>X X X</u> |
| Others | | | |

10. Load on unit (circle one) moderate, heavy, light, extremely light, extremely heavy, sudden peak loads. _____
11. Safety or relief valve(s) name plate pressure setting 65# @ 70"
12. Are safety or relief valves piped to a safe point of discharge and are there proper drains? yes
Does it appear that discharge piping is adequately supported so that weight of piping does not rest on valve body? yes
Are drip-pan ells or flexible connections used? yes
13. Incoming water temperature: Feedwater (steam boiler) 160°F
Return water (hot water boiler) _____
14. Actual height of water above top of tubes at lowest visible point in gauge glass 3 1/8"
15. List dimensions in inches measured above lowest portion of gauge glass at operating pressure (steam boiler only):

| | MASTER | AUXILIARY |
|--------------------|---------------|---------------|
| Pump Off | <u>2 1/8"</u> | _____ |
| Pump On | <u>1 3/4"</u> | _____ |
| Low Water Cut Off | <u>1/2"</u> | <u>1/4"</u> |
| High Water Cut Off | <u>5 1/2"</u> | <u>7 1/2"</u> |



CLEAVER-BROOKS

16. Type of return system used (steam boiler) Preheat Tank & Pump

Type of system (hot water boiler) three-way valve primary-secondary reverse-return accumulator-tank
 or explain. _____

17. Pressure or temperature control settings:

| | | | | |
|--------------------|--------|------------|---------|---------------------------|
| Operating Control | Cut-In | <u>42#</u> | Cut-Out | 50# <u>50#</u> |
| Modulating Control | To Low | <u>44#</u> | To High | _____ |
| High Limit Control | Cut-In | _____ | Cut-Out | <u>58#</u> |

NOTE: Reliable safety or relief valve operation is predicated on operating pressure or temperature being no higher than 85% of valve(s) set pressure.

- a. If hot water boiler, what is operating pressure? _____
- b. If equipped with minimum temperature Aquastat, what is "On" setting? _____
- c. If equipped with low fire hold Aquastat, what is "On" setting? _____
- d. If hot water boiler, are there system devices to stop burner firing or to shut-off circulating pump on a rise of outdoor temperature? _____
- e. If hot water boiler, are there system devices to provide night, weekend, or holiday setback of system temperature? _____

18. If day-nite set-up installed on steam boilers, have controls been set according to customer's requirements? _____

19. Was operation of combustion control explained and demonstrated to operator? _____

Make FRIGGE Model 70D10 Serial No. 8605 Code No. 3

20. Safety timing (Flame response) 1.1 sec. 21. Latchout switch timing 35 sec.

22. Was rear door opened before firing? yes Closing and resealing explained? yes

23. Were front doors opened before firing? yes Closing and resealing explained? yes

24. Furnace and rear door refractory inspected? yes 25. Was care of refractory and wash coating explained? yes

26. Was burner removed and its operation explained prior to firing? yes 27. Type of pilot: Gas _____ Oil _____

28. Was customer shown how to clean pilot and adjust pilot flame? yes 29. Was proper electrode(s) setting explained? yes

30. Was ignition system, tightness of connectors etc., explained? yes

31. Was function of scanner explained? yes

32. If fuel oil preheated with steam, is condensate wasted? N/A Piped to drain? _____

33. Was operation with manual potentiometer versus automatic operation by the modulating control potentiometer demonstrated and explained? yes

Have you cautioned operating personnel against practice of operating on manual potentiometer only thus creating unwanted condition of "On-Off" firing resulting in undue expansion and contraction? _____

34. At what pressure or temperature was burner turned to automatic position? 40#


35. If boiler equipped with rotary damper, was alignment checked and operation explained? _____

36. Was linkage and cam adjustment fully explained? yes

37. Was setting or adjusting of operating and modulating temperature or pressure controls fully demonstrated? yes

38. Was water column and auxiliary low water cut-off drain procedure demonstrated? yes

39. Have functions of all operating controls been reviewed with operator? yes Has operator(s) _____ been instructed on trouble-shooting? yes




1. Grade of Oil #2 F.O.
2. Oil suction line size 3/4"
3. Oil return line size 3/4"
4. Is fuel supply tank above or below level of boiler? Above
5. Length of horizontal suction line run _____
6. Length of vertical lift of suction line Day tank in boiler room Type of check valve used _____ location _____
8. Inches of vacuum with unit running NONE Location of reading _____
9. Time required for oil pressure to come to running pressure 1 sec.
10. Was flow of oil completely outlined to operator? yes
11. If more than one unit, does each unit have an individual fuel pump? yes; common individual suction line?
Pump Make and model Tullill Motor ILA H.P., Type of Drive Direct
12. If belt-driven equipment involved, was operator shown how to adjust belts? yes
13. Was servicing and cleaning of strainers explained? yes
14. Was relative position of diffuser and nozzle checked and explained? yes
15. Was lube-oil level, its importance, and maximum and minimum level explained? yes Grade Sae _____ Brand _____
16. Was atomizing air pressure system checked out and explained? yes
17. Was air filter and lube-oil strainer cleaning shown? yes
18. Was operation of oil metering valve explained? yes
19. Was secondary air adjustment, its importance on lighting, and affects on combustion explained? yes
20. Was metering valve packing adjustment or replacement demonstrated? yes
21. Were functions of combustion air proving switch and atomizing air proving switch explained? yes
22. Was adjustment and function of fuel oil controller and the flow of oil through it explained? yes
23. Was proper method of cleaning burner gun and nozzle assembly demonstrated? yes
24. Oil temperature at fuel oil controller N/A
25. Primary air pressure: low fire _____ high fire _____
26. Oil supply pressure 75#
27. Has oil piping, including fuel oil controller, from last strainer to solenoid valve been flushed and cleaned? yes
Have solenoid valve(s) been disassembled to check cleanliness of seat and disc? yes
28. If equipped, has nozzle post purge been explained? N/A
And is operation proper? _____ Nozzle size _____
29. If gas pilot, what is pressure with solenoid valve open 1" W.C. closed 10" W.C.
30. If light oil pilot, what is oil pressure? _____

COMBUSTION TEST RESULTS

| Fuel Oil | Low Fire | | | | | | High Fire | | | | | | |
|---|--------------|-------|-------|-------|-------|-------|-----------|-------|-------|-------|-------|-------|-------|
| | Cam Position | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 |
| % CO ₂ | | 10.9 | 11.6 | 11.8 | 11.9 | 12.4 | 13.1 | 13.6 | 13.6 | 13.7 | 13.9 | 13.6 | 13.7 |
| % O ₂ | | 6.2 | 5.3 | 5.0 | 5.0 | 4.2 | 3.3 | 2.7 | 2.6 | 2.5 | 2.3 | 2.6 | 2.5 |
| Smoke Spot | | | | | | | | | | | | | |
| Stack Temp. <u>net</u> | | 185°F | 205°F | 206°F | 222°F | 234°F | 237°F | 238°F | 229°F | 245°F | 249°F | 231°F | 239°F |
| Oil Burner Pressure | | 38 | 38 | 37 | 37 | 37 | 37 | 37 | 37 | 37 | 36.5 | 36.5 | 36.5 |
| Oil Return Pressure <u>Ambient Temp.</u> | | 86°F | 87°F | 88°F | 88 | 88°F | 88°F | 88°F | 88°F | 89°F | 89° | 89°F | 89°F |

31. Type of Combustion Analysis Equipment used: KANE MAP



Applied Engineering Company, Inc.

Manufacturer's Representative Division

COMBUSTION TEST RESULTS

• PHONE 1919 275-1031

Fuel Gas

| | % CO ₂ | % O ₂ | % CO | Gas Supply Press. | Stack Temp. | Steam Press. | Steam Flow | Steam Temp. | Feed Wt. Temp. |
|----|-------------------|------------------|------|-------------------|-------------|--------------|------------|-------------|----------------|
| 1 | | | | | | | | | |
| 2 | | | | | | | | | |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |
| 5 | | | | | | | | | |
| 6 | | | | | | | | | |
| 7 | | | | | | | | | |
| 8 | | | | | | | | | |
| 9 | | | | | | | | | |
| 10 | | | | | | | | | |
| 11 | | | | | | | | | |
| 12 | | | | | | | | | |

F.O. Gilpeale, Fuel Oil

| | % CO ₂ | % O ₂ | Oil Press. Burner | Atom Air or Steam Press. | Oil Temp. | Stock Temp. Net | Steam Press. | Steam Flow | Steam Temp. | Feed Wt. Temp. |
|----|-------------------|------------------|-------------------|--------------------------|----------------------|-----------------|--------------|-----------------------|-------------|----------------|
| 1 | 10.9 | 6.2 | 38# | 13.5 | 9.6 | 185°F | 47# | 86°F | | 155°F |
| 2 | 11.6 | 5.3 | 38# | 16.0 | 21.9 | 202°F | 49# | 87°F | | 155°F |
| 3 | 11.8 | 5.0 | 37# | 19.0 | 31.5 | 206°F | 43# | 88°F | | 180°F |
| 4 | 11.9 | 5.0 | 37# | 20.5 | 40.1 | 222°F | 46# | 88°F | | 200°F |
| 5 | 12.4 | 4.2 | 37# | 21.5 | 45.4 | 231°F | 45# | 88°F | | 205°F |
| 6 | 12.1 | 3.3 | 37# | 22.5 | 53.8 | 237°F | 46# | 88°F | | 205°F |
| 7 | 13.6 | 2.7 | 37# | 23.0 | 57.9 | 238°F | 44# | 88°F | | 200°F |
| 8 | 13.6 | 2.6 | 37# | 23.5 | 59.1 | 229°F | 38# | 88°F | | 195°F |
| 9 | 13.7 | 2.5 | 37# | 24.0 | 60.1 | 245°F | 46# | 89°F | | 190°F |
| 10 | 13.9 | 2.3 | 36.5# | 24.0 | 60.2 | 249 | 47# | 89°F | | 180°F |
| 11 | 13.6 | 2.6 | 36.5# | 24.0 | 60.4 | 231 | 34# | 89°F | | 180°F |
| 12 | 13.7 | 2.5 | 36.5# | 24.0 | 61.1 | 239 | 37# | | | 175°F |

Sample June

BA-106

Contract No. 7893

CB101-200, un. FL-80611

8-20-86


#2 F.O.

Comments, etc.

Accepted

By

Field Representative



INSPECTION REPORT-BOILERS
 NAVFAC 9-11014/41 13/871
 Supersedes NAVDOCKS 2544
 S/N 0105-LF-004-0000

DATE OF INSPECTION
 26 JUNE, 29 AUG. 1986

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
 COMMANDING GENERAL
 MCB, CAMP LEJEUNE, NC

2. TO
 NAVFACENGCOM
 NORFOLK, VA

14. CERTIFICATE ISSUED YES NO
 EXPIRES 26 JUNE 1987

15. BOILER INSPECTOR
 Thomas L. Loxier
 NAVY OR NATIONAL BOARD NO.
 NAVFAC 239

BOILER DATA

3. MANUFACTURER
 CLEAVER BROOKS

4. PROPERTY NO. 65
 5. MFG. SERIAL NO. C-80611
 6. MFG. MODEL NO. N.B. 61798

7. BUILDING NO. BA-106
 8. YEAR BUILT 1986
 9. CAPACITY 4,900 LB/HR

10. FUEL (Check)
 COAL OIL GAS

11. PRESSURE
 DESIGNED 150 psi
 OPERATING 50 psi
 TEST 225 psi

12. FEED WATER TREATMENT
 SATISFACTORY UNSATISFACTORY

13. TYPE
 WATER TUBE FIRE TUBE C. I.

16. REASON FOR NOT ISSUING CERTIFICATE

17. BOILER USE
 EXPORT

19. COMBUSTION
 13.5 % CO₂ 2.7 % EXCESS O₂

18. COMBUSTION CONTROL (Mfg. Name)
 FIREVE

20. FLUE GAS TEMPERATURE
 AFTER BOILER 245 °F ; AFTER HEAT TRAP _____ °F

SAFETY DEVICES
SAFETY VALVES

21. MANUFACTURER
 KUNKLE

22. NUMBER AND SIZE
 2 - 2"

23. PSI SETTING
 165-170

24. CONDITION
 SMT.

STEAM PRESSURE GAUGE

25. MANUFACTURER
 CLEAVER BROOKS

26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

| ITEM | IN SERVICE | ALTERNATE |
|------------------|--------------------|-----------|
| 28. MANUFACTURER | CLEAVER BROOKS | |
| 29. TYPE | NOZZLE - AIR ATOM. | |
| 30. FUEL GRADE | #2 | |

31. INSPECTOR'S COMMENTS
 NEW BOILER INSTALLED UNDER CONTRACT # 84-7893
 BOILER WILL RETAIN SAME PROPERTY NO. AS OLD BOILER.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
 [Signature] 9/2/86 BY DIRECTION

Handwritten marks and scribbles in the top right corner.

| | | | |
|--|--|---|---|
| MFGRS. SERIAL NO. 89443 | MFGRS. MODEL NO. CB 200-150 | MANUFACTURER CLEAVER BROOKS | DATE OF SHEET 20 AUG-86 |
| TYPE OF SUPERHEATER N/A | FURNACE VOLUME 44 CU. FT. | OPERATION <input checked="" type="checkbox"/> AUTOMATIC <input type="checkbox"/> SEMI-AUTOMATIC <input type="checkbox"/> MANUAL | USE <input checked="" type="checkbox"/> EXPORT <input type="checkbox"/> ELEC. POWER GENERATION <input type="checkbox"/> LAID UP - WET <input type="checkbox"/> LAID UP - DRY |
| TEMPERATURE AT SUPERHEATER OUTLET N/A °F | HEATING SURFACE (SQ. FT.) 1000 | PRESSURE (psig) 150 DESIGN 50 MAWP 50 INSTALLED WP | DATE BUILT 1986 |
| NORMAL FEEDWATER TEMPERATURE 200 °F | BOILER _____ WATER WALL _____ ECONOMIZER _____ SUPERHEATER _____ | CAPACITY 200 HP 6,900 LB./HR EDR BTU/HR. | DATE INSTALLED JULY 1986 |
| (See Reverse Side for Fittings) | DRUMS NO. 1 DIAMETER 60 IN. LENGTH 14 FT. 0 IN. <input type="checkbox"/> RIVETED <input type="checkbox"/> FORGE WELDED <input checked="" type="checkbox"/> FUSION WELDED | AIR HEATER <input checked="" type="checkbox"/> NONE <input type="checkbox"/> TUBULAR <input type="checkbox"/> REGENERATIVE <input type="checkbox"/> STEAM | BOILER TYPE <input type="checkbox"/> C.I. <input type="checkbox"/> WATER TUBE <input checked="" type="checkbox"/> FIRE TUBE DRAFT <input type="checkbox"/> NATURAL <input checked="" type="checkbox"/> FORCED <input type="checkbox"/> INDUCED |
| | | | PRODUCES <input checked="" type="checkbox"/> STEAM <input type="checkbox"/> LOW TEMP. WATER <input type="checkbox"/> HIGH TEMP. WATER CIRCULATION <input checked="" type="checkbox"/> NATURAL <input type="checkbox"/> FORCED |

| | FUEL & FIRING EQUIPMENT IN SERVICE | ALTERNATE FUEL & FIRING EQUIPMENT |
|------|--|---|
| FUEL | COAL <input type="checkbox"/> ANTHRACITE <input type="checkbox"/> BITUMINOUS GAS <input type="checkbox"/> NATURAL <input type="checkbox"/> MANUFACTURED OIL <input checked="" type="checkbox"/> COMMERCIAL 1, 2, 4, 5, 6 <input type="checkbox"/> NAVY <input type="checkbox"/> OTHER | COAL <input type="checkbox"/> ANTHRACITE <input type="checkbox"/> BITUMINOUS GAS <input type="checkbox"/> NATURAL <input type="checkbox"/> MANUFACTURED OIL <input type="checkbox"/> COMMERCIAL 1, 2, 4, 5, 6 <input type="checkbox"/> NAVY SPECIAL <input type="checkbox"/> OTHER |

| | FIRING EQUIPMENT | FIRING EQUIPMENT |
|------------------|--|--|
| FIRING EQUIPMENT | <input type="checkbox"/> COAL-HAND FIRED <input type="checkbox"/> COAL - STOKER <input type="checkbox"/> UNDERFEED - MULTIPLE RETORT <input type="checkbox"/> UNDERFEED - SINGLE RETORT <input type="checkbox"/> SPREADER - DUMP GRATE <input type="checkbox"/> SPREADER - VIBRATING GRATE <input type="checkbox"/> SPREADER - TRAVELING GRATE <input type="checkbox"/> CHAIN GRATE GAS <input type="checkbox"/> GAS RING <input type="checkbox"/> VENTURI TYPE <input type="checkbox"/> COAL - PULVERIZER <input type="checkbox"/> ATTRITION <input type="checkbox"/> BALL & RACE <input type="checkbox"/> BOWL MILL <input type="checkbox"/> TUBULAR <input type="checkbox"/> OIL BURNERS <input type="checkbox"/> MECHANICAL <input type="checkbox"/> STEAM ATOMIZED <input checked="" type="checkbox"/> AIR ATOMIZED <input type="checkbox"/> ROTARY CUP | <input type="checkbox"/> COL-HAND FIRED <input type="checkbox"/> COAL - STOKER <input type="checkbox"/> UNDERFEED - MULTIPLE RETORT <input type="checkbox"/> UNDERFEED - SINGLE RETORT <input type="checkbox"/> SPREADER - DUMP GRATE <input type="checkbox"/> SPREADER - VIBRATING GRATE <input type="checkbox"/> SPREADER - TRAVELING GRATE <input type="checkbox"/> CHAIN GRATE GAS <input type="checkbox"/> GAS RING <input type="checkbox"/> VENTURI TYPE <input type="checkbox"/> COAL - PULVERIZER <input type="checkbox"/> ATTRITION <input type="checkbox"/> BALL & RACE <input type="checkbox"/> BOWL MILL <input type="checkbox"/> TUBULAR <input type="checkbox"/> OIL BURNERS <input type="checkbox"/> MECHANICAL <input type="checkbox"/> STEAM ATOMIZED <input type="checkbox"/> AIR ATOMIZED <input type="checkbox"/> ROTARY CUP |

| |
|--|
| FIRING EQUIPMENT MANUFACTURER CLEAVER BROOKS |
|--|

| | | |
|---------------------------|---------------------------------------|------------------------------------|
| PROPERTY NO. 65 | BUILDING OR LOCATION BA-106 | ACTIVITY BOILER 65 MCBCL |
|---------------------------|---------------------------------------|------------------------------------|

DATA RECORD SHEET - BOILERS
 NAVFAC 9-11014/40 (9-69) Supersedes NAVDOCKS 2509
 S/N 0105-003-7010

| FITTING | NUMBER | SIZE | MANUFACTURER | TYPE | SETTING | RANGE | PRESSURE CLASS |
|---------------------|--------|--------|--------------------|---------------------|---------|-------|----------------|
| SAFETY VALVES | 2 | 2" | KUNKLE - 6021 | | 65-70 | | |
| STEAM OUTLET VALVES | 1 | 6" | ROCKWELL EDWARD | NON-RETURN ANGLE | | | 300 |
| BLOW-OFF VALVES | 2 | 1 1/2" | EVERLASTING | QUICK ACTING | | | 250 |
| FEEDWATER VALVES | 2 | 2" | MILWAUKEE | GLOBE GATE | | | 300 |
| WATER COLUMN | | | MCDONNELL & MILLER | | | | 150 |
| FEEDWATER REGULATOR | 1 | | MCDONNELL & MILLER | #157 | | | |
| WATER GAGES | | | | | | | |
| STEAM GAGES | 1 | 6" | CLEAVER BROOKS | | | 0-200 | |
| SOOT BLOWERS | N/A | | N/A | | | | |
| FUSIBLE PLUGS | N/A | | | | | | |

NATL BD. # 61798

CONTROL - FIREYE

SAFETY VALVE - SET 65 = 4944 LB/HR, SET 70 = 5045 LB/HR.

MAX FIRING RATE 60 GPH #2 OIL.

| | | | |
|---|--|---|--|
| MFGRS. SERIAL NO. 89443 | MFGRS. MODEL NO. CB 200-150 | MANUFACTURER Cleaver Brooks | DATE OF SHEET 20 Aug 86 |
| TYPE OF SUPERHEATER N/A | FURNACE VOLUME 44 CU. FT. | OPERATION <input checked="" type="checkbox"/> AUTOMATIC <input type="checkbox"/> SEMI-AUTOMATIC <input type="checkbox"/> MANUAL | USE <input checked="" type="checkbox"/> EXPORT <input type="checkbox"/> ELEC. POWER GENERATION <input type="checkbox"/> LAID UP - WET <input type="checkbox"/> LAID UP - DRY |
| TEMPERATURE AT SUPERHEATER OUTLET N/A °F | HEATING SURFACE (SQ. FT.) 1000 | PRESSURE (psig) DESIGN _____ 150 MAWP 50 INSTALLED WP | DATE BUILT 1986 |
| NORMAL FEEDWATER TEMPERATURE _____ °F | BOILER _____ WATER WALL _____ ECONOMIZER _____ SUPERHEATER _____ | AIR HEATER <input checked="" type="checkbox"/> NONE <input type="checkbox"/> TUBULAR <input type="checkbox"/> REGENERATIVE <input type="checkbox"/> STEAM | DATE INSTALLED July 1986 |
| (See Reverse Side for Fittings) | DRUMS NO. 1 DIAMETER 60 IN. LENGTH 14 FT. 0 IN. <input type="checkbox"/> RIVETED <input type="checkbox"/> FORGE WELDED <input checked="" type="checkbox"/> FUSION WELDED | CAPACITY 200 HP 6,900 LB./HR EDR BTU/HR. | BOILER TYPE C.I. _____ WATER TUBE _____ FIRE TUBE <input checked="" type="checkbox"/> DRAFT NATURAL _____ <input checked="" type="checkbox"/> FORCED INDUCED _____ |
| | | | PRODUCES <input checked="" type="checkbox"/> STEAM LOW TEMP. WATER _____ HIGH TEMP. WATER _____ CIRCULATION NATURAL <input checked="" type="checkbox"/> FORCED _____ |

| FUEL | FUEL & FIRING EQUIPMENT IN SERVICE | | ALTERNATE FUEL & FIRING EQUIPMENT | |
|------------------|--|---|--|--|
| | COAL | OIL | COAL | OIL |
| | <input type="checkbox"/> ANTHRACITE <input type="checkbox"/> BITUMINOUS | <input checked="" type="checkbox"/> COMMERCIAL 1, 2, 4, 5, 6 <input type="checkbox"/> NAVY <input type="checkbox"/> OTHER _____ | <input type="checkbox"/> ANTHRACITE <input type="checkbox"/> BITUMINOUS | <input type="checkbox"/> COMMERCIAL 1, 2, 4, 5, 6 <input type="checkbox"/> NAVY SPECIAL <input type="checkbox"/> OTHER _____ |
| | <input type="checkbox"/> NATURAL <input type="checkbox"/> MANUFACTURED | | <input type="checkbox"/> NATURAL <input type="checkbox"/> MANUFACTURED | |
| FIRING EQUIPMENT | FIRING EQUIPMENT IN SERVICE | | ALTERNATE FIRING EQUIPMENT | |
| | COAL - STOKER | COAL - PULVERIZER | COAL - STOKER | COAL - PULVERIZER |
| | <input type="checkbox"/> COAL - HAND FIRED <input type="checkbox"/> UNDERFEED - MULTIPLE RETORT <input type="checkbox"/> UNDERFEED - SINGLE RETORT <input type="checkbox"/> SPREADER - DUMP GRATE <input type="checkbox"/> SPREADER - VIBRATING GRATE <input type="checkbox"/> SPREADER - TRAVELING GRATE <input type="checkbox"/> CHAIN GRATE <input type="checkbox"/> GAS <input type="checkbox"/> GAS RING <input type="checkbox"/> VENTURI TYPE | <input type="checkbox"/> ATTRITION <input type="checkbox"/> BALL & RACE <input type="checkbox"/> BOWL MILL <input type="checkbox"/> TUBULAR <input type="checkbox"/> OIL BURNERS <input type="checkbox"/> MECHANICAL <input type="checkbox"/> STEAM ATOMIZED <input checked="" type="checkbox"/> AIR ATOMIZED <input type="checkbox"/> ROTARY CUP | <input type="checkbox"/> COAL - HAND FIRED <input type="checkbox"/> UNDERFEED - MULTIPLE RETORT <input type="checkbox"/> UNDERFEED - SINGLE RETORT <input type="checkbox"/> SPREADER - DUMP GRATE <input type="checkbox"/> SPREADER - VIBRATING GRATE <input type="checkbox"/> SPREADER - TRAVELING GRATE <input type="checkbox"/> CHAIN GRATE <input type="checkbox"/> GAS <input type="checkbox"/> GAS RING <input type="checkbox"/> VENTURI TYPE | <input type="checkbox"/> ATTRITION <input type="checkbox"/> BALL & RACE <input type="checkbox"/> BOWL MILL <input type="checkbox"/> TUBULAR <input type="checkbox"/> OIL BURNERS <input type="checkbox"/> MECHANICAL <input type="checkbox"/> STEAM ATOMIZED <input type="checkbox"/> AIR ATOMIZED <input type="checkbox"/> ROTARY CUP |

| |
|---|
| FIRING EQUIPMENT MANUFACTURER Cleaver Brooks |
|---|

| | | | |
|--------------------|--------------------------------|-----------|---|
| PROPERTY NO. 65 | BUILDING OR LOCATION BA-106 | BOILER 65 | ACTIVITY Marine Corps Base Camp Lejeune |
|--------------------|--------------------------------|-----------|---|

DATA RECORD SHEET - BOILERS
 NAVFAC 9-11014/40 (9-69) Supersedes NAVDOCKS 2509
 S/N 0105-003-7010

| FITTING | NUMBER | SIZE | MANUFACTURER | TYPE | SETTING | RANGE | PRESSURE CLASS |
|---------------------|--------|------|--------------|------|---------|-------|----------------|
| SAFETY VALVES | | | | | | | |
| STEAM OUTLET VALVES | | | | | | | |
| BLOW-OFF VALVES | | | | | | | |
| FEEDWATER VALVES | | | | | | | |
| WATER COLUMN | | | | | | | |
| FEEDWATER REGULATOR | | | | | | | |
| WATER GAGES | | | | | | | |
| STEAM GAGES | | | | | | | |
| SOOT BLOWERS | | | | | | | |
| FUSIBLE PLUGS | | | | | | | |

BA-106

L-9072

89443

UNIT L-80611
S.O. 8501819

MODEL CB 200-150# Stm psi
PART NO. 524-1209

FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATERTUBE
As Required by the Provisions of the ASME Code Rules

C25-1978A 10/82

LEBANON PA PLANT

1. Manufactured and Certified by Cleaver-Brooks Division of Aqua-Chem, Inc., Milwaukee, Wisconsin
(Name and address of manufacturer)
2. Manufactured for Camp Le Jeune - Jacksonville, North Carolina
(Name and address of purchaser)
3. Location of Installation Camp Le Jeune - Jacksonville, North Carolina
(Name and address)

4. Type Internally Fired Boiler No. 89443 N/A 524-1209
(HRT, etc.) (Mfr's Serial No.) (CRN) (Drawing No.)
61798 Year Built 19 86
(Nat'l. Board No.)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section I, 19 83 and Addenda to SUMMER, 1985
(Year) (Date)

Remarks: Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report: NONE
(Name of part, item number, mfr's name and identifying stamp)

6. Boiler Shells or Drums: No. 1 Dia. 60" Length 168" Dia. _____ Length _____

7. Shell Plates SA 515-70, 3/8"
(For each Shell or Drum state: Material Specification No. & grade, nominal thickness)

8. Longitudinal Joint(s) Welded Joint Efficiency 90%
(Seamless, Welded) (As compared to Seamless)

9. Heads NONE
(Material Specification No.; Thickness—Flat, Dished, Ellipsoidal—Radius of Dish)

10. Girth Joint(s) Welded No. of Shell Courses 2
(Seamless, Welded)

11. Tube Sheet SA 285-C, 1/2" Tube Holes 2.525"
(Mat'l Spec., Grade, Thickness) (Dia.)

12. Boiler Tubes: No. 108 SA 178-A Straight
(Mat'l. Spec., Grade) (Straight or Bent)
Dia. 2-1/2" Length 168-1/2" Gauge .105"
(If various, give max. & min.) (or thickness)

13. Furnace No. 1 Size 24" O.D. Length, each section PL 24" CORR 144-1/4" Total 168-1/4"
(O.D. or W x H)
Type Combination - Plain and Corrugated

PLAIN SA 53-B .500" (Plain, Adamson, Ring Reinforced, Corrugated, Combined or Stayed)
CORR SA 53-B .375" Seams: Type Seamless (Welded Girth)
(Mat'l Spec., Grade, Thickness) (Seamless, Welded)

14. Staybolts: No. NONE Size N/A
(Diam., Mat'l. Spec. Grade Size Telltale, Net Area)
Pitch N/A Max. AWP N/A psi.
(Hor. and Vert.)

15. Stays or Braces

| Location | Material Spec. No. | Type | No. & Size | Max. Pitch | Total Net Area | Fig. PFT-32 L/1 | Dist. Tubes to Shell | Area to be Stayed | Max. A.W.P. psi. |
|----------------------|--------------------|------|------------|------------|----------------|-----------------|----------------------|-------------------|------------------|
| (a) F.H. above tubes | SA675-60 | Diag | * 7 | 7 | 5.0264 | 1.09 | 16-1/2 | 343 | 154 |
| (b) R.H. above tubes | SA675-60 | Diag | * 7 | 7 | 5.0264 | 1.09 | 16-1/2 | 343 | 154 |
| (c) F.H. below tubes | N/A | | | | | | | | |
| (d) R.H. below tubes | N/A | | | | | | | | |
| (e) Through stays | N/A | | | | | *8 @ 1" | | | |
| (f) Dome braces | N/A | | | | | | | | |

16. Other Parts. 1. Water Column Assy. N/A 3. N/A
(Brief Description—i.e. Dome, Boiler Piping, etc.)

- Threaded pipe - SA 106-B, 1" & 1/2" Sch 80, M.A.W.P. 150# PSI
- Other pressure piping installed by contractor.
-

Form P-2 (Back)

17. Openings (a) Steam 1 @ 6" 300# Flg. (b) Safety Valve 2 @ 2" NPT
(No., Size, and Type) (No., Size, and Type)
 (c) Blowoff 2 @ 1-1/2" NPT Bottom CL (d) Feed 2 @ 2" NPT (R & L Side)
(No. Size, Type and Location) (No., Size, Type, and Location)
 (e) Manholes: No. 1 Size 11" x 15" Location Shell - Ring
 (f) Handholes: No. 6 Size 3-1/4" x 4-1/2" Location Shell
 No Connections to Item 17. N/A

18. Fusible Plug (if used) _____
(No., Diam., Location, Mfrs. Stamp)

19. Boiler Supports: No. 4 Type Legs Attachment Welded
(Saddles, Legs, Lugs) (Bolted or Welded)

20. Max. AWP 150 psi Based On PG-27 Heating Surface 1000 sq ft
(Code Par. and/or Formula) (Total)

21. Shop Hydrostatic Test 225# psig. N/A kw.
(Electric Boilers)

CERTIFICATE OF COMPLIANCE

We certify the statements in this data report to be correct. Cleaver-Brooks Division
 Date March 26, 1986 Signed of Aqua-Chem, Inc. by Samuel R. Carroll
(Manufacturer) (Authorized Representative)
 Our Certificate of Authorization No. 10905 to use the (A) or (S) S Symbol expires
January 15 19 89.

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Division of Aqua-Chem, Inc. at Lebanon, PA
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or
 Province of Pennsylvania and employed by The Hartford Steam Boiler I & I Co.
 of Hartford, Conn. have inspected parts of this boiler referred to as data items
1-8, 10-13, 15, 17-21 and have examined Manufacturer's Partial Data Reports for items
NONE

and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable
 sections of the ASME BOILER AND PRESSURE VESSEL CODE.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler
 described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any
 personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date April 3, 1986
David L. Klose Commissions NB 8884 PA 2309
Inspector Nat'l Board, State, Province and No.

CERTIFICATE OF COMPLIANCE

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION I of the ASME BOILER AND
 PRESSURE VESSEL CODE.
 Date _____ Signed _____ By _____
(Assembler) (Representative)
 Our Certificate of Authorization No. _____ to use the (A) or (S) _____ Symbol expires
 _____ 19 _____

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or
 Province of _____ and employed by _____ of _____
 have compared the statements in this Manufacturer's Data Report with the described boiler and state that the parts referred to as data
 items _____, not included in the certificate of shop inspection, have been
 inspected by me and that to the best of my knowledge and belief the manufacturer and/or the assembler has constructed and assembled
 this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was
 inspected and subjected to a hydrostatic test of _____ psi.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler
 described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any
 personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____
 _____ Commissions _____
Inspector Nat'l Board, State, Province and No.

ASME Section IX, Code
 Form WPS-1989
 ASME Boiler and Pressure Vessel Code
 Section IX-1989

QUALIFICATION TESTS
 (See QW 301 Section IX ASME Boiler and Pressure Vessel Code)

Welder Name Perry Shaw Check No. _____ Stamp No. (D)

Using WPS No. 100 Rev. 1

the above welder is qualified for the following ranges:

| Process | Record Actual Values | Used in Qualification | Qualification Range |
|-------------------------------------|----------------------|-----------------------|---------------------|
| Process | | SNAP | SNAP |
| Electrode | | MANUAL | MANUAL |
| Electrode Diameter | | 1/8" to 3/16" | 1/8" to 3/16" |
| Shielding Gas | | Ar | Ar |
| Travel Speed | | 1.482 | 1.482 |
| Current | | | |
| Voltage | | | |
| Diameter | | 6.625 | 2 7/8" |
| Groove | | | |
| Fillet | | | |
| Filler Metal (QW-404) | | SFA 5.1 | |
| Spec. No. | | E-6010 & E7018 | |
| Class | | 3 4 | |
| Position | | 1-6 | ALL Positions |
| Weld Position (QW-410) | | Vertical Up | |
| Base Type (QW-408) | | | |
| Electrical Characteristics (QW-409) | | DC | |
| Current | | 115 | |
| Polarity | | | |

Guided Bend Test Results QW-462.2(a), QW-462.3(a), QW-462.3(b)
 Type and Fig. No. Result

| | | |
|-----------|---|--------------|
| Face Bend | 1 | Satisfactory |
| Face Bend | 2 | Satisfactory |
| Root Bend | 1 | Satisfactory |
| Root Bend | 2 | Satisfactory |

Radiographic Test Results (QW-304 & QW-305)
 For alternative qualification of groove welds by radiography

Radiographic Results _____

Fillet Weld Test Results (See QW-462.4(a), QW-462.4(b))

Fracture Test (Describe the location, nature and size of any crack or tearing of the specimen) _____

Length and Penetration Depth _____

Micro Test—Fracture _____

Appearance—Front Side (leg) _____ in X _____ in Convexity _____ in or Concavity _____

Test Conducted by Harris Construction Company Laboratory—Test No. _____

We certify that the statements in this report are correct and that the test welds were prepared, welded and tested in accordance with the requirements of Sections IX of the ASME Code

Organization Harris Construction Co.

By Robert B. Anderson

6/2/86

This qualification test may be modified to conform to the type and number of tests required by the Code

1-23-87

HARRIS CONST CO.

SEAL WELD ALL TUBES IN 2ND PASS (46)

BA-186

65 BOILER

DATE OF INSPECTION
 9 MAY - 19 DEC 1980

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
 BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.

2. TO
 NAVFACENGCOM
 NORFOLK, VA

14. CERTIFICATE ISSUED YES NO
 EXPIRES 9 MAY 1981

BOILER DATA

3. MANUFACTURER
 YORK SHIPLEY

4. PROPERTY NO. 38 5. MFG. SERIAL NO. 63-8242-1430038 6. MFG. MODEL NO. SPA-188-6-97209

7. BUILDING NO. M-230 8. YEAR BUILT 1963 9. CAPACITY 6,500 LBS/HR

10. FUEL (Check)
 COAL OIL GAS

11. PRESSURE
 DESIGNED 150 psi OPERATING 50 psi TEST 105 psi

12. FEED WATER TREATMENT
 SATISFACTORY UNSATISFACTORY

13. TYPE
 WATER TUBE FIRE TUBE C. I.

15. BOILER INSPECTOR
 Jesse Z. Sellen
 NAVY OR NATIONAL BOARD NO.
 NAVFAC 225

16. REASON FOR NOT ISSUING CERTIFICATE

17. BOILER USE
 EXPORT

18. COMBUSTION CONTROL (Mfg. Name)
 FIREYE

19. COMBUSTION
 9.0 % CO₂ % EXCESS O₂

20. FLUE GAS TEMPERATURE
 AFTER BOILER 350 °F ; AFTER HEAT TRAP °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER
 CONSOLIDATED

22. NUMBER AND SIZE
 2-2"

23. PSI SETTING
 65-75

24. CONDITION
 GOOD

STEAM PRESSURE GAUGE

25. MANUFACTURER
 U.S. GAGE

26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

| ITEM | IN SERVICE | ALTERNATE |
|------------------|--------------|-----------|
| 28. MANUFACTURER | YORK SHIPLEY | |
| 29. TYPE | NOZZLE SPRAY | |
| 30. FUEL GRADE | #2 | |

31. INSPECTOR'S COMMENTS
 OK

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
 R.M. Sellen
 BY DIRECTION

