



DEPARTMENT OF THE NAVY
OFFICER IN CHARGE OF CONSTRUCTION
RESIDENT OFFICER IN CHARGE OF CONSTRUCTION
NAVAL FACILITIES ENGINEERING COMMAND CONTRACTS
CAMP LEJEUNE, NORTH CAROLINA 28542

IN REPLY REFER TO:
N62470-82-C-4669
JAX/W/JLD/sel
29 April 1985

AS-704
#5 Boiler.

Northeast Construction Company
P. O. Box 548
Jacksonville, NC 28541-0548

Re: Contract N62470-82-C-4669, Upgrade BSQ's AS-702 and AS-704, MCAS(H),
New River, Jacksonville, NC

Gentlemen:


Your submittal number 9C is returned herein. Please provide this office with original signatures on these documents. This may be in the form of copied documents with original signatures for certification.

Sincerely yours,

A handwritten signature in cursive script, appearing to read "J. L. Davis", is written above the typed name.

J. L. DAVIS
LT, CEC, USN
Resident Officer in
Charge of Construction

Copy to:
BMO (Attn: Mr. Tom Lanier)



FORM R-1, REPORT OF WELDED X REPAIR OR ALTERATION
 As Required by the Provisions of The National Board Inspection Code

*file - 236
copy to Smith*

1. Work done by A & M Company, Inc. P. O. Box 3147 Wilmington, NC 28405 (Name and address of repair or alteration organization) Serial No 1

2. Owner Burnham Corp. Lancaster, PA (Name and address of owner) MAR 7 1985

3. Location of Installation Marine Corps Air Station - New River, NC (Name and address)

4. Unit Identification Boiler (Boiler Pressure Vessel) Name of Manufacturer Burnham Corp.

5. Identifying Nos 15660 (Mfg. Serial No.) 15660 (National Board No.) B-1 (Jurisdiction) 1984 (Other) 1984 (Year Built)

6. Description of Work Repair Leak in Fillet Weld from Water Jacket to Base Plate
 (Use back or separate sheet or sheets if necessary)

- 1) Dress Weld suitable for Repair
- 2) Repair Weld
- 3) HYDROSTATIC TEST PERFORMED BY JUMILRY HEAT 16
& AHC COND. - WITNESSED BY A+M CO. INC. Pressure Test at 45 ps

7. Remarks Attached are Manufacturer's Partial Data Report, properly identified and signed by Commissioned Inspector for the following items of this report

In lieu of being inspected by Mr. Warden Baysden - Northeast Coast and Chuck Steed of Humphrey Heat & Air Cond. visually inspected weld repair and witness hydrostatic test at 45 PSI.

Warden Baysden
Chuck Steed

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that all Design material, construction, and workmanship on this Repair conform to The National Board Inspection Code

Date 3/28/85 Signed A & M Company, Inc. by Frank D. Weist (Authorized Representative)


Our Certificate of Authorization No R487 to use the "R" Symbol expires Aug 17 19 87

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors or the State or Province of NAUPAC 239 and employed by M.C. Comp & Equip of Jacksonville N.C. have inspected the work described in this Data Report on 3/21 19 85 and state that to the best of my knowledge and belief this work has been done in accordance with The National Board Inspection Code.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the work described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the Inspector's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date 3/21/85 Thomas L. Lenoir Commissions NAUPAC 239
(Inspector) (National Board State Province and No)



FABRICATION CHECK LIST


"TRAVELER"

Job Name: Burnham Corp. Boiler Weld Repair B-1

Job Number: 47576 (NB# 15660)

	PROJ. MGR	DATE	Q.C.M.	N.C.D.L. BOILER INSP.	A.I. HOLD
1. Code material received and visual inspection					
2. Mill test reports checked for compliance					
3. Code material marked with identifiers HT.#					
4. Materials stored in ASME segregated area					
5. Review of job procedure with Authorized Inspector					
6. Fit-up assembly in accordance with specifications*					
7. Proper welding materials and procedure followed W.P.S.# <u>2A</u>		7/3/15	JW		
8. Visual inspection of all welds and N.D.E. requirements met		7/1/15	JW		
9. Witness hydrostatic test* Test Pressure <u>45</u> lbs.		7/1/15	JW	Ⓟ	
10. ASME P-4A data forms or NB, repair form properly executed and signed		7/3/15	JW	Ⓟ	
11. ASME Code Symbol or "R" Stamp applied to vessel		7/3/15	JW	Ⓟ	
12. All records and forms properly filed					

* Indicates hold points for Authorized Inspector





A & M Company

P.O. Box 3147
Wilmington, N.C. 28406

Frank G. Weiss

Office
(919) 799-0510

**24 HOUR PHONE
(919) 799-0510**

- Installation & Repairs of Boilers, Turbines, Generators, Pressure Piping
- Procedure Welding
- Industrial Painting and Insulation
- Other Mechanical & Plant Maintenance Capabilities

1. Work done by A & M Company, Inc. P. O. Box 3147 Wilmington, NC 47576 (Name and address of repair or alteration organization) (Serial No) #5 Boiler

2. Owner Burnham Corp. Lancaster, PA (Name and address of owner)

3. Location of Installation Marine Corps Air Station - New River, NC (Name and address)

4. Unit Identification Boiler Name of Manufacturer Burnham Corp. (Boiler Pressure Vessel)

5. Identifying Nos. 15660 15660 B-1 1984 (Mfg. Serial No) (National Board No) (Jurisdiction) (Other) (Year Built)

6. Description of Work: Repair Leak in Fillet Weld from Water Jacket to Base Plate (Use back separate sheet or sketch if necessary)

- 1) Dress Weld suitable for Repair
- 2) Repair Weld
- 3) HYDROSTATIC TEST PERFORMED BY HUMPHRY HEATING & AIR COND. - WITNESSED BY A+M CO. INC. Pressure Test if Applied 45 psi

7. Remarks: Attached are Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors for the following items of this report

In lieu of having Inspector Mr. Warden Baysden - Northeast Coast and Chuck Steed of Humphry Heat & Air Cond. visually inspected weld repair and witness hydrostatic test at 45 PSI.
Warden Baysden
Chuck Steed

Name of part, item number, mfg. number and identifying stamp

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that all Design material, construction, and workmanship on this Repair conform to The National Board Inspection Code

Date 3/18/85 Signed A & M Company, Inc. by Frank J. Weist (Repair, Alteration Organization) (Authorized Representative)


Our Certificate of Authorization No R487 to use the "R" Symbol expires Aug 17 19 87

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors or the State or Province of _____ and employed by _____ of _____ have inspected the work described in this Data Report on _____ 19 _____ and state that to the best of my knowledge and belief this work has been done in accordance with The National Board Inspection Code

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the work described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the Inspector's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date _____ Inspector _____ Commissions _____ (Nat'l Board, State, Province and No)



FABRICATION CHECK LIST

"TRAVELER"

Job Name: Burnham Corp. Boiler Weld Repair B-1
Job Number: 47576 (NB# 15660)

	PROJ. MGR	DATE	Q.C.M.	N.C.D.L. BOILER INSP.	A.I. HOLD
1. Code material received and visual inspection					
2. Mill test reports checked for compliance					
3. Code material marked with identifiers					
4. Materials stored in ASME segregated area HT.# _____					
5. Review of job procedure with Authorized Inspector					
6. Fit-up assembly in accordance with specifications*					
7. Proper welding materials and procedure followed W.P.S.# <u>2A</u>	F/W	3/18	F/W		
8. Visual inspection of all welds and N.D.E. requirements met	F/W	3/18	F/W		
9. Witness hydrostatic test* Test Pressure <u>45</u> lbs.	F/W	3/16	F/W		
10. ASME P-4A data forms or NB, repair form properly executed and signed	F/W	3/14/85	F/W		
11. ASME Code Symbol or "R" Stamp applied to vessel	F/W	3/18/85	F/W		
12. All records and forms properly filed					

* Indicates hold points for Authorized Inspector



THE NATIONAL BOARD OF BOILER AND
PRESSURE VESSEL INSPECTORS

Certificate of Authorization

R 487

THIS IS TO CERTIFY that A & M COMPANY, INC.

206 WOODLAND DRIVE, WILMINGTON, NC 28403

is hereby authorized to use the Repair Symbol
of the National Board of Boiler and Pressure Vessel Inspectors for


**"NATIONAL BOARD CODE REPAIR AT THE ABOVE LOCATION AND
EXTENDED FOR FIELD REPAIRS CONTROLLED BY THIS LOCATION"**

*in accordance with the applicable rules of the National Board of
Boiler and Pressure Vessel Inspectors. The use of the Repair symbol
and the authority granted by this certificate of authorization are
subject to the provisions of the agreement set forth in the ap-
plication. Any repair stamped with this symbol shall have been made
strictly in accordance with the provisions of the National Board
Inspection Code.*

THIS AUTHORIZATION is issued or renewed on SEPTEMBER 5, 1984

and expires on AUGUST 17, 1987 by

THE NATIONAL BOARD OF BOILER AND PRESSURE VESSEL INSPECTORS




Chairman

G. H. Whitley

Executive Director


S. Harrison



A & M Company, Inc.
P. O. Box 3147
Wilmington, North Carolina
28406

Company Name A & M Company, Inc.
 Procedure Qualification Record No. 2 Date 3/15/85
 WPS No. 2A
 Welding Process(es) SMAW
 Types (Manual, Automatic, Semi-Auto.) Manual

JOINTS (QW-402)



Groove Design Used

<p>BASE METALS (QW-403) Material Spec. <u>SA285</u> Type or Grade <u>C</u> P-No. <u>1</u> to P-No. <u>1</u> Thickness <u>1/4" - 5/16"</u> Diameter <u>N/A</u> Other <u>N/A</u></p>	<p>POSTWELD HEAT TREATMENT (QW-407) Temperature <u>N/A</u> Time <u>N/A</u> Other <u>N/A</u></p>
<p>FILLER METALS (QW-404) Weld Metal Analysis A-No. <u>1</u> Size of Electrode <u>3/32</u> Filler Metal F-No. <u>4</u> SFA Specification <u>5.1</u> AWS Classification <u>E7018</u> Other <u>N/A</u></p>	<p>GAS (QW-408) Type of Gas or Gases <u>N/A</u> Composition of Gas Mixture <u>N/A</u> Other <u>N/A</u></p>
<p>POSITION (QW-405) Position of Groove <u>2F</u> Weld Progression (Uphill, Downhill) <u>N/A</u> Other _____</p>	<p>ELECTRICAL CHARACTERISTICS (QW-409) Current <u>DC</u> Polarity <u>Reverse</u> Amps. <u>80-110</u> Volts <u>20-25</u> Other <u>N/A</u></p>
<p>PREHEAT (QW-406) Preheat Temp. <u>65°F Min.</u> Interpass Temp. <u>800°F</u> Other <u>N/A</u></p>	<p>TECHNIQUE (QW-410) Travel Speed <u>N/A</u> String or Weave Bead <u>Stringer</u> Oscillation <u>N/A</u> Multipass or Single Pass (per side) <u>Multipass</u> Single or Multiple Electrodes <u>Single</u> Other <u>Each pass of weld bead shall be cleaned of anything that would affect the integrity of the welds by grinding, chipping or brushing</u></p>

**A & M COMPANY, INC.
RECORD OF PERFORMANCE QUALIFICATION TEST**

Prepared according to the requirements of Section IX of the ASME Boiler Code

Date Welded 2-6-85

WELDER'S NAME Fred L. Osborne PERSONAL NO. 543255 SYMBOL NO. E

WELDING PROCESS Combination G.T.A.W. & S.M.A.W.

POSITION (If vertical, state whether upward 6G
or downward.) (Flat, horizontal, vertical or overhead;
see QW-405, QW-461-2, QW-461-3, QW-461-4)

In accordance with Procedure Specification No. 2

Material Specification SA106B to SA106B of P-No. 1 to P-No. 1

Diameter and wall thickness (if pipe),
otherwise joint thickness 4" Sch. 80

Thickness range this qualifies 1/16" to .674"

FILLER METAL

SPECIFICATION NO. SFA5-1 & SFA5-18 GROUP NO. F 4 & 6

Describe filler metal if not included in Table Q-II-2 or QN-II-2: _____

Is backing strip used? no

FOR INFORMATION ONLY

Filler metal diameter and trade name 3/32" Hobart 7018 & 3/32" Linde ER705-2

Flux for Submerged Arc or gas for Inert Shielded Arc Welding Argon 20-25 C.F.H.


GUIDED BEND TEST RESULTS (See QW-462.2(a), QW-462.3(a), QW-462.3(b))


Type and Figure No.	Results	Type and Figure No.	Results
2 Face	Satisfactory		
2 Root	Satisfactory		

RADIOGRAPHIC RESULTS: As an alternate to Guided Bend Tests, Radiographic Test Results must be recorded in spaces provided below in accordance with QW-304, QW-305 of the ASME Sec. IX Code, Article 2 of Section V and UW-51 of Section VIII, Division I Code.

Type and Figure No.	Results	Type and Figure No.	Results

Date _____ Signed By _____





A & M Company, Inc.
P. O. Box 3147
Wilmington, North Carolina 28406

**WELDING PROCEDURE SPECIFICATION FOR A COMBINATION
OF GAS TUNGSTEN ARC WELDING AND SHIELDED METAL ARC
WELDING OF CARBON STEEL PER ASME SECTION IX BOILER
AND PRESSURE VESSEL CODE "WELDING AND BRAZING
QUALIFICATIONS"**

W.P.S. No. 2
Date: 6/13/80
Revision:
Date:
Sheet 1 of 5

WELDING PROCESS: The welding shall be done by a combination of Gas Tungsten Arc Welding for the stringer bead (first pass) and second pass. The remaining passed (weld on) shall be done using the Shielded Metal Arc Welding Process. Both processes shall use manual equipment.

BASE METAL: The base metal used to qualify this welding procedure specification conforms to ASME SA 53 Grade B listed under "P" No. 1 Classification.

BASE METAL THICKNESS: The base metal thickness used to qualify this Welding Procedure Specification is 0.382" thick which will qualify material thickness 1/16" (0.0625") thru 49/64" (0.7656"). The Welding Procedure Specification is qualified on 1-1/4" diameter which will qualify over 1" diameter pipe.

FILLER METAL: The filler metal for the Gas Tungsten Arc Welding process shall conform to ASME filler metal specifications SFA 5.2 weld metal analysis A-1 Group "F" No. 6 A.W.S. RG 65. The diameter of the filler metal is 1/8".

The filler metal for the Shielded Metal Arc Welding process shall conform to ASME filler metal specifications SFA 5.1 weld metal analysis A-1 Group "F" No. 4 AWS Classification E 7018. The diameter of the filler metal is 3/32".

SHIELDING GAS: The shielding gas for the Gas Tungsten Arc Welding process shall be welding Grade Argon. The flow rate shall be 15 C.F.H. thru 30 C.F.H. The cup size shall be 3/8". External shielding gas is not required for the Shielded Metal Arc Welding process.

ELECTRICAL CHARACTERISTICS: The current shall be direct current, electrode negative, straight polarity for the Gas Tungsten Arc Welding Process using a 3/32" diameter 2% thoriated tungsten electrode and direct current, electrode positive, reverse polarity, for the Shielded Metal Arc Welding Process.

POSITION: This Welding Procedure Specification was qualified in the 2G fixed position with the axis of the pipe vertical. The Welding Procedure Specification shall allow for welding of the plate or pipe in all positions.

PREHEAT AND INTERPASS TEMPERATURE: No welding shall be performed when the parts to be joined by welding are below room temperature (65° F min.) without first warming the welding area to a minimum of 65° F. Welding shall not be continued when the welding zone exceeds 800° F.

POST WELD HEAT TREATMENT: No post weld heat treatment is required for this Welding Procedure Specification.

PREPARATION OF BASE MATERIAL: The edges of the parts to be joined by welding shall be prepared by machining, flame cutting, or grinding as shown on the attached drawing and shall be cleaned of oil, grease, scale, rust, or other foreign material. See Figure No. 1.

BACKING STRIP OR BACKING GAS: The welded joint shall not utilize a backing strip or backing gas.

JOINT WELDING PROCEDURE: The welding techniques such as electrode size, filler metal size, mean voltage and amperages for each electrode shall be substantially as shown on the attached drawing. See Figure No. 1.

APPEARANCE OF WELDING LAYERS: The welding current and manner of depositing the weld metal shall be such that there shall be practically no undercutting on the side walls of the welding groove or the adjoining base material.


CLEANING: All slag or flux remaining on any bead of welding shall be removed before laying down the next successive bead of welding.

DEFECTS: Any cracks, porosity, lack of fusion, or lack of penetration that appear on any bead of welding shall be removed by chipping, grinding, gouging, or any other suitable means, before depositing the next successive bead of welding.

PEENING: None required by this Welding Procedure Specification.

TREATMENT OF UNDERSIDE OF WELDING GROOVE: None required by this Welding Procedure Specification.

APPROVED BY: A & M Company, Inc.
Company Name

SIGNED BY: 
Company Representative

DATE: 6-30-80

A & M Company, Inc.
P. O. Box 3147
Wilmington, North Carolina
28406

W.P.S. No. 2
Sheet 3 of 5


Company Name A & M Company, Inc.
 Procedure Qualification Record No. 2 Date 6/13/80
 WPS No. 2
 Welding Process(es) Gas tungsten arc welding for stringer bead shielded metal arc welding weldout
 Type: (Manual, Automatic, Semi-Auto.) Manual

JOINTS (QW-402)

See Figure No. 1 Attached

Groove Design Used

<p>BASE METALS (QW-403)</p> <p>Material Spec. <u>ASME SA 53</u></p> <p>Type or Grade <u>B</u></p> <p>P-No. <u>1</u> to P-No. <u>1</u></p> <p>Thickness <u>0.382" wall</u></p> <p>Diameter <u>1-1/4" diameter</u></p> <p>Other _____</p>	<p>POSTWELD HEAT TREATMENT (QW-407)</p> <p>Temperature <u>None Required</u></p> <p>Time <u>N/A</u></p> <p>Other _____</p>
<p>FILLER METALS (QW-404)</p> <p>Weld Metal Analysis A-No. <u>1</u></p> <p>Size of Electrode <u>1/8" for GTAW and 3/32" for SMAW</u></p> <p>Filler Metal F-No. <u>6 for GTAW and 4 for SMAW</u></p> <p>SFA Specification <u>5.2 for GTAW and 5.1 for SMAW</u></p> <p>AWS Classification <u>RG65 for GTAW and E7018 for SMAW</u></p> <p>Other _____</p>	<p>GAS (QW-408)</p> <p>Type of Gas or Gases <u>Argon for GTAW</u></p> <p>Composition of Gas Mixture <u>N/A</u></p> <p>Other _____</p>
<p>POSITION (QW-405)</p> <p>Position of Groove <u>2G Horizontal</u></p> <p>Weld Progression (Uphill, Downhill) <u>N/A</u></p> <p>Other _____</p>	<p>ELECTRICAL CHARACTERISTICS (QW-409)</p> <p>Current <u>Direct Current</u></p> <p>Polarity <u>Straight - GTAW, Reverse - SMAW</u></p> <p>Amps. <u>GTAW 75/95 Volts GTAW 9/12</u> <u>SMAW 85/105 volts SMAW 22/25</u></p> <p>Other <u>see Figure No. 1 for further details</u></p>
<p>FREHEAT (QW-406)</p> <p>Preheat Temp. <u>Room Temp 65° F. min</u></p> <p>Interpass Temp. <u>Maximum of 800° F</u></p> <p>Other _____</p>	<p>TECHNIQUE (QW-410)</p> <p>Travel Speed <u>N/A</u></p> <p>String or Weave Bead <u>stringer beads</u></p> <p>Oscillation <u>N/A</u></p> <p>Multipass or Single Pass (per side) <u>multipass</u></p> <p>Single or Multiple Electrodes <u>single electrode</u></p> <p>Other <u>See Figure No. 1 for further details</u></p>



A & M Company, Inc.
P. O. Box 3147
Wilmington, North Carolina
28406

W.P.S. No. 2
 Sheet 4 of 5

Tensile Test (QW-150)

Specimen No.	Width	Thickness	Area	Ultimate Total Load lb.	Ultimate Unit Stress psi	Character of Failure & Location
1-3587 T-1	0.489"	0.3/4"	0.1829"	9,770	53,400	Ductile Fracture Base Metal
1-3587 T-2	0.504"	0.387"	0.1950	10,270	52,700	Ductile Fracture Base Metal

Guided Bend Tests (QW-160)

Type and Figure No.	Result
Side Bend Figure 462.22	No Indications Conforms
Side Bend Figure 462.22	No Indications Conforms
Side Bend Figure 462.22	3 Indications 1/32" thru 3/32" conforms
Side Bend Figure 462.22	4 Indications 1/64" thru 3/32" conforms

Toughness Tests (QW-170)

Specimen No.	Notch Location	Notch Type	Test Temp.	Impact Values	Lateral Exp.		Drop Weight	
					% Shear	Mils	Break	No Break

Fillet Weld Test (QW-180)

Result — Satisfactory: Yes _____ No _____ Penetration into Parent Metal: Yes _____ No _____
 Macro-Results _____

Other Tests None Required

Type of Test _____
 Deposit Analysis _____
 Other _____


Welder's Name Horace Long Clock No. _____ Stamp No. _____
 Tests conducted by: Hobart Bros. Co. Weld Test Lab Laboratory Test No. T-3587

We certify that the statements in this record are correct and that the test welds were prepared, welded and tested in accordance with the requirements of Section IX of the ASME Code.

Date 6-30-80

Manufacturer A & M Company, Inc.
 By [Signature]

(Detail of record of tests are illustrative only and may be modified to conform to the type and number of tests required by the Code.)



DATE OF INSPECTION
 24 AUG. 15 SEPT 1983

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1 FROM BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.
 2 TO NAVFACENCOM
 NORFOLK, VA

14. CERTIFICATE ISSUED YES NO
 EXPIRES 24 AUG. 1984
 15. BOILER INSPECTOR
Thomas L. Lanier
 NAVY OR NATIONAL BOARD NO

BOILER DATA

3. MANUFACTURER
 NATIONAL RADIATOR

4. PROPERTY NO. 5	5. MFG. SERIAL NO. 10176	6. MFG. MODEL NO. AC-4075
7. BUILDING NO. AS-704	8. YEAR BUILT 1953	9. CAPACITY 1,610,000 BTU/HR.
10. FUEL (Check) <input type="checkbox"/> COAL <input checked="" type="checkbox"/> OIL <input type="checkbox"/> GAS		
11. PRESSURE DESIGNED 30 psi OPERATING 12 psi TEST 45 psi		
12. FEED WATER TREATMENT <input type="checkbox"/> SATISFACTORY <input type="checkbox"/> UNSATISFACTORY		13. TYPE <input type="checkbox"/> WATER TUBE <input checked="" type="checkbox"/> FIRE TUBE <input type="checkbox"/> C. I.

16. REASON FOR NOT ISSUING CERTIFICATE

17. BOILER USE
 HEATING

18. COMBUSTION CONTROL (Mfg. Name)
 HONEYWELL

19. COMBUSTION
 7.5 % CO₂ _____ % EXCESS O₂

20. FLUE GAS TEMPERATURE
 AFTER BOILER 250 °F : AFTER HEAT TRAP _____ °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER
 WATTS

22. NUMBER AND SIZE
 1-2"

23. PSI SETTING
 30

24. CONDITION
 GOOD

25. MANUFACTURER
 MARSHALL TOWN

26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
------	------------	-----------

28. MANUFACTURER DUNHAM BUSH - IRON FIREMAN	
29. TYPE NOZZLE SPRAY	
30. FUEL GRADE #2	

31. INSPECTOR'S COMMENTS
 1. BOILER SETTING AS BEFORE
 2. REPLACE ALTITUDE GAGE WITH LOWER PROBE.
 3. ADD STOP PIT.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
R.M. DeLeon

BY DIRECTION

MFGRS. SERIAL NO.

15660

TYPE OF SUPERHEATER

None

TEMPERATURE AT SUPERHEATER OUTLET

N/A °F

NORMAL FEEDWATER TEMPERATURE

N/A °F

(See Reverse Side for Fittings)

MFGRS. MODEL NO.

4FW-127-SPL LB

FURNACE VOLUME

CU. FT

HEATING SURFACE (SQ. FT.)

BOILER 120

WATER WALL

ECONOMIZER

SUPERHEATER

DRUMS

NO. _____

DIAMETER _____ IN.

LENGTH _____ FT. _____ IN.

RIVETED

FORGE WELDED

FUSION WELDED

MANUFACTURER

BURNHAM

OPERATION

- AUTOMATIC
- SEMI-AUTOMATIC
- MANUAL

PRESSURE (psig)

30 DESIGN

15 MAWP
INSTALLED WP

AIR HEATER

- NONE N/A
- TUBULAR
- REGENERATIVE
- STEAM

USE

- EXPORT
- ELEC. POWER GENERATION
- LAID UP - WET
- LAID UP - DRY
- Heating

CAPACITY

21.2 HP

_____ LB. HR

_____ EDR

885.5 M BTU/HR.

DATE OF SHEET

DATE BUILT

1984

DATE INSTALLED

5-15-85

BOILER

TYPE

- C.I.
- WATER TUBE
- FIRE TUBE

DRAFT

- NATURAL
- FORCED
- INDUCED

PRODUCES

- STEAM
- LOW TEMP. WATER
- HIGH TEMP. WATER

CIRCULATION

- NATURAL
- FORCED

FUEL & FIRING EQUIPMENT IN SERVICE

FUEL

COAL

- ANTHRACITE
- BITUMINOUS

OIL

- COMMERCIAL 1, 2, 4, 5, 6
- NAVY
- OTHER _____

GAS

- NATURAL
- MANUFACTURED

ALTERNATE FUEL & FIRING EQUIPMENT

COAL

- ANTHRACITE
- BITUMINOUS

OIL

- COMMERCIAL 1, 2, 4, 5, 6
- NAVY SPECIAL
- OTHER _____

GAS

- NATURAL
- MANUFACTURED

FIRING EQUIPMENT

COAL - HAND FIRED

COAL - STOKER

- UNDERFEED - MULTIPLE RETORT
- UNDERFEED - SINGLE RETORT
- SPREADER - DUMP GRATE
- SPREADER - VIBRATING GRATE
- SPREADER - TRAVELING GRATE
- CHAIN GRATE

GAS

- GAS RING
- VENTURI TYPE

COAL - PULVERIZER

- ATTRITION
- BALL & RACE
- BOWL MILL
- TUBULAR

OIL BURNERS

- MECHANICAL
- STEAM ATOMIZED
- AIR ATOMIZED
- ROTARY CUP

COL - HAND FIRED

COAL - STOKER

- UNDERFEED - MULTIPLE RETORT
- UNDERFEED - SINGLE RETORT
- SPREADER - DUMP GRATE
- SPREADER - VIBRATING GRATE
- SPREADER - TRAVELING GRATE
- CHAIN GRATE

GAS

- GAS RING
- VENTURI TYPE

COAL - PULVERIZER

- ATTRITION
- BALL & RACE
- BOWL MILL
- TUBULAR

OIL BURNERS

- MECHANICAL
- STEAM ATOMIZED
- AIR ATOMIZED
- ROTARY CUP

FIRING EQUIPMENT MANUFACTURER

POWER FLAME

PROPERTY NO.

5

BUILDING OR LOCATION

AS-704

BOILER 5

ACTIVITY

MCAS (H), NEW RIVER

DATA RECORD SHEET - BOILERS
NAVFAC 9-11014/40 (9-69) Supersedes NAVDOCKS 2509

FITTING	NUMBER	SIZE	MANUFACTURER	TYPE	SETTING	RANGE	PRESSURE CLASS
SAFETY VALVES	1	1½"	WATTS	MODEL M	30		
STEAM OUTLET VALVES	1	2"	GRINNELL	GATE		150	
BLOW-OFF VALVES	1	1½"	GRINNELL	GATE		150	
FEEDWATER VALVES	1	3/4"	GRINNELL	GATE		125	
WATER COLUMN	N/A						
FEEDWATER REGULATOR	1	3/4"	WATTS MOOR 335-1		12	10-25	
WATER GAGES	N/A						
STEAM GAGES	1	3"	US GAGE	ALTITUDE		0-50 PSI 60-260	
SOOT BLOWERS	N/A						
FUSIBLE PLUGS	N/A						

SAFETY VALVE - MFG WATTS SIZE 1½" CAP. 2,105,000 BTU/HR

PRIMARY CONTROL - HONEYWELL R4795D

BURNER TIP SIZE - 3.5 GPH MONARCH F 80 BPS 80°