

DATE OF INSPECTION
 21 FEB 1985

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
 BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.
 2. TO
 NAVFACENCOM
 NORFOLK, VA

14. CERTIFICATE ISSUED YES NO
 EXPIRES 21 FEB. 1987
 15. BOILER INSPECTOR
 Thomas L. Lanier
 NAVY OR NATIONAL BOARD NO.
 NAVFAC 239
 16. REASON FOR NOT ISSUING CERTIFICATE

BOILER DATA

3. MANUFACTURER
 BUCKEYE BOILER CO. (CHAMPION)

4. PROPERTY NO. PV-68	5. MFG. SERIAL NO. 020466	6. MFG. MODEL NO. N.B. 372709
7. BUILDING NO. BB-71	8. YEAR BUILT 1982	9. CAPACITY 19 CU. FT. VOLUME
10. FUEL (Check) <input type="checkbox"/> COAL <input type="checkbox"/> OIL <input type="checkbox"/> GAS	11. PRESSURE DESIGNED 200 psi OPERATING 175 psi TEST AIR 200 psi	
12. FEED WATER TREATMENT <input type="checkbox"/> SATISFACTORY <input type="checkbox"/> UNSATISFACTORY	13. TYPE <input type="checkbox"/> WATER TUBE <input type="checkbox"/> FIRE TUBE <input type="checkbox"/> C. I.	

17. BOILER USE AIR-RECEIVER	18. COMBUSTION CONTROL (Mfg. Name)
19. COMBUSTION % CO ₂ _____ % EXCESS O ₂ _____	20. FLUE GAS TEMPERATURE AFTER BOILER _____ °F ; AFTER HEAT TRAP _____ °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER ASME	22. NUMBER AND SIZE 1-1/4"	23. PSI SETTING 200	24. CONDITION GOOD
25. MANUFACTURER ASHCROFT		26. CORRECTIONS WATER LEG CONSTANT _____ psi; OTHER _____ psi	
27. REASON IF NOT TESTED			

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		
31. INSPECTOR'S COMMENTS		

START & MAINTAIN P.M. LOG.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
 J. J. Sellen
 BY DIRECTION

