

Memorandum

DATE: 12 May 1986

FROM: Supervisory Chemist, WQCL, Environmental Branch, NREAD, MCB, Camp Lejeune

TO: Supervisory Ecologist, Environmental Branch, NREAD, MCB, Camp Lejeune

SUBJ: Fred Hill's 10 and 11 April 1986 Visit

1. Most of what was discussed in Mr. Hill's report dealt with operational matters. Mr. Hill stated that "records of operations (including total water treated, filter and softener operations, chemical feed and dosage rates, etc.) should be reported monthly for each facility" to Raleigh. Apparently Utilities is not doing this.

2. In Mr. Hill's memo plant and recommends is an "A" operator. A before, but the State of the number of plants and the

Req. Para 1 "Should be" or "Must be" ??

Elizabeth A. Betz
Elizabeth A. Betz

Memorandum

TO: The Adjutant General
FROM: The Adjutant General
SUBJECT: [Illegible]

Memorandum


DATE: 12 May 1986

FROM: Supervisory Chemist, WQCL, Environmental Branch, NREAD, MCB, Camp Lejeune


TO: Supervisory Ecologist, Environmental Branch, NREAD, MCB, Camp Lejeune

SUBJ: Fred Hill's 10 and 11 April 1986 Visit

1. Most of what was discussed in Mr. Hill's report dealt with operational matters. Mr. Hill stated that "records of operations (including total water treated, filter and softener operations, chemical feed and dosage rates, etc.) should be reported monthly for each facility" to Raleigh. Apparently Utilities is not doing this.
2. In Mr. Hill's memorandum to Mr. Rundgren he classified Hadnot Point as an "A" plant and recommends that Camp Lejeune be managed by an "A" operator. Mac Frazelle is an "A" operator. As I had understood it, none of our plants were "A" plants before, but the State had strongly recommended an "A" operator as a foreman because of the number of plants and the diversified treatment processes.


Elizabeth A. Betz

SECRET DOCUMENT



NREAD COPY - file
at WQCH
008



North Carolina Department of Human Resources

Eastern Regional Office • 404 Saint Andrews Drive • Greenville, N. C. 27834

James G. Martin, Governor

Phillip J. Kirk, Jr., Secretary

April 16, 1986

Commanding General
US Marine Corps Base
Camp Lejeune, NC 28542

ATTN: Utilities Director
G. S. Johnson, Jr.

Dear Sir:

I visited the potable water treatment plant on April 10 and 11 April 1986. I was to update our files on treatment capacities, and consider improvements in the plant facilities.

The routine plant operations were carried out. I was very pleased with the work completed or now in progress.

We discussed several specific items at the water surface at the Camp Johnson facilities. (1) The maintenance level at the Tarawa Terrace and Camp Johnson facilities has dropped below the others. This is understandable, however, considering these are to be abandoned when the Holcomb Boulevard project is completed (estimated late 1986). (2) The water flow pattern at the Onslow Beach system is different from other facilities utilizing similar treatment. Normally, water is pumped from the wells through filters then through the ion exchange softeners, not divided. Additionally, filter backwash water is usually from the treated water system, not untreated well water.

We also discussed several items which may be applicable to more than one facility. These include: (1) The filters and softeners should be inspected annually for media loss and condition as well as any structural or operational abnormalities. (2) Covers for the brine (NaCl) day tanks will reduce some of the problems with surface corrosion. Installation and operation of dehumidifiers will also help this problem. (3) The existing treatment process consisting of aeration, lime addition, sedimentation, filtration (sand media), ion exchange (softening), chlorination, and phosphate (at three plants) may be altered to reduce chemical costs while maintaining acceptable quality. An in-plant or laboratory trial of the process may prove effective, depending on more detailed water quality analysis.

Review &
Comment
S. D. D.
JGW
D. J. D.



The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author outlines the various methods used to collect and analyze the data. This includes both primary and secondary data collection techniques. The analysis focuses on identifying trends and patterns over time, which is crucial for making informed decisions.

The final part of the document provides a detailed breakdown of the results. It shows that there has been a significant increase in sales volume, particularly in the latter half of the period. This is attributed to several factors, including improved marketing strategies and a strong focus on customer service.

NREAD copy - file
at WQCH
JOS



North Carolina Department of Human Resources

Eastern Regional Office • 404 Saint Andrews Drive • Greenville, N. C. 27834

James G. Martin, Governor

Phillip J. Kirk, Jr., Secretary

April 16, 1986

Commanding General
US Marine Corps Base
Camp Lejeune, NC 28542

ATTN: Utilities Director
G. S. Johnson, Jr.

Dear Sir:

I visited the potable water treatment plant on 10 and 11 April 1986. I met Mr. Frazelle, Jr. (Water Treatment Plant Supervisor) to update our files and discuss treatment capacities, and consider options for improvements in the plant facilities.

The routine plant operations were carried out. I was very pleased with the completed or now in progress work.

We discussed several specific items including: (1) The water surface at the Tarawa Terrace and Camp Johnson facilities has dropped below the others. This is understandable, however, considering these are to be abandoned when the Holcomb Boulevard project is completed (estimated late 1986). (2) The maintenance level at the Tarawa Terrace and Camp Johnson facilities has dropped below the others. This is understandable, however, considering these are to be abandoned when the Holcomb Boulevard project is completed (estimated late 1986). (3) The water flow pattern at the Onslow Beach system is different from other facilities utilizing similar treatment. Normally, water is pumped from the wells through filters then through the ion exchange softeners, not divided. Additionally, filter backwash water is usually from the treated water system, not untreated well water.

We also discussed several items which may be applicable to more than one facility. These include: (1) The filters and softeners should be inspected annually for media loss and condition as well as any structural or operational abnormalities. (2) Covers for the brine (NaCl) day tanks will reduce some of the problems with surface corrosion. Installation and operation of dehumidifiers will also help this problem. (3) The existing treatment process consisting of aeration, lime addition, sedimentation, filtration (sand media), ion exchange (softening), chlorination, and phosphate (at three plants) may be altered to reduce chemical costs while maintaining acceptable quality. An in-plant or laboratory trial of the process may prove effective, depending on more detailed water quality analysis.

JULIAN:
HERE IS A COPY FOR YOUR RECORDS OF DHS VISIT & FRKO HILL REPORT.
JGW
DWS
JK



Faint, illegible text, possibly a header or introductory paragraph.

Faint, illegible text, possibly a sub-section or a specific point.

Faint, illegible text, possibly a concluding paragraph or a signature area.

NR READ COPY - file
at WQCH
008



North Carolina Department of Human Resources

Eastern Regional Office • 404 Saint Andrews Drive • Greenville, N. C. 27834

James G. Martin, Governor

Phillip J. Kirk, Jr., Secretary

April 16, 1986

Commanding General
US Marine Corps Base
Camp Lejeune, NC 28542

ATTN: Utilities Director
G. S. Johnson, Jr.


Dear Sir:

I visited the potable water treatment facilities aboard USMCB Camp Lejeune on 10 and 11 April 1986. I was accompanied during this visit by Mr. B. M. Frazelle, Jr. (Water Treatment Operator Foreman). The purpose of this visit was to update our files and records concerning the facility operations, treatment capacities, and construction work in progress as well as offer any suggestions for improvements in the process or daily operation and maintenance at the treatment facilities.

The routine plant operation and equipment maintenance are well organized and carried out. I was very pleased with the expansion and upgrading work recently completed or now in progress at several facilities.

We discussed several specific plant situations including: (1) A light film on the water surface at the filters in the Holcomb Boulevard facility may be from oil lubricated well pumps. (2) The maintenance level at the Tarawa Terrace and Camp Johnson facilities has dropped below the others. This is understandable, however, considering these are to be abandoned when the Holcomb Boulevard project is completed (estimated late 1986). (3) The water flow pattern at the Onslow Beach system is different from other facilities utilizing similar treatment. Normally, water is pumped from the wells through filters then through the ion exchange softeners, not divided. Additionally, filter backwash water is usually from the treated water system, not untreated well water.

We also discussed several items which may be applicable to more than one facility. These include: (1) The filters and softeners should be inspected annually for media loss and condition as well as any structural or operational abnormalities. (2) Covers for the brine (NaCl) day tanks will reduce some of the problems with surface corrosion. Installation and operation of dehumidifiers will also help this problem. (3) The existing treatment process consisting of aeration, lime addition, sedimentation, filtration (sand media), ion exchange (softening), chlorination, and phosphate (at three plants) may be altered to reduce chemical costs while maintaining acceptable quality. An in-plant or laboratory trial of the process may prove effective, depending on more detailed water quality analysis



Commanding General
Page 2
April 16, 1986


and study. (4) I noticed several open electrical service panels. A standing policy should be established to close or secure these at the end of the work or shift change, especially in the water plant areas. (5) Many water systems utilizing dry feeders for fluoride prefer sodium silicofluoride (due to its cost) instead of sodium fluoride (dissolves only to 4% solution). (6) Records of operations (including total water treated, filter and softener operations, chemical feed and dosage rates, etc.) should be reported monthly for each facility to our office in Raleigh.

I understand that planning is in progress for the development of private operations contracts for the water treatment facilities. Our office, in cooperation with the NC Attorney General's office, would like to review the final contract proposal to determine the operation's responsibilities as well as the system's liabilities.

As always, I appreciate the cooperation and attitude of the Base towards the State's Water Supply Branch and regulations.

If you have any questions or wish to discuss these comments further, please contact me.

Sincerely,



J. Fred Hill
Water Plant Consultant
Water Supply Branch
Environmental Health Section

bgb

Enclosures

cc: C. E. Rundgren
M. P. Bell



North Carolina Department of Human Resources

Eastern Regional Office • 404 Saint Andrews Drive • Greenville, N. C. 27834

James G. Martin, Governor

Phillip J. Kirk, Jr., Secretary

April 16, 1986

MEMORANDUM

TO: Charles E. Rundgren, Chairman
N.C. Water Treatment Facility Operators Board of Certification

FROM: J. Fred Hill
Water Plant Consultant *JFH*

SUBJECT: Water Treatment Plant Ratings
USMC Base Camp Lejeune

Attached are the classification rating forms with the modification for lime softening with spiractors that we discussed.


The eight systems surveyed are directed, managed, and operated through a common administration and responsible operator in charge (Byron M. Frazelle, "A" certification).

I recommend the system be classified to an "A" rating based on the management organization and the diversified treatment techniques involved.

If you have any questions, please let me know.

bgb

Attachments



USMC BASE
CAMP LEJEUNE
MANAGEMENT

Operations

LtCol. W. M. Rice
Base Maintenance Officer

Fred Cone
Asst. BMO

G. S. Johnson, Jr.
Utilities Director

David Southerland
Util. General Foreman


Willard Price
General Foreman

B. M. Frazelle (Mac)
WTP Operator Foreman

Monitoring & Surveillance

Natural Resources and Environmental
Affairs Division

Julian Wooten, Director
Danny Sharpe, Supervisory Ecologist
Elizabeth Metz, Supv. Chemist




US MARINE CORPS BASE

Camp Lejeune, NC

WTP Operators

<u>Name</u>	<u>Title</u>	<u>Certification</u>
Adkins, James M.	Water Treatment Plant Operator	C-Well
Barber, Elbert F.	Water Treatment Plant Operator	C
Brown, Leland R.	Industrial Equipment Repairer	C-Well
Campbell, Emery G.	Water Treatment Plant Operator	C
Cannon, Fred J.	Water Treatment Plant Operator	C
Huneycutt, Gaines B.	Water Plant Operator	C
Collins, Philip R.	Water Treatment Plant Operator	C
Duncan, Freddy	Water Treatment Plant Operator	B
Dunlap, James	Water Plant Operator	O
Ellis, Donald R.	Water Treatment Plant Operator Leader	C
Frazelle, Byron M.	Water Treatment Plant Operator Foreman	A
Hardison, Rufus C.	Water Treatment Plant Operator	C
Hartsoe, Joel R.	Water Treatment Plant Operator Leader	B-Well
Herring, L.	Water Plant Operator	O
Hill, Daniel E., Jr.	Water Treatment Plant Operator Leader	B-Well
Holland, Larry W.	Water Treatment Plant Operator Leader	B-Well
Phillips, Major	Water Treatment Plant Operator Helper	O
James, Nathaniel L.	Water Plant Operator	O
Kelly, Calvin D., Jr.	Water Treatment Plant Operator	C
Kolde, Sally	Clerk Typist	O
Lee, Jerry J.	Water Treatment Plant Operator	C
Marhelko, Michael J.	Water Treatment Plant Operator	C
Miller, Stanley L.	Water Treatment Plant Operator Leader	B
Milton, George D.	Water Treatment Plant Operator	C
Morton, Billie L.	Water Treatment Plant Operator	B
Mundt, Berton L.	Water Treatment Plant Operator	C
Odum, Cobrett G.	Water Treatment Plant Operator	C
Parker, Leon S.	Water Treatment Plant Operator	C-Well
Pehowic, Stanley A.	Water Treatment Plant Operator Leader	B
Petersen, Larry G.	Water Treatment Plant Operator	C-Well
Christensen, Nancy	Water Treatment Plant Operator Helper	O
Price, W. R.	Utilities Systems Plant General Foreman	B
Reiff, Howard F.	Water Treatment Plant Operator	C
Rich, Melvin P.	Industrial Equipment Mechanic	C
Riggs, Alvin T.	Water Treatment Plant Operator	C
Riggs, Joseph E.	Water Treatment Plant Operator	C
Smallwood, Scottie	Water Treatment Plant Operator	C
Stone, Tally	Water Treatment Plant Operator	C
Sumner, David W.	Industrial Equipment Repairer	C-Well
Sypnier, Richard A.	Water Treatment Plant Operator	C-Well
Thomas, Tommie T.	Industrial Equipment Mechanic	C-Well
Vick, Ronnie C.	Instrument Mechanic	B-Well
Ward, William	Water Plant Operator	O
Wooten, Robert	Water Treatment Plant Operator	C-Well



NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY US MC Camp Lejeune - Holcomb Blvd.

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B-W

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A
 Grade


NAME B. M. Frazelle
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>
<u>see list</u>	

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground-----	3	<u>3</u>
Surface-----	5	
Surface with Reservoir-----	6	
Coliform Bacteria less than 1.0 per 100 ml-----	2	<u>2</u>
Coliform Bacteria 1.0 - 100 per 100 ml-----	4	
Coliform Bacteria 100 - 1000 per 100 ml-----	6	
Coliform Bacteria 1000 - 5000 per 100 ml-----	8	
Coliform Bacteria 5000 - 20000 per 100 ml-----	12	
Aeration-----	2	
Coagulation----- <u>spirator - line</u>	10	<u>10</u>
Sedimentation-----	5	
Filtration-----	10	<u>10</u>
Disinfection-----	10	<u>10</u>
Ion Exchange-----	5	
Adsorption-----	2	
Chemical Oxidation-----	2	
Softening-----	2	<u>2</u>
Stabilization-----	2	
Fluoridation-----	10	<u>10</u>
Raw Water Pumping-----	5	<u>5</u>
Receiving Basin-----	1	<u>5</u>
Finished Water Pumping-----	5	<u>5</u>
Storage at Plant-----	1	<u>1</u>
Storage - System-----	2	<u>2</u>
Pumpage - from attached chart-----	1-50	<u>12</u>
TOTAL POINTS	<u>(1,204 mg)</u>	<u>72</u>

DATE 4-10-86



NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC-Lejeune HANNOT POINT

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED A

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A
 Grade


NAME B. M. Frazelle
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground-----	3	<u>3</u>
Surface-----	5	
Surface with Reservoir-----	6	
Coliform Bacteria less than 1.0 per 100 ml-----	2	<u>2</u>
Coliform Bacteria 1.0 - 100 per 100 ml-----	4	
Coliform Bacteria 100 - 1000 per 100 ml-----	6	
Coliform Bacteria 1000 - 5000 per 100 ml-----	8	
Coliform Bacteria 5000 - 20000 per 100 ml-----	12	
Aeration-----	2	
Coagulation----- <u>Spiractor - Gmc</u>	10	<u>10</u>
Sedimentation-----	5	
Filtration-----	10	<u>10</u>
Disinfection-----	10	<u>10</u>
Ion Exchange-----	5	
Adsorption-----	2	
Chemical Oxidation-----	2	
Softening-----	2	<u>2</u>
Stabilization-----	2	
Fluoridation-----	10	<u>10</u>
Raw Water Pumping-----	5	<u>5</u>
Receiving Basin-----	1	<u>1</u>
Finished Water Pumping-----	5	<u>5</u>
Storage at Plant-----	1	<u>1</u>
Storage - System-----	2	<u>2</u>
Pumpage - from attached chart-----	1-50	<u>24</u>
TOTAL POINTS	(3,241 mbs)	<u>85</u>

DATE 4-10-86



NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC Camp Lejeune - Onslow Beach

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B-W

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE - A -
 Grade


NAME B. M. Frazelle
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>
<u>SEE LIST</u>	

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground-----	3	<u>3</u>
Surface-----	5	
Surface with Reservoir-----	6	
Coliform Bacteria less than 1.0 per 100 ml-----	2	<u>2</u>
Coliform Bacteria 1.0 - 100 per 100 ml-----	4	
Coliform Bacteria 100 - 1000 per 100 ml-----	6	
Coliform Bacteria 1000 - 5000 per 100 ml-----	8	
Coliform Bacteria 5000 - 20000 per 100 ml-----	12	
Aeration-----	2	<u>2</u>
Coagulation-----	10	
Sedimentation-----	5	
Filtration-----	10	<u>10</u>
Disinfection-----	10	<u>10</u>
Ion Exchange-----	5	<u>5</u>
Adsorption-----	2	
Chemical Oxidation-----	2	
Softening-----	2	<u>2</u>
Stabilization-----	2	
Fluoridation-----	10	
Raw Water Pumping-----	5	<u>5</u>
Receiving Basin-----	1	
Finished Water Pumping-----	5	<u>5</u>
Storage at Plant-----	1	<u>1</u>
Storage - System-----	2	<u>2</u>
Pumpage - from attached chart-----	1-50	<u>2</u>
TOTAL POINTS	<u>(.137 MG)</u>	<u>49</u>

DATE 4-10-86



NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY 115 Mc Camp Lejeune - Courthouse Bldg

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B-W

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A
 Grade

NAME B. M. Frazelle
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>
<u>see list</u>	

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground-----	3	<u>3</u>
Surface-----	5	
Surface with Reservoir-----	6	
Coliform Bacteria less than 1.0 per 100 ml-----	2	<u>2</u>
Coliform Bacteria 1.0 - 100 per 100 ml-----	4	
Coliform Bacteria 100 - 1000 per 100 ml-----	6	
Coliform Bacteria 1000 - 5000 per 100 ml-----	8	
Coliform Bacteria 5000 - 20000 per 100 ml-----	12	
Aeration-----	2	<u>2</u>
Coagulation-----	10	
Sedimentation-----	5	
Filtration-----	10	<u>10</u>
Disinfection-----	10	<u>10</u>
Ion Exchange-----	5	<u>5</u>
Adsorption-----	2	
Chemical Oxidation-----	2	
Softening-----	2	
Stabilization-----	2	<u>2</u>
Fluoridation-----	10	
Raw Water Pumping-----	5	<u>5</u>
Receiving Basin-----	1	
Finished Water Pumping-----	5	<u>5</u>
Storage at Plant-----	1	<u>1</u>
Storage - System-----	2	<u>2</u>
Pumpage - from attached chart-----	1-50	<u>5</u>
	(.452 mb)	
TOTAL POINTS		<u>52</u>

DATE 4-10-86

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC - Camp Lejeune - Rifle Range

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B-W

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A
 Grade


NAME B. M. FRACELLE
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>
<i>see list</i>	

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground-----	3	<u>3</u>
Surface-----	5	
Surface with Reservoir-----	6	
Coliform Bacteria less than 1.0 per 100 ml-----	2	<u>2</u>
Coliform Bacteria 1.0 - 100 per 100 ml-----	4	
Coliform Bacteria 100 - 1000 per 100 ml-----	6	
Coliform Bacteria 1000 - 5000 per 100 ml-----	8	
Coliform Bacteria 5000 - 20000 per 100 ml-----	12	
Aeration-----	2	<u>2</u>
Coagulation-----	10	
Sedimentation-----	5	
Filtration-----	10	<u>10</u>
Disinfection-----	10	<u>10</u>
Ion Exchange-----	5	<u>5</u>
Adsorption-----	2	
Chemical Oxidation-----	2	
Softening-----	2	
Stabilization-----	2	<u>2</u>
Fluoridation-----	10	
Raw Water Pumping-----	5	<u>5</u>
Receiving Basin-----	1	<u>5</u>
Finished Water Pumping-----	5	<u>5</u>
Storage at Plant-----	1	<u>1</u>
Storage - System-----	2	<u>2</u>
Pumpage - from attached chart-----	1-50	<u>3</u>
	(.262 mb)	
TOTAL POINTS		<u>50</u>

DATE 4-10-80



NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC - 6000000 TARRAW TERRACE

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B-1

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A
 Grade

NAME B.M. Frazzle
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground-----	3	<u>3</u>
Surface-----	5	
Surface with Reservoir-----	6	
Coliform Bacteria less than 1.0 per 100 ml-----	2	<u>2</u>
Coliform Bacteria 1.0 - 100 per 100 ml-----	4	
Coliform Bacteria 100 - 1000 per 100 ml-----	6	
Coliform Bacteria 1000 - 5000 per 100 ml-----	8	
Coliform Bacteria 5000 - 20000 per 100 ml-----	12	
Aeration-----	2	
Coagulation----- <u>lime - spiractor</u>	10	<u>10</u>
Sedimentation-----	5	
Filtration-----	10	<u>10</u>
Disinfection-----	10	<u>10</u>
Ion Exchange-----	5	
Adsorption-----	2	
Chemical Oxidation-----	2	
Softening-----	2	<u>2</u>
Stabilization-----	2	
Fluoridation-----	10	<u>10</u>
Raw Water Pumping-----	5	<u>5</u>
Receiving Basin-----	1	
Finished Water Pumping-----	5	<u>5</u>
Storage at Plant-----	1	<u>1</u>
Storage - System-----	2	<u>2</u>
Pumpage - from attached chart-----	1-50	<u>2</u>
TOTAL POINTS	<u>(812 msl)</u>	<u>68</u>

DATE 4-10-86

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC - Camp Johnson

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B-W

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A
 Grade

NAME B. M. Ferrell
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground-----	3	2
Surface-----	5	
Surface with Reservoir-----	6	
Coliform Bacteria less than 1.0 per 100 ml-----	2	2
Coliform Bacteria 1.0 - 100 per 100 ml-----	4	
Coliform Bacteria 100 - 1000 per 100 ml-----	6	
Coliform Bacteria 1000 - 5000 per 100 ml-----	8	
Coliform Bacteria 5000 - 20000 per 100 ml-----	12	
Aeration-----	2	
Coagulation-----	10	
Sedimentation-----	5	
Filtration-----	10	
Disinfection-----	10	10
Ion Exchange-----	5	5
Adsorption-----	2	
Chemical Oxidation-----	2	
Softening-----	2	
Stabilization-----	2	2
Fluoridation-----	10	2
Raw Water Pumping-----	5	
Receiving Basin-----	1	5
Finished Water Pumping-----	5	5
Storage at Plant-----	1	1
Storage - System-----	2	2
Pumpage - from attached chart-----	1-50	2
(340 n16)		
TOTAL POINTS.		41

DATE 4-10-86

NORTH CAROLINA DEPARTMENT OF HUMAN RESOURCES
 WATER TREATMENT FACILITY OPERATORS BOARD OF CERTIFICATION
 RATING VALUES FOR CLASSIFICATION OF WATER SUPPLY WORKS

NAME OF WATER TREATMENT FACILITY USMC - EMPLOYEES - NEW RIVER AIR STATION

CLASSIFICATION ASSIGNED FACILITY AND LEVEL OF CERTIFICATE REQUIRED B.W

GRADE CERTIFICATE HELD BY OPERATOR IN RESPONSIBLE CHARGE A
 Grade

NAME B.M. FRAZELLE
 (Operator)

OTHER OPERATORS

<u>NAME</u>	<u>GRADE CERTIFICATE HELD IF ANY</u>
<u>SEE LIST</u>	

<u>UNIT</u>	<u>RATING VALUE</u>	<u>ASSIGNED VALUE</u>
Ground-----	3	3
Surface-----	5	5
Surface with Reservoir-----	6	6
Coliform Bacteria less than 1.0 per 100 ml-----	2	2
Coliform Bacteria 1.0 - 100 per 100 ml-----	4	4
Coliform Bacteria 100 - 1000 per 100 ml-----	6	6
Coliform Bacteria 1000 - 5000 per 100 ml-----	8	8
Coliform Bacteria 5000 - 20000 per 100 ml-----	12	12
Aeration-----	2	2
Coagulation- <u>SPIRATOR - LIME</u> -----	10	10
Sedimentation-----	5	5
Filtration-----	10	10
Disinfection-----	10	10
Ion Exchange-----	5	5
Adsorption-----	2	2
Chemical Oxidation-----	2	2
Softening-----	2	2
Stabilization- <u>RECARBONATION</u> -----	2	2 (2)
Fluoridation-----	10	10
Raw Water Pumping-----	5	5
Receiving Basin-----	1	1
Finished Water Pumping-----	5	5
Storage at Plant-----	1	1
Storage - System-----	2	2
Pumpage - from attached chart-----	1-50	9
TOTAL POINTS	(876 MGD)	59 (61)

DATE 4-10-86

DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES

WELL NO. _____

WELL INFORMATION

ID NO. _____

1) WELL SITE: Owned or controlled (100' radius)? OK - ALL WELLS

Sources of pollution/distance controlled by USMC

Adequate slope? _____ Flooding? _____

2) WELL HOUSE: Free of stored materials? yes

Properly drained? _____ Freeze protection? _____

Condition of house OK Locked? yes

3) WELL: Diameter VARIED Type const. _____ Yield (GPM) Varies Storage at well _____

Properly sealed? _____ Properly vented? _____

26 wells

Casing depth _____ Well depth _____ Meter Available? @ WTP

Concrete slab adequate? _____ Size Aux Eng @ 7 wells

Size of blow-off _____ Sample tap available yes

4) PUMP: Capacity Max 400 MIN 50 Avg 104 Type pump VERT TURB (High Service) 2 @ 1000 gpm
1 @ 500 gpm

Height above floor (pump/casing) _____ Is pump leaking? BOOSTERS 2 @ 125 gpm
2 @ 750 gpm

5) TREATMENT: Is this a central treatment facility? yes (one of eight)

Chlorinator: Type W & T GAS (T-CONT) Capacity 18/200 ppd In Service? yes

Spare parts or unit? SPARE w/200 ppd Proper ventilation? yes Gas Mask? AIR PACK; REPAIR KIT; ALARMS.

RECARBONATION

Facilitator: Type NATURAL GAS (SUBMERGED) Condition OK

Filter(s): Type GRAVITY (NO RATE CONTROLS) 3 ea Media SAND & ANTHRACITE

Size 17'x23' Rate (gpm/ft²) _____ Head loss B/W @ 2.5-3.0 OR 48 hrs

Type controls B/W controls only Condition OK w/surface wash

Comments filter rate changes based on C.O.H. filter overflow thru recarb. unit

Softeners: Type SPIRATORS No. 2 Media SAND - CATALYST

Size _____ Rate (gpm/ft²) 1200 gpm ea Head loss _____

Type controls USES HYDRATED LIME Condition OK (BULK STORAGE)

Comments LIME SLAKER - SPARE UNIT

Other treatment (Describe): _____

Process Wastewater treatment (Describe): TO SAN SW2

6) REMARKS AND RECOMMENDATIONS Aux generator @ WTP

DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
WELL INFORMATION

WELL NO. _____

ID NO. _____

1) WELL SITE: Owned or controlled (100' radius)? OK - ALL wells

Sources of pollution/distance CONTROLLED by USMC

Adequate slope? _____ Flooding? _____

2) WELL HOUSE: Free of stored materials? YES

Properly drained? _____ Freeze protection? _____

Condition of house OK Locked? YES

3) WELL: Diameter VARIED Type const. GRAVEL Yield (GPM) VARIED Storage at well NO

Properly sealed? _____ Properly vented? _____

8 wells

Casing depth _____ Well depth _____ Meter Available? @ WTP

Concrete slab adequate? _____ Size As a 5 wells

Size of blow-off _____ Sample tap available? YES

4) PUMP: Capacity 40 ^{MIN} 200 ^{MAX} 115 ^{AVG} Type pump: VERT TURBS. (service pumps - 1250 gpm (w/aux)

Height above floor (pump/casing) _____ Is pump leaking? 1000 gpm
500 gpm

5) TREATMENT: Is this a central treatment facility? yes (one of eight)

Chlorinator: Type WAT gas (150#) Capacity 10/30 ppd In Service? yes

Spare parts or unit? spare unit (50 ppd) Proper ventilation? yes Gas Mask? AIR PACK, REPAIR KIT, Cl₂ ALERT.

Aerator: Type NONE Condition _____

Filter(s): Type NONE No. _____ Media _____

Size _____ Rate (gpm/ft²) _____ Head loss _____

Type controls _____ Condition _____

Comments _____

Softeners: Type ION EXCHANGE No. 2 Media Na Zeolite

Size 72" Ø Rate (gpm/ft²) 180 ea Head loss ± 10

Type controls _____ Condition fair (some leaks)

Comments Regen. @ 046 Hg - Bulk salt tank w/ day tank inside WTP

Other treatment (Describe): Phosphate - BIF food pump (2 gal/20 gal H₂O) (1.0 mg/l ORING POU)

Process wastewater treatment (Describe): dischg to SAN. SWIR

6) REMARKS AND RECOMMENDATIONS ① valves leaking at softener ② to be phased out for Bif

WELL NO. _____

ID NO. _____

1) WELL SITE: Owned or controlled (100' radius)? OK - All wells

Sources of pollution/distance sites controlled by USMC

Adequate slope? _____ Flooding? _____

2) WELL HOUSE: Free of stored materials? yes

Properly drained? _____ Freeze protection? _____

Condition of house OK Locked? yes

3) WELL: Diameter varies Type const. gravel Yield (GPM) 111 → 236 Storage at well no

Total 9 Properly sealed? yes Properly vented? _____

6 wells Casing depth _____ Well depth _____ Meter Available? _____

3 wells Emer. only Concrete slab adequate? _____ Size _____

Size of blow-off _____ Sample tap available Aux entry @ 2 wells

4) PUMP: Capacity 111 ^{min} 236 ^{Max} 141 ^{AVG} Type pump VERT TURB.

Height above floor (pump/casing) _____ High Service Pumps
is pump leaking? 1200 gpm (w/aux pump)

5) TREATMENT: Is this a central treatment facility? yes (1 of 8)

Chlorinator: Type W&T gas Capacity 50 ppd In Service? yes
operating 18

Spare parts or unit? spare unit Proper ventilation? yes Gas Mask? AIR pack, Repair Kit & Alert.

Aerator: Type NONE Condition _____

Filter(s): Type PRESSURE No. 6 Media SAND

Size 84" Ø Rate (gpm/ft²) 127 gpm ea Head loss ±5-10 lbs

Type controls _____ Condition _____

Comments BACKWASHED daily - Access openings in filter sides

Softeners: Type SPIRACTOR No. 1 Media SAND-catalyst

Size 1.0 MGD Rate (gpm/ft²) _____ Head loss _____

Type controls Hydrated lime - BAGS Condition MIXER MOTOR NOISY

Comments _____

Other treatment (Describe): NaF - in line solution before SATURATOR - meter on fill line
W&T 747 pump

Process Wastewater treatment (Describe): dischg to SAN. SWR

6) REMARKS AND RECOMMENDATIONS Plat to see recommendations on 3-

DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES

WELL INFORMATION

WELL NO. _____

ID NO. _____

- 1) WELL SITE: Owned or controlled (100' radius)? OK - All wells
Sources of pollution/distance none - controlled by USMC
Adequate slope? _____ Flooding? _____
- 2) WELL HOUSE: Free of stored materials? yes
Properly drained? _____ Freeze protection? yes
Condition of house OK Locked? yes
- 3) WELL: Diameter varies Type const. GRAVEL Yield (GPM) varies Storage at well _____
Properly sealed? _____ Properly vented? TOTAL 756 gpm
4 wells Casing depth _____ Well depth _____ Meter Available? yes
Concrete slab adequate? _____ Box drive @ 2 wells
Size of blow-off _____ Sample tap available yes
- 4) PUMP: Capacity MIN 104 MAX 300 AVG 189 Type pump VERT TURB (high service in WTP)
Height above floor (pump/casing) _____ Is pump leaking? _____
- 5) TREATMENT: Is this a central treatment facility? yes (one of eight)
Chlorinator: Type W/T GAS (150# cyl) Capacity 18/100 ppd In Service? yes (manifold system)
Spare parts or unit? SPARE @ 30 ppd Proper ventilation? yes Gas Mask? AIRPACK, ALERT, REPAIR KIT
Aerator: Type PERMUTIT FORCED DRAFT Condition fan OK - DETENTION TANK @ UNIT
Filter(s): Type PRESSURE (PERMUTIT) No. 3 Media SAND
Size 96" Ø Rate (gpm/ft²) 134 gpm/ft² Head loss 5'
Type controls MULTIPOINTS Condition OK - ALL CONTROLS NOT AUTOMATIC
Comments B/W ea 3rd day
Softeners: Type PERMUTIT No. 2 Media Na Zeolite
Size 60" Ø Rate (gpm/ft²) 128 gpm/ft² Head loss 5-8'
Type controls MULTIPOINT Condition OK
Comments REGENERATE @ 1100 MG - BRINE DAY TANK INSIDE WTP
Other treatment (Describe): lime feed for pH control & Fe reduction
Process Wastewater treatment (Describe): dischg. to SAN. SWR
- 6) REMARKS AND RECOMMENDATIONS _____

DEPARTMENT OF HUMAN RESOURCES
 DIVISION OF HEALTH SERVICES
 WELL INFORMATION

WELL NO. _____

ID NO. _____

1) WELL SITE: Owned or controlled (100' radius)? OK - ALL WELLS

Sources of pollution/distance CONTROLLED BY USMC

Adequate slope? _____ Flooding? _____

2) WELL HOUSE: Free of stored materials? YES

Properly drained? _____ Freeze protection? YES

Condition of house _____ Locked? YES

3) WELL: Diameter VARIES Type const. _____ Yield (GPM) VARIES Storage at well _____

Properly sealed? _____ Property sealed? TOTAL 777 gpm

5 wells Casing depth _____ Well depth _____ Meter Available? @ WTP

Concrete slab adequate? _____ Size _____

Size of blow-off _____ Sample tap available YES

4) PUMP: Capacity MIN 104 gpm MAX 240 ~~AV~~ 155 Type pump VERT TURIS

Height above floor (pump/casing) _____ Is pump leaking? hi service pumps 2 @ 500 gpm

1 @ 750 w/aux. drive

5) TREATMENT: Is this a central treatment facility? YES (one of eight)

Chlorinator: Type W&T Capacity 15/100 ppd In Service? YES

Spare parts or unit? SPARE 100 ppd Proper ventilation? YES Gas Mask? AIR PACK, ALERT, REPAIR KIT

Aerator: Type PERMIT FORCED DRAFT Condition FAN OK - DETENTION TANK

Filter(s): Type PERMIT - PRESSURE No. 6 Media _____

Size 96" Ø Rate (gpm/ft²) 94 gpm ea Head loss ± 5 #

Type controls MULTIPOINT Condition OK

Comments BACKWASHED DAILY

Softeners: Type PERMIT No. 4 Media Na Zeolite

Size 72" Ø Rate (gpm/ft²) 102 gpm ea Head loss 5 #

Type controls MULTIPOINT Condition OK

Comments REGENERATED @ 100 MG

Other treatment (Describe): Lime (hydrated to slurry & pump - pH coated for Fe reduction)

Process Wastewater treatment (Describe): Phosphate NOT IN SERVICE

LT settling pond - diseng. to ditch

6) REMARKS AND RECOMMENDATIONS _____

- ① BRINE DAY TANK INSIDE BLDG. SHOULD HAVE COVER
- ② LIME & PDK NOT NECESSARY TOGETHER (SHOULD PERFORM IN-PLANT TRIALS TO DETERMINE IF LIME MAY BE DISCONTINUED)
- ③ INSPECT FILTERS & SOFTENERS ANNUALLY FOR MEDIA & INTERIOR CONDITION

DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES

WELL INFORMATION

WELL NO. _____

ID NO. _____

1) WELL SITE: Owned or controlled (100' radius)? OK - ALL wells
Sources of pollution/distance controlled by USMC
Adequate slope? _____ Flooding? _____

2) WELL HOUSE: Free of stored materials? yes
Properly drained? _____ Freeze protection? _____
Condition of house OK Locked? yes

3) WELL: Diameter VARIES Type const. GRAVEL Yield (GPM) VARIES Storage at well _____
Properly sealed? _____ Properly vented? TOTAL 369 gpm

2 wells Casing depth _____ Well depth _____ Meter Available? yes
Concrete slab adequate? _____ sim Aux @ 1 well
Size of blow-off _____ Sample tap available yes

4) PUMP: Capacity MAX 210 MIN 159 ALA # 185 Type pump VERT TURB
Height above floor (pump/casing) _____ service pumps
1 @ 1000 gpm (w/aux drive)
1 @ 750

5) TREATMENT: Is this a central treatment facility? yes (one of eight) 1 @ 300
Chlorinator: Type W&T gas (150#) Capacity 10/30 ppd In Service? yes

Spare parts or unit? spare 1 @ 50 ppd Proper ventilation? yes Gas Mask? AIR PACK, AKET, Repair Kit
Aerator: Type Pressurized - in line unit Condition OK - uses AIR COMPRESSOR

Filter(s): Type Calgon (Pressure units) No. 2 Media Sand
Size 48" Ø Rate (gpm/ft²) 37 gpm ea Head loss ± 5'
Type controls Manual cycle Condition OK

Comments Backwashed at .030 mg - Uses raw water for B/W

Softeners: Type Calgon No. 2 Media Na Zeolite
Size 42" Ø Rate (gpm/ft²) 75 gpm ea Head loss ± 5'
Type controls Manual cycle Condition OK - New Resin in 1977

Comments Regenerated @ .080 mg

Other treatment (Describe): _____

Process Wastewater treatment (Describe): Settling pond - pumped to ditch

6) REMARKS AND RECOMMENDATIONS ① Should use TAP water for B/W ② Flow pattern S/B changed - now split thru filters & softeners - should All be thru filters then softener (Extend resin life & Reduce iron in dist. system)

DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
WELL INFORMATION

WELL NO. _____

ID NO. _____

1) WELL SITE: Owned or controlled (100' radius)? ok - all wells

Sources of pollution/distance controlled by USMC

Adequate slope? _____ Flooding? _____

2) WELL HOUSE: Free of stored materials? yes

Properly drained? _____ Freeze protection? _____

Condition of house OK Locked? yes

3) WELL: Diameter varies Type const. GRAVEL Yield (GPM) VARIES Storage at well NO

Properly sealed? _____ Properly vented? TOTAL - 7224 gpm

35 wells Casing depth _____ Well depth _____ Meter Available? @ WTP

Concrete slab adequate? _____ AUX @ 18 wells

Size of blow-off _____ Sample tap available _____

4) PUMP: Capacity MAX 450 MIN 105 AVG 350 Type pump VERT TURB (service pumps 1 @ 3000 gpm 3 @ 1500 gpm (2w/aux pwr))

Height above floor (pump/casing) _____ Is pump leaking? _____

5) TREATMENT: Is this a central treatment facility? yes (one of eight)

Chlorinator: Type WET GAS Capacity 50/200 ppd In Service? yes

Spare parts or unit? spare unit (200ppd) Proper ventilation? yes Gas Mask? AIRPK, repair kit cl₂ ALERT

Recarbonation Acetator Type PROPANE GAS - SUBMERGED Condition NEW - '85

Filter(s): Type GRAVITY No. 5 Media SAND-ANTHRACITE

Size 350 # ea Rate (gpm/ft²) 2.0 Head loss 3/4 @ 5 ft.

Type controls NEW Condition GOOD

Comments SURFACE WASH ea. FILTER

Softeners: Type SPIRATORS No. 5 Media SAND-catalyst

Size HYDRAP LIME (WT) Rate (gpm/ft²) 1.0 MGD ea Head loss _____

Type controls 6 feed pumps 1000 # Lime / MG H₂O Condition _____

Comments _____

Other treatment (Describe): WET NaF-GRAVIMETRIC (New '85)

Process Wastewater treatment (Describe): NEW - 3/4 to holding BASIN - sludge to SAN SWR

Supnat. to RAW WATER

6) REMARKS AND RECOMMENDATIONS _____

Maintains pH @ 8.8 for stability

DEPARTMENT OF HUMAN RESOURCES
 DIVISION OF HEALTH SERVICES
 WELL INFORMATION

WELL NO. _____

ID NO. _____

1) WELL SITE: Owned or controlled (100' radius)? OK - All wells

Sources of pollution/distance None - controlled by USMC

Adequate slope? _____ Flooding? _____

2) WELL HOUSE: Free of stored materials? yes

Properly drained? yes Freeze protection? yes

Condition of house OK Locked? yes

3) WELL: Diameter varies Type const. GRAVEL Yield (GPM) varies Storage at well NO

Properly sealed? _____ Properly vented? Total 1800 gpm

8 wells

Casing depth _____ Well depth _____ Meter Available? @ WTP

Concrete slab adequate? _____ Size Aux only @ 4 wells

Size of blow-off _____ Sample tap available _____

4) PUMP: Capacity Min 133 Max 350 Avg 225 Type pump VERT TURBINE (usual)

Height above floor (pump/casing) _____ High serv. pumps 2 @ 700 gpm 2 @ 1500 gpm
 Is pump leaking? (Aux avail on each)

5) TREATMENT: Is this a central treatment facility? yes (one of eight)

Chlorinator: Type WET gas Capacity 1 @ 50 operated @ 2 @ 100 35ppm In Service? yes

Spare parts on unit? 3 units Proper ventilation? yes Gas Mask? yes; Respirator KIT & alert system

Aerator: Type NONE Condition _____

Filter(s): Type GRAVITY No. 2 Media RAPID SAND

Size 18 X 20' Rate (gpm/ft²) 2.0 usual Head loss _____

Type controls ROBERTS- Condition good

Comments all controls & meters OK; surface sweeps in each

Softeners: Type SPIRATOR No. 2 Media CATALYST (SAND)

Size 700 gpm (ea) Rate (gpm/ft²) _____ Head loss _____

Type controls HYDRATED lime - Bulk Condition good

Comments _____

Other treatment (Describe): NaF with gravimetric feeder - calibrated ea shift

Process Wastewater treatment (Describe): settling pond - disch to SAN. SWR.

6) REMARKS AND RECOMMENDATIONS Oil film on filters may be from oil lubricated pumps - SR careful. (2) Be careful with NaF (most use Na2SiF6)

Memorandum

11330
NREAD(L)

DATE: 9 June 1986

FROM: Supervisory Chemist, Water Quality Control Laboratory, Environmental
Branch, NREAD
TO: The Record

SUBJ: PHONCON with Cmdr Rocha, Naval Dental Clinic

REF: (a) OPNAVINST 11330.3 Of 1 Aug 1973

1. On 6 June 1986, I called Cmdr Rocha, officer in charge of the Naval Dental Clinic, to discuss what laboratory analysis he required for compliance with the reference.
2. Cmdr Rocha stated that the reference was old but current and required the following fluoride analysis: [1] Daily tests in the raw and treated water at the plant. [2] A monthly distribution sample. [3] A semi-annual distribution sample at the furthestest point.
3. I asked Cmdr Rocha if he had any problem accepting the daily fluoride readings from Utilities, since they use the same procedure as the laboratory. Cmdr Rocha stated that as long as the results were in writing he didn't much care where they were from. He also added that the daily results could be compiled and forwarded weekly.
4. The reference has no requirement for semi-annual well fluorides.

Elizabeth A. Betz

1900

1900

1900

6 JUN 1986

CMDE ROCHA -

1. OPNAVINST 11330.1 OF 1 AUG 1973 IS CURRENT, OLD BUT CURRENT.
2. REGS REQUIRE:
 - A. DAILY TESTS ~~OF~~ FOR FLUORIDE WHERE IT IS FEED.
 - i. RAW
 - ii TREATED
 - B. MONTHLY DISTRIBUTION SAMPLE
 - C. SEMIANNUAL FAR-POINT DISTRIBUTION SAMPLE
3. HE RECOMMENDED THAT FOR THE MONTHS OF JULY AND AUGUST THE ~~LIMIT~~ ~~BE~~ MAXIMUM LIMIT BE 0.8
4. THE DAILY DATA CAN BE FORWARDED WEEKLY. ~~AND FROM~~
5. HE DIDN'T CARE WHETHER THE RESULTS WERE PROVIDED BY UTILITIES OR NREA AS LONG AS THEY WERE IN WRITING

1. Introduction

The purpose of this study is to investigate the effects of...

The study was conducted over a period of six months...

The results of the study are as follows:

1. The first finding is that there is a significant correlation between...

2. The second finding is that the majority of participants...

3. The third finding is that...

4. The fourth finding is that the data suggests a positive impact of...

5. The fifth finding is that the study identified several limitations...

6. The sixth finding is that the research highlights the need for further...

7. The seventh finding is that the study provides valuable insights into...

8. The eighth finding is that the research supports the hypothesis that...

Conclusion