

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
<i>4195</i>	<i>12-18-74</i>	<i>2,505</i>	REMOVE <i>PROCURE CONTRACT TO REPAIR MOTOR GEN</i>
<i>3541</i>	<i>9-12-75</i>	<i>434</i>	<i>Replace floor type closers</i>
<i>5260</i>	<i>5-16-75</i>		<i>Replace 400 cycle motor generator</i>
<i>4959</i>	<i>5-9-75</i>	<i>4856</i>	<i>Interior Paint</i>
<i>4498</i>	<i>7-22-77</i>	<i>859</i>	<i>Repair A/C Compressor</i>
<i>9-101</i>	<i>9-10-80</i>		
<i>4147</i>	<i>3-3-78</i>	<i>309</i>	<i>Rpr. A/c compressor</i>
<i>4198</i>	<i>12-28-79</i>	<i>1424</i>	<i>Replc floor tile complete in Rm 134</i>
<i>2550</i>	<i>9-21-79</i>	<i>2000</i>	<i>reat entire bldg for termite</i>
<i>3549</i>	<i>2-23-79</i>	<i>978</i>	<i>Rm + Replc condensate pumping unit</i>
<i>3233</i>	<i>Comp</i>	<i>274</i>	<i>Assst fire dept to test & flush sprinkler system</i>
<i>3106</i>	<i>Comp</i>	<i>4444</i>	<i>Repr air conditioner</i>
<i>1008</i>	<i>6-5-81</i>	<i>2423</i>	<i>Installation of hood, exhausted & paint</i>
<i>4229</i>	<i>10-7-82</i>	<i>2415</i>	<i>Remove block wall</i>
<i>3083</i>	<i>10-1-81</i>	<i>1499</i>	<i>Repair, calibrate & test Johnson controls system</i>
<i>1145</i>	<i>6-12-81</i>	<i>232</i>	<i>install partition</i>
<i>3148</i>	<i>12-4-81</i>	<i>1248</i>	<i>alter electrical service for 400Hz converter</i>
<i>1106</i>	<i>2-4-81</i>	<i>1576</i>	<i>Install block wall, hang door & paint</i>
<i>3476</i>	<i>6-19-81</i>	<i>17,592</i>	<i>Remove & Replace 400 Hz Frequency changer</i>
<i>4070</i>	<i>6-19-81</i>	<i>1082</i>	<i>Repair A/C system</i>
<i>4058</i>	<i>6-5-81</i>	<i>1000</i>	<i>Replace damage P.R.V on steam service</i>
<i>2025</i>	<i>4-10-81</i>	<i>390</i>	<i>fab & install 16 projection screen wall mount</i>
<i>3097</i>	<i>3-27-81</i>	<i>2189</i>	<i>Replace metal door & frame, paint up boiler</i>
<i>3920</i>	<i>6-28-82</i>	<i>4503</i>	<i>ROR A/C</i>
<i>E-841</i>	<i>Op</i>	<i>2775</i>	<i>Cyclic Maint</i>
<i>4963</i>	<i>7-30-85</i>	<i>2210</i>	<i>Misc, struct, mech, elect, sps</i>

