









REVISIONS			
SYM	DESCRIPTION	DATE	APPROVED



- LEGEND**
- ⊗ EXISTING MOTOR AND HORSEPOWER INDICATED
 - NEW DISCONNECT SWITCH
 - EXISTING DISCONNECT SWITCH
 - ⊞ NEW 112.5 KVA, 480/240/120/60/30 3Ø 4W DRY TYPE TRANSFORMER
 - ⊞ NEW 60AMP COND CENTER
 - ⊞ NEW JUNCTION BOX
 - ⊞ NEW 22.5 AMP, 240/120/60/30 1Ø/2Ø MINN BREAKER PANEL BOARD
 - ⊞ EXISTING COMBINATION STARTER CONTROL
 - ⊞ SECTION DETAIL. DETAIL NUMBER OR LETTER. SHEET DETAILS DRAWN ON SHEET. DETAIL ORIGINATED ON.
 - ⊞ ELEVATION DETAIL.
 - ⊞ PLAN VIEW DETAIL.
 - ⊞ INSERTED WITH THE TITLE OF DETAIL DRAWING.
 - EXISTING CONDUCTOR AND CONDUIT.
 - NEW CONDUCTORS AND CONDUIT. IF EXISTING CONDUIT IS USED IT WILL BE INDICATED.



NOTES
THE NEW CONDUCTORS FEEDING INTO THE EXISTING WIRE TRAY WILL ONLY SERVICE THE EXISTING LINE PUMP COMBINATION STARTER CONTROLS.



PUBLIC WORKS DEPT. MARINE CORPS BASE CAMP LEJEUNE, N.C.		DEPARTMENT OF THE NAVY NAVAL FACILITIES ENGINEERING COMMAND ATLANTIC DIVISION	
DESIGNED BY: [Signature]		DRAWN BY: [Signature]	
APPROVED: [Signature]		DATE: [Date]	
SATISFACTORY TO: [Signature]		DATE: [Date]	
COMMANDING GENERAL: [Signature]		SIZE: [Size]	
APP'D: [Signature]		CODE IDENT NO: [Code]	
DATE: [Date]		F 80091	
FOR COMMANDER, NAEPIC		SCALE: [Scale]	
SHEET NO. [Number]		SHEET TOTAL [Total]	



