

NAVAL REGIONAL MEDICAL CENTER; CAMP LEJEUNE, N. C.
REVIEWERS COMMENTS
SUBMITTAL 555-A & 556-A FOOD SERVICE EQUIPMENT

1. Dishwasher assembly (Item #59) is required to have the following functions or capacities:
 - A. Prewash function (not provided in submittal)
 - B. 234 rack per hour capacity (180 rack per hour capacity submittal)
 - C. 1.2 gal. per rack rinse. (1.6 gal. per rack proposed which increased hot water consumption 33%)
 - D. 1-1/2 H.P. Pump Motors (1 H.P. proposed)
 - E. Stainless steel frame (not indicated on submittal)
 - F. Condensate catch pan in vent hoods (not indicated on submittal)
 - G. 2 H.P. Blower/Dryer w/heater and enclosed dryer section chamber.
(Proposed unit has 3/4 H.P. fan with forced air into open rack area.)
 - H. Automatic fill (not indicated on submittal)
 - I. 12 Foot long overshef (2 smaller shelves bolted together submitted)
2. Provide additional electrical service as required for Item #29 at no additional cost to the Government.
3. Items by Shelley Manufacturing Co. shall be of Chocolate (N-075) color.
4. Provide rough-in drawings showing "... the exact location of all plumbing, gas, steam, and electrical conduit penetrations in the concrete floor and walls." (See 11400-2.2.2)

