

CONTRACTOR'S SUBMITTAL TRANSMITTAL
SECTION 11705

file 580 B thru 12/3
REC

5ND LANTDIV 4-4355/3 (Rev. 6/76)

CONTRACT NO. 1-02675-77-6-7023
TRANSMITTAL NO. 583-B
DATE 9-29-80

FROM CONTRACTOR
Cardinal Contr. Co.
TO
Lockwood Greene, Engrs.

PROJECT TITLE AND LOCATION
NAVAL REGIONAL MED. CTR
Camp Lejeune, N.C.

CONTRACTOR USE ONLY

*List only one specification division per form.

List only one of the following categories on each transmittal form and indicate which is being submitted

- Contractor Approved
- OICC Approval

Lockwood Greene Engineers
RECEIVED
OCT 2 1980
ACK

REVIEWER USE ONLY

- ACTION CODES
- A-Approved
 - D-Disapproved
 - AN-Approved as noted
 - RA-Receipt acknowledged.
 - C-Comments
 - R-Resubmit

ITEM NO	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES	REVIEWER'S INITIALS CODE AND DATE
580B	3.1	Jewett Co. Letter, 7/16/80	7	AJ	15 12/1/80
Thru		Cardinal C.C. - Elect. Power Require.	7		
583-B		Confirmation #25			
"	"	Jewett Co. Dwgs. Revised 7/80			
		SR-1408-2A; SR-1408-2B; and	7		
		BR-776			

CONTRACTOR'S COMMENTS

581-B 3.1 Copeland Condensing Unit-Lit. 7
Bohn Unit Coolers-Lit. 7

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

9-29-80

W.M.J. Haymaker

DATE RECEIVED BY REVIEWER

FROM (Reviewer)

3 Nov 80

LANTDIV

TO

CARDINAL CONT Co.

Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.

Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS

SEE NOTES ON ATTACHED JEWETT Co. LETTER

2333

COPIES TO:
ROICC (2)
LANTDIV (1)
A-E (1)

DATE


12 Nov 80

SIGNATURE

J.P. Miller

2333





CONTRACTOR'S SUBMITTAL TRANSMITTAL

5ND LANTDIV 4-4355/3 (Rev. 6/76)

SECTION 11705

580 B thru

CONTRACT NO. N-62470-77-C-7526	TRANSMITTAL NO. 583-B	DATE 9-29-80
-----------------------------------	--------------------------	-----------------

FROM CONTRACTOR
Cardinal Contr. Co.
TO
Lockwood Greene, Engrs.

PROJECT TITLE AND LOCATION
*NAVAL REGIONAL MED. CTR
Camp Lejeune, N.C.*

CONTRACTOR USE ONLY

REVIEWER USE ONLY

*List only one specification division per form.

**ACTION CODES

List only one of the following categories on each transmittal form, and indicate which is being submitted

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit

- Contractor Approved
 OICC Approval
 Deviation/Substitution For OICC Approval

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
580B	3.1	Jewett Co. Letter, 7/16/80	7		
Thru		Cardinal C.C. - Elect. Power Require.	7		
583-B		Confirmation #25			
"	"	Jewett Co. Dwg's. Revised 7/80			
		SR-1408-2A; SR-1408-2B; and BR-776	7		

CONTRACTOR'S COMMENTS

581-B 3.1 Copeland Condensing Unit-Lit. 7
Bohn Unit Coolers - Lit. 7

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

9-29-80

W.M.J. Haymaker

DATE RECEIVED BY REVIEWER

FROM (Reviewer)

TO

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.


REVIEWER'S COMMENTS



COPIES TO:
ROICC (2)
LANTDIV (1)
A-E (1)

DATE

SIGNATURE



PK # 2.5

POWER REQUIREMENT CONFIRMATION

to: ISEC

FILE NO. _____
 Lockwood Greene Engineers, Inc.
RECEIVED
 OCT 2 1980
 REF. TO _____
 ACK _____

DATE: 6-16-80

PROJECT: Naval Regional Medical Center
Camp Lejeune, North Carolina

SUBMITTAL NUMBER 580-A thru 583

gentlemen:

We require that you confirm the power requirement for the electrical equipment and/or motors furnished by your firm for the above referenced project by SAP.

The information will be forwarded to the Electrical Contractor by this office upon receipt or their verification with the Contract Requirements.


SPECIFICATION SECTION

11705

Please List Item #

	ITEM	POWER CHARACTERISTICS
	R-8400; Refrig., Pass-Thru (BR-148-BC-D)	1/3 H.P.; 115-60-1; 7.5 AMP
For	R-8400; Temp. Monitor (TMS-1)	115-60-1
	R-8405; Refrig., Wall Mtd., Pass-Thru (WM-7-BC-D)	1/5 H.P.; 115-60-1; 2.7 AMP
For	R-8405; Temp. Monitor (TMS-1)	115-60-1
	R-5200; Freezer (UC-5-LF-BC)	1/3 H.P.; 115-60-1; 6.8 AMP
*For	R-5200; Temp. Monitor (TMS-3-B-JG)	115-60-1
	R-6000; (4) Refrig. Blood Bank (BB-2)	1/4 H.P.; 115-60-1; 5.0 AMP
*For	R-6000; (4) Temp. Monitor (TMS-1-B-JG)	115-60-1
	R-6081; (2) Refrig. Biological/Pharmacy (SJB-225)	3/4 H.P.; 208-60-1; 6.0 AMP
For	R-6081; (2) Temp. Monitor (TMS-1-B)	115-60-1; 3.3 AMP
	R-8101; Refrig. Mortuary (BR-776)	1 1/2 H.P.; 208-220-60-3; 5.0 AMP
*For	R-8101; Temp. Monitor (TMS-1-B-JG)	115-60-1; 6.1 AMP
		115-60-1

*NOTE: Items require a (2) Conductor 22 Ga. Signal Wire between equipment and hospital communications center.



7-21-80

R 6081 Bio Refrigerator
R 8101 Mortuary Ref

"This material is submitted in accordance with the requirements of
Section 11705 Paragraph _____ of the Spec-
ifications. Contract Drawings and Sheet Numbers _____

Per trans 580A through 583A

205 Bad Hospital Naval Facility, San Diego, Calif.
Marine Corps Base, Camp Lejeune, N.C. NHCL-81150 /

SUPPLIER AND/OR MANUFACTURER

JEWETT

By: Intermountain Specialty Equipment Co., Inc."

FILE NO.
Lockwood Greene Engineers, Inc.
RECEIVED
OCT 2 1980
REF. TO
ACK

N-62470-77-C-7526

"It is hereby certified that the (material) (equipment) shown and marked in this submittal is that ~~approved~~/proposed to be incorporated into Contract Number _____, is in compliance with the contract drawings and specifications, and can be installed in the allocated spaces, and is (~~approved for use~~) (submitted for Government approval).

CARDINAL CONTRACTING CO.


Authorized Reviewer _____ Date _____

Signature CQC Rep WAH Date 9-29-80."

2333



englewood, colorado



JUL 18 1980

THE JEWETT REFRIGERATOR
COMPANY, INC.

July 16, 1980

Intermountain Specialty Equipment Company
33 Inverness Drive East
P. O. Box 1158
Englewood, Colorado 80150

Attention: Barbara Farris

Re: Your Agreement #12438062
Naval Regional Medical Center
Camp LeJeune, North Carolina
Jewett S.O. 43754

Dear Ms. Farris:

In accordance with your transmittal of June 23, 1980, and the reviewer's transmittal numbers 580-A through 583-A of 5-15-80, enclosed are (1) sepia and (3) prints of the following for final approval and clarification:

Item #R-8101

Drawing BR-776 BR-776 Walk-In Mortuary Refrigerator
Model #WSWH-0150 "Copeland" Condensing unit data sheets
Model #ADT0900B "Bohn" Unit Cooler data sheets

Item #R-6081

Drawing SR-1408-2A SJB-225 Walk-In/Reach-In Biological/Pharmacy Refrigerator
Drawing SR-1408-2B SJB-225 Walk-In/Reach-In Biological/Pharmacy Refrigerator



Also included are (6) copies of the Power Requirement Confirmation for all items of equipment that we will furnish.


Although Item #R-6081 had been "approved as noted" by the reviewer's transmittal, the comments regarding this item, as well as on some of the other items, were somewhat confusing. Therefore, we would appreciate a confirmation on our interpretation for each of the comments he listed.

Item R-8400

We will furnish door actuated light switches. However, we still recommend the twist switches initially shown as these switches are preferred with glass doors to eliminate opening of the doors when a person is searching for a product contained in the refrigerator.

23 33





Items R-4650,
R-8400, R-6081,
R-4651

The electrical requirements for Items R-8400 and R-6081 are shown on the enclosed Power Requirement Information. The other two listed items are not part of our contract.

Item R-5200

Disregard per letter of May 23, 1980.

Items R-5200,
R-6000, R-8101

We are furnishing the Audio-Visual Alarm for these items with our "JG" feature, which will allow connection to the Hospital Communications Center. The responsibility for furnishing and running the wire between the equipment and the Hospital Communications Center is by others. GC Coordinate

Item R-6081

Comment #1 - We have revised the closure of both refrigerators to suit the ceiling heights in the designated room locations so that the panels extend just above the dropped ceiling tiles. Please verify the ceiling heights shown on our Drawings SR-1408-2A and SR-1408-2B. OK

Comment #2 - The plumbing lines have been rearranged so that the condensate, etc. will discharge to the building floor drains. It is imperative that the P.C. locate his floor drain directly below the drain located on our Drawings SR-1408-2A and SR-1408-2B; on centerline of refrigerator 3'-4" from front (reach-in door end). The floor drain assemblies for these units will be similar in arrangement to that shown on our Drawing BR-776. Please verify the drain locations. GC Coordinate

Item R-8101

Comment #1 - We recommend that both the floor drain and the drain for condensate discharge be located in accordance with the dimensions shown on our Drawing BR-776. Please verify this location with the G.C.

Comment #2 - Architect's Drawing MO-11 shows a type "c" air device (interconnected to a 6" x 6" duct) through the ceiling of this refrigerator. However, the location and cutout size required is not given. We indicated on our Drawing BR-776 that this hole shall be field installed as it would be a very simple procedure. If you prefer that this hole be factory installed, please furnish us the necessary size and location. Coordinate w/ HVAC Contractor

Comment #3 - Data for refrigeration equipment is enclosed.

Per D.O.N. letter of May 23, 1980, we have increased the size of the entry door to 4' wide. OK

You indicated in your transmittal of June 23, 1980 that we may proceed with fabrication in accordance with the notations and comments included with that transmittal. Unfortunately, we cannot proceed until all the above questions are resolved and final approval is granted on the resubmitted items. We will require 120 days for fabrication after receipt of final approvals.

The five copies of installation prints, operation and maintenance manuals will be forwarded shortly after final approvals are received.

We look forward to receiving your approval by return mail as soon as possible, so that we may commence fabrication to the satisfaction of all parties concerned. To avoid any further delay, please contact this office directly should any questions arise regarding the aforementioned matters.

Very truly yours,


THE JEWETT REFRIGERATOR COMPANY, INC.

Richard D. Syroczyński
Richard D. Syroczyński
Engineering Administrator

RDS/tjb
Encs.

cc: W. H. McKelvie Co., Inc.
1213 De Vere Drive
Silver Spring, Maryland 20903
(301) 434-2440

L. S. Reed & Company
2740 South Vallejo Street
Englewood, Colorado 80150
(303) 761-6154



CONTRACTOR'S SUBMITTAL TRANSMITTAL
SECTION 11705

5ND LANTDIV 4-4355/3 (Rev. 6/76)

CONTRACT NO. *11-62470-77-8-7526* TRANSMITTAL NO. *583-1* DATE *1-21-80*

FROM CONTRACTOR
Cardinal Contrs. Co.
TO
Lockwood Greene, Engrs.

PROJECT TITLE AND LOCATION
*NAVAL REGIONAL MED. CTR.
Camp Lejeune, N.C.*

CONTRACTOR USE ONLY

REVIEWER USE ONLY

*List only one specification division per form.

**ACTION CODES

List only one of the following categories on each transmittal form,
and indicate which is being submitted

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged
- C-Comments
- R-Resubmit

- Contractor Approved OICC Approval Deviation/Substitution For OICC Approval

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
<i>583-1 3.2</i>	<i>15EC Letter, Dated 1/19/80</i>	<i>15EC Letter, Dated 1/19/80</i>	<i>7</i>		<i>Jan 27 1980</i>

FILE NO. *Lockwood Greene Engineers, Inc.*
RECEIVED
JAN 24 1980
REF. TO _____
ACK. _____

CONTRACTOR'S COMMENTS

Do you wish An Additional Drain Provided?

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

1-21-80

W.M.J. Haymaker

DATE RECEIVED BY REVIEWER

FROM (Reviewer)

1 FEB 80

LANTDIV

CARDINAL CONTRS CO.

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS

A&E AIR FILTER MUST BE ADDRESSED ON SUBMITTAL FOR APPROVAL, ALSO EMCS MUST CONNECT WITH WITH REFRIGERATORS

file field 3/20/80

only one copy of submittal


5 TO:
CC (2)
TDIV (1)
1)

DATE

27 FEB 80

SIGNATURE

J.P. [Signature]



CONTRACTOR'S SUBMITTAL TRANSMITTAL

5ND LANTDIV 4-4355/3 (Rev. 6/78)

SECTION 11705

CONTRACT NO. *N-62470-77-C-7526*

TRANSMITTAL NO.

583-1

DATE

1-21-80

FROM CONTRACTOR

Cardinal Contr. Co.

PROJECT TITLE AND LOCATION

*NAVAL REGIONAL MED. CTR.
Camp Lejeune, N.C.*

TO

Lockwood Greene, Engrs.

CONTRACTOR USE ONLY

REVIEWER USE ONLY

*List only one specification division per form.

**ACTION CODES

List only one of the following categories on each transmittal form, and indicate which is being submitted

A-Approved
D-Disapproved
AN-Approved as noted
RA-Receipt acknowledged.
C-Comments
R-Resubmit

Contractor Approved

OICC Approval

Deviation/Substitution
For OICC Approval

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
<i>583-1</i>	<i>3:2</i>	<i>ISEC Letter, Dated 1/19/80</i>	<i>7</i>		

CONTRACTOR'S COMMENTS

Do you wish An Additional Drain Provided?

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

1-21-80

CONTRACTOR REPRESENTATIVE (Signature)


W.M.J. Haymaker

DATE RECEIVED BY REVIEWER

FROM (Reviewer)

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.


REVIEWER'S COMMENTS



COPIES TO:
OICC (2)
LANTDIV (1)
(1)

DATE

SIGNATURE



ISEC
intermountain specialty
equipment co., inc.

33 Inverness Drive East
P.O. Box 1158
Englewood, Colorado 80150
(303) 773-1444

January 9, 1980

Cardinal Contracting Co.
P.O. Box 8408
Camp LeJeune, NC 28542

RE: Job No: 12438
205 Bed Hospital
Naval Regional Medical Center
Marine Corps Base
Camp LeJeune, NC
N62470-77-C-7526
Specification Section 11705

Gentlemen:

Deviations are requested on this material in order to meet manufacturer's standard products or provide a better quality material than that specified. There will be no additional cost to the government, general contractor or other subcontractors as a result of these deviations. Other trades will have to coordinate necessary rough-ins with our approved submittal data.

Please note that our letter of deviation dated October 5, 1979 for the R8101 mortuary refrigerator includes a note that an additional floor drain would be required along the side of the refrigerator to accommodate the condensation of the water from the cooling coil. This drain would be required by any manufacturer providing a refrigerator in accordance with the specifications.

Sincerely,

INTERMOUNTAIN SPECIALTY EQUIPMENT CO., INC.

Barbara S Farris

Barbara S. Farris
Project Manager

eng

FILE NO.	Lockwood Greene Engineers, Inc.
RECEIVED	
JAN 24 1980	
REF. TO	
ACK.	

202

