

40/2
02

File

CONTRACTOR'S SUBMITTAL TRANSMITTAL

5ND LANTDIV 4-4355/3 (Rev. 6/78)

FROM CONTRACTOR Trader Construction Company		CONTRACT NO. 81-C-1766	TRANSMITTAL NO. 38F	DATE April 30, 1984
TO Lockwood Greene/Six Associates		PROJECT TITLE AND LOCATION Public Works MGB Camp Lejeune, N.C.		

CONTRACTOR USE ONLY

*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

- Contractor Approved
 OICC Approval
 Deviation/Substitution For OICC Approval

REVIEWER USE ONLY

**ACTION CODES

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
159	15801	Heat, Vent, Air Conditioning			
	6.2.8	Motor Operated water control valves			
		Catalog data, shop drawings	7	AN	BWB 5/8/84

CONTRACTOR'S COMMENTS

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC ROICC, Camp Lejeune, N.C.		CONTRACTOR REPRESENTATIVE (Signature) <i>Dale Stallings</i>	
DATE RECEIVED BY REVIEWER 5/3/84	FROM (Reviewer) Six Associates, Inc.	TO Trader Construction Co.	

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS

PROVIDE ALL M.O. CONTROL VALVES REQUIRED AS PER PLANS.

COPY TO: FIELD

DATE: 23 May 84

COPIES TO: ROICC (2) ✓ LANTDIV (1) A-E (1)	DATE 5/8/84	SIGNATURE <i>Barbara W. Beacock</i>
-----------------------------------------------------	----------------	----------------------------------------

RECEIVED
MAY 10 1984
SIX ASSOCIATES, INC.

