

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**

5ND LANTDIV 4-4355/3 (Rev. 6/76)

*File*

CONTRACT NO. 81-C-1766	TRANSMITTAL NO. 39D	DATE Feb. 8, 1984
---------------------------	------------------------	----------------------

FROM CONTRACTOR  
**Trader Construction**  
TO  
**Lockwood Greene/Six Associates**

PROJECT TITLE AND LOCATION  
**Public Works**  
**MCB**  
**Camp Lejeune, N. C.**

**CONTRACTOR USE ONLY**

*\*List only one specification division per form.*


*List only one of the following categories on each transmittal form, and indicate which is being submitted*

- Contractor Approved       OICC Approval

**REVIEWER USE ONLY**

**\*\*ACTION CODES**

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit



ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, etc. or brochure number)	ACTION CODES	REVIEWER'S INITIALS CODE AND DATE
128	07220	Roof Insulation		
		Certificate of conformance		
		Federal Specifications HH-I-1972	7	A/C A.B. 14 Feb 84
			C	11

CONTRACTOR'S COMMENTS

**COPY TO: FIELD**  
**DATE: MAR 13 1984**

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC  
**ROICC, Camp Lejeune, N. C.**

CONTRACTOR REPRESENTATIVE (Signature)  
*Ms. Dale Stallings*

DATE RECEIVED BY REVIEWER: **2/13/84**  
FROM (Reviewer): **LANTDIV**  
TO: **TRADER CONSTRUCTION**

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.


REVIEWER'S COMMENTS **— APPROVED —**

We endorse proposed deviation at no cost to the Government and subject to compliance with Spec Section 07220, para. 2.1.1.1d.

Please comply with NAVFAC letter dated 19 May 83 regarding deviations.

Please indicate specific item submitted for approval.

COPIES TO: ROICC (2) LANTDIV (1) A-E (1)	DATE <b>2/29/84</b>	SIGNATURE <i>J. Haste</i>
---	------------------------	------------------------------





THE CELOTEX CORPORATION, 1500 JOHN TIPTON BLVD., PENNSAUKEN, NEW JERSEY 08110 • (609) 663-2626

January 24, 1984

E L Scott Roofing Co  
P O Box 128  
Kinston, NC 28501

Re: Public Works and Heli Pad  
Camp Lejeune, NC  
Contract #81-C 1766

Dear Sirs:

This is to advise you that Federal Specification HH-I-530A and Interim Amendment 4 have been superceded by Federal Specification HH-I-1972, and to certify that Thermax Hy-Tec Roof Insulation for the referenced job is manufactured to comply with Federal Specification HH-I-1972/2 (with non-asphaltic/glass fiber facers).

Sincerely yours,

George W Jackson  
The Celotex Corporation  
Quality Control Supervisor

"It is hereby certified that the (equipment) (material) shown and marked in this submittal is that proposed to be incorporated into Contract Number NS2470 81-C-1766 in compliance with the Contract drawings and specifications, can be installed in the allocated space, and is submitted Government approval.

Certified by D.S.

Date 2-8-84

  
Notary Public

