

40/02 Feb

CONTRACTOR'S SUBMITTAL TRANSMITTAL

5ND LANTDIV 4-4355/3 (Rev. 6/76)

CONTRACT NO. 81-C-1766	TRANSMITTAL NO. 71A	DATE Jan. 31, 1984
---------------------------	------------------------	-----------------------

FROM CONTRACTOR
Trader Construction

TO
Lockwood Greene/Six Associates

PROJECT TITLE AND LOCATION
Public Works

MCB
Camp Lejeune, N. C

<p align="center">CONTRACTOR USE ONLY</p> <p align="center">*List only one specification division per form.</p> <p align="center">List only one of the following categories on each transmittal form, and indicate which is being submitted</p> <p><input checked="" type="checkbox"/> Contractor Approved <input type="checkbox"/> OICC Approval <input type="checkbox"/> Deviation/Substitution For OICC Approval</p>	<p align="center">REVIEWER USE ONLY</p> <p align="center">**ACTION CODES</p> <p>A-Approved D-Disapproved AN-Approved as noted RA-Receipt acknowledged. C-Comments R-Resubmit</p>
--	---

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
130	07230/1.2	Perimeter Insulation			
		Styreneofoam Insulation, Cat. Data	7	A	A.B. (Feb 84
		Styreneofoam, certification	7	A	"

CONTRACTOR'S COMMENTS

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC
ROICC, Camp Lejeune, N. C.

CONTRACTOR REPRESENTATIVE (Signature)
Dale Stallings

DATE RECEIVED BY REVIEWER: **2/3/84**

FROM (Reviewer): **Six Associates, Inc.**

TO: **Trader Construction Co.**

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on **ONE COPY** of the transmittal form.


REVIEWER'S COMMENTS

COPY TO: FIELD
DATE: FEB 27 1984

COPIES TO: ROICC (2) ✓, LANTDIV (1), A-E (1)

DATE: **2/16/84**

SIGNATURE: *A.B. Johnson*



FOAM INDUSTRIES INCORPORATED

January 26, 1984

Trader Construction Company
P. O. Box 1578
New Bern, N. C. 28560

Attention: Dale Stallings


Re: Public Works Job
Marine Corp Base
Transmittal No. 71
Camp LeJeune, N. C.

Gentlemen:

We hereby certify that 2# density STYRENEFOAM EPS at a 2" thickness has the same physical properties as those shown on attached specification sheet for 2# density at 1" thickness except that the R value doubles to 8.6 at 75 degrees F. The K factor is a comparative value based only on 1" thickness and is not applicable to 2" thickness.

Very truly yours,

THE PROFESSIONAL FOAM PEOPLE



George Bonhach
President

GB/pd

cc: Mr. Aubrey Woodlief
Dixie Forming and Bldg. Spec.
Raleigh, N. C.

"It is hereby certified that the (equipment) (material) shown and marked in this submittal is that proposed to be incorporated into Contract Number 1162470-81-C-176 in compliance with the Contract drawings and specifications, and is submitted Government approval.

Certified by DS

Date 1-31-84

SWORN TO AND SUBSCRIBED BEFORE ME THIS TWENTY-SIXTH DAY OF JANUARY, 1984.



Notary Public, Georgia State at Large
My Commission Expires Jan. 23, 1984

RECEIVED
JAN 30
TRADER CONST. CO.

