



JG WILSON
QUALITY ROLLING DOORS SINCE 1876

JUNE 29, 1983

REFERENCE: PUBLIC WORKS HELIPAD
CAMP LEJEUNE, N. C.
J.G. WILSON ORDER No. 16-28-93

CERTIFICATE OF COMPLIANCE

THIS IS TO CERTIFY THAT THE DOORS WE PROPOSE TO FURNISH ON THIS ORDER WILL BE FABRICATED IN ACCORDANCE WITH SPECIFICATIONS, WITH ONE EXCEPTION.

IN LIEU OF STEEL GROOVES ON WEATHER DOORS, WE PROPOSE TO FURNISH EXTRUDED ALUMINUM GUIDES WITH STEEL MOUNTING ANGLES. THIS ARRANGEMENT IS OUR STANDARD PRACTICE FOR WILSON WEATHER DOORS.

THE J. G. WILSON CORPORATION

R. L. BRUCE
CHIEF ENGINEER

ATLANTIC DIVISION
NAVAL FACILITIES ENGINEERING COMMAND
NORFOLK, VIRGINIA 23511

APPROVED _____

APPROVED AS NOTED _____

DISAPPROVED _____

SUBJECT TO THE REQUIREMENTS OF

CONTRACT NO N62470-81-C-1766

APPROVAL OF A SUBMITTAL DOES NOT INCLUDE APPROVAL OF ANY DEVIATION FROM THE CONTRACT REQUIREMENTS UNLESS THE CONTRACTOR CALLS ATTENTION TO AND SUPPORTS THE DEVIATION... THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING PROPER PHYSICAL DIMENSIONS & WEIGHTS, COORDINATION OF TRADES, ETC., AS REQUIRED.

REVIEWER DATE 29 June 83

FOR OFFICER IN CHARGE OF CONSTRUCTION

"It is hereby certified that the (equipment) (material) shown and marked in this submittal is that proposed to be incorporated into Contract Number N62470-81-C-1766. is in compliance with the Contract drawings and specifications, and is submitted Government approval.

Certified by Date 10 Aug 83

