

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
 LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO. 81-C-1766	TRANSMITTAL NO. 52	DATE 6 OCT 83
PROJECT TITLE AND LOCATION Public Works & Helipad MCB Camp Lejeune, NC		

FROM CONTRACTOR  
 Trader Construction Company

TO  
 Lockwood Greene/Six Associates

**CONTRACTOR USE ONLY**

\*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

- Contractor Approved     
  OICC Approval     
  Deviation/Substitution For OICC Approval

**REVIEWER USE ONLY**

**\*\*ACTION CODES**

- A-Approved  
 D-Disapproved  
 AN-Approved as noted  
 RA-Receipt acknowledged.  
 C-Comments  
 R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES	REVIEWER'S INITIALS CODE AND DATE
154	14510 2.2.1	a. Auto Lift, Dover	7	A-C	CAT-406 11-3-83
		b. Hydraulic Pumping Unit		-	
		c. Pipe & Fittings	1	A	CAT-406 11-3-83
		d. Valves	2	A	CAT-406 11-3-83
		e. Controls	3	A	CAT-406 11-3-83
		f. Adaptors	5	A-C	CAT-406 11-3-83

ROUTING ORDER		INT
1	40	2
2		
3		
4		
5		
6		

**CONTRACTOR'S COMMENTS**

- Contract dwgs and Specs conflict concerning vehicle lift.
- Per directions from ROICC, Air operated lift is submitted in lieu of hydraulic lift.
- Contract does not specify types of adaptors and number of each to be furnished or make and model numbers for vehicles to be serviced. Request this info be provided during review.
- No change in contract price.

**COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC**

ROICC, Camp Lejeune, NC

**CONTRACTOR REPRESENTATIVE (Signature)**

*John May*

**DATE RECEIVED BY REVIEWER**

24 Oct 83

**FROM (Reviewer)**

LANTDIV

**TO**

Trader Cust Co

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

**REVIEWER'S COMMENTS**

- Verify the front - I mean jack capacity of 7000 lbs
- Verify adaptor and vehicle types w/ ROICC.
- Hydraulic piping unit not required. *Field copy 12-20-83*

COPIES TO:  
 ROICC (2)  
 LANTDIV (1)  
 A-E (1)

**DATE**

7 Nov 83

**SIGNATURE**

*[Signature]*

