

DATE PREPARED: 1 Jun 1975

FROM: Commanding Officer, MCAS(H) New River

TO: COMMANDANT OF THE MARINE CORPS (CODE LFF)

NOMENCLATURE	CATEGORY CODE	UNIT OF MEASURE	SPECIFIC AREA
Hazardous and Flammables Storehouse	441-30	SF	LA
DETERMINATION OF REQUIREMENTS: (If additional space is needed, use plain sheet of paper)			

A hazardous and flammables storehouse is similar to a general warehouse (441-10) in most respects except provision is made to prevent and remove through proper ventilation evaporated and gaseous fumes in accordance with NFPA (National Fire Prevention Association) Standard No. 30.

Any amount of space that is justified for Category Code 441-30 must be considered a portion of the total amount of space allowed for Category Codes 441-10 through 441-35/40 and may not exceed 5% of such total amount.

<u>Table</u>		<u>SF</u>
441-11	=	120,900
441-12	=	200,500
441-35	=	<u>11,415</u>
Total		332,815 SF

Maximum allowed 5% of 332,815 = 16,641 SF

Whenever practical, general storage shed (441-35) should be specified and used.

TOTAL REQUIREMENT FOR CATEGORY CODE

16,641 SF

MOBILIZATION STATEMENT

SIGNATURE: F. M. MORGAN

BY DIRECTION

CMC REVIEW ACTION

EVALUATION:

The established requirement is approved.

DATE

26 MAR 1976

ESTABLISHED REQUIREMENT

16,641 SF

SIGNATURE: A Z Bartlett

