

FOR OFFICIAL USE ONLY

DATE : 1 SEPT , 1980

DEPARTMENT OF THE NAVY  
PROJECT ENGINEERING DOCUMENTATION

DINING FACILITIES  
MODERNIZATION


(P-697)

FY 1982 MCON


MARINE CORPS BASE  
CAMP LEJEUNE  
NORTH CAROLINA

ADMINISTERED BY:  
ATLANTIC DIVISION  
NAVAL FACILITIES  
ENGINEERING COMMAND  
NORFOLK, VA. 23511


PREPARED BY:  
ODELL ASSOCIATES, INC.  
222 S. CHURCH ST.  
CHARLOTTE, N.C. 28202



1. COMPONENT NAVY		FY 19 <u>82</u> MILITARY CONSTRUCTION PROJECT DATA			2. DATE 1 SEPT 80	
3. INSTALLATION AND LOCATION MARINE CORPS BASE CAMP LEJEUNE, NORTH CAROLINA			4. PROJECT TITLE DINING FACILITIES MODERNIZATION			
5. PROGRAM ELEMENT		6. CATEGORY CODE 722-10	7. PROJECT NUMBER P-697		8. PROJECT COST (\$000) \$5,600	
<b>9. COST ESTIMATES</b>						
Escalation 12%		ITEM	Bid opening date 1 JANUARY 82	U/M	QUANTITY	UNIT COST
						COST (\$000)
Dining Facility Modernization				SF	102,975	\$ 44.14 \$4,482
Buildings				SF	102,975	38.55 (3,909)
Built in equipment				LS		( 512)
Solar Systems				LS		( 61)
Supporting Facilities						353
Utilities				LS		( 323)
Site Improvements				LS		( 30)
Subtotal						\$4,835
Contingency (10%)						484
Total Contract Cost						\$5,319
Supervision Inspection and Overhead (5.5%)						292
Total Request						\$5,611
Total Request (Rounded)						\$5,600
Equipment provided from other appropriations						(63)
<b>10. DESCRIPTION OF PROPOSED CONSTRUCTION</b>						
Interior renovations consisting of new wall coverings, new doors, installation of decorative partitions, omit alternate windows in dining wings, providing new lowered ceilings, air conditioning, insulation, fluorescent fixtures; installation of terrazzo and quarry tile on floor, miscellaneous carpentry, plumbing, masonry, mechanical work, painting, site improvements, and related work. (Air conditioning -285 tons)						
11. REQUIREMENTS: <u>25,946 PN.</u> ADEQUATE: <u>17,230 PN.</u> SUBSTANDARD: <u>10,118 PN.</u>						
PROJECT: Renovate the existing enlisted dining facilities, Buildings 1209, M424, 508, RR3, BA103.						
REQUIREMENT: The alterations and renovations are considered essential to solve the major problems of poor atmosphere, personnel traffic flow, efficiency of layout, maintenance and cleanliness, durability and flexibility of facilities used.						
CURRENT SITUATION: The facilities are in a general run-down condition with little modernization since their construction over 37 years ago. The overall condition and configuration of the existing facilities does not present an environment for efficient or maximum utilization.						
IMPACT IF NOT PROVIDED: Continued use of inefficient and outdated dining facilities.						



1. COMPONENT  NAVY	FY 19 <u>82</u> MILITARY CONSTRUCTION PROJECT DATA	2. DATE  1 SEPT 80
3. INSTALLATION AND LOCATION  MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA		
4. PROJECT TITLE  DINING FACILITIES MODERNIZATION	5. PROJECT NUMBER  P 697	
<p><u>ENVIRONMENTAL IMPACT</u> The Environmental Impact Assessment has been reviewed, and where required, the design concepts give consideration to eliminating adverse environmental effects consistent with applicable directives.</p> <p><u>PRESERVATION OF HISTORICAL SITES AND STRUCTURES</u> The project facilities do not directly or indirectly affect a district, site, building, structure, object or setting which is listed in the National Register or otherwise possesses a significant quality of American history.</p> <p><u>FALLOUT SHELTER CONSTRUCTION</u> Fallout shelter excluded - - Shelter not economically feasible as part of this project.</p> <p><u>FLOOD HAZARDS EVALUATION</u> Requirements of Executive Order No. 11988 (Flood plain Management) and Executive Order No. 11990 (Protection of Wetlands) are not applicable.</p> <p><u>POLLUTION, PREVENTION, ABATEMENT AND CONTROL</u> This project will not cause additional air or water pollution.</p> <p><u>DESIGN FOR ACCESSIBILITY OF PHYSICALLY HANDICAPPED PERSONNEL</u> Provisions for physically handicapped personnel not required in preparation and service areas of the facilities, since its use is specifically restricted to able-bodied military personnel. However, a dining area in each building will be made accessible to the handicapped and public toilets will be outfitted for the handicapped.</p>		



BUDGET ESTIMATE SUMMARY SHEET FOR P-697

Title: DINING FACILITIES MODERNIZATION Costs Escalated to: 1 JAN 82

Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%


Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%

	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT		
BUILDINGS 1209, M424, 508, RR-3, BA-103			102,975 SF					
1	Foundation	.379	N/A	N/A	39,000	39,000	0	
2	Slab on Grade	.447	N/A	N/A	46,000	46,000	0	
3	Structural Frame	.767	N/A	N/A	79,000	79,000	0	
4	Supported Floor	0	N/A	N/A	0	0	0	
5	Roof	.767	N/A	N/A	79,000	79,000	0	
6	Exterior Walls	1.729	N/A	N/A	178,000	178,000	0	
7	Interior Walls	.719	N/A	N/A	74,000	74,000	0	
8	Interior Finishes	8.886	N/A	N/A	915,000	915,000	0	
9	Doors and Windows	2.593	N/A	N/A	267,000	267,000	0	
10	Specialties	.923	N/A	N/A	95,000	95,000	0	
11	Plumbing	4.758	N/A	N/A	490,000	490,000	0	
12	Mechanical	9.002	N/A	N/A	927,000	927,000	0	
13	Electrical	7.000	N/A	N/A	720,000	720,000	0	
14	Equipment	4.972	N/A	N/A	512,000	0	512,000	
SUBTOTAL								
15	Solar Systems	.60	50.80	1210 Coll.SF	61,000	61,000	0	
Sub-Total Building				43.53		\$4,482,000	\$3,970,000	\$*512,000

1	Piling						*
2	Elec. Substation & Dist.	2.93	N/A	N/A	302,000	302,000	
3	Not Used						*
4	Telephone & Fire Alarm						
5	Water Distribution						
6	Sanitary Sewers	.204	N/A	N/A	21,000	21,000	
7	Roads, Parking, Sidewalks						
8	Storm Sewers						*
9	Site Improvements	.291	N/A	N/A	30,000	30,000	*
10	Demolition (In ea. sys.						*
11	above)						
12							
13							
14							
15							
Sub-Total Supporting Facilities							* \$ 353,000

Total Estimated Contract Cost: 1 Jan 82	\$ 4,835,000
Contingency 10 %	\$ 483,500
SIOM 5.5%	\$ 292,517
Total Budget Cost	\$ 5,611,017
Rounded	\$ 5,600,000

\*Asteric indicates these totals on 1391.



BUDGET ESTIMATE SUMMARY SHEET FOR P-697

Title: DINING FACILITIES MODERNIZATION Costs Escalated to: 1 JAN 82

Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%


Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%

	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT	
BUILDING 1209			22,530 SF				
1	Foundation	.400	N/A	N/A	9,023	9,023	0
2	Slab on Grade	.616	N/A	N/A	13,883	13,883	0
3	Structural Frame	.836	N/A	N/A	18,825	18,825	0
4	Supported Floor	0	N/A	N/A	0	0	0
5	Roof	.768	N/A	N/A	17,298	17,298	0
6	Exterior Walls	1.953	N/A	N/A	43,995	43,995	0
7	Interior Walls	.881	N/A	N/A	19,855	19,855	0
8	Interior Finishes	9.742	N/A	N/A	219,488	219,488	0
9	Doors and Windows	2.562	N/A	N/A	57,731	57,731	0
0	Specialties	1.102	N/A	N/A	24,829	24,829	0
1	Plumbing	6.320	N/A	N/A	142,393	142,393	0
2	Mechanical	10.013	N/A	N/A	225,585	225,585	0
3	Electrical	7.54	N/A	N/A	169,971	169,971	0
4	Equipment	4.701	N/A	N/A	105,928	0	105,928
SUBTOTAL							
5	Solar Systems	.80	47.69	380 Coll.SF	18,123	18,123	0
Sub-Total Building				48.24	\$1,086,927	\$980,999	\$*105,928

1	Piling			0	0	0	* 0
2	Elec. Substation & Dist.	2.75	N/A	N/A	62,000	62,000	0
3	Not Used			0	0	0	* 0
4	Telephone & Fire Alarm			0	0	0	0
5	Water Distribution			0	0	0	0
6	Sanitary Sewers	.106	N/A	N/A	2,381	2,381	0
7	Roads, Parking, Sidewalks			0	0	0	* 0
8	Storm Sewers			0	0	0	* 0
9	Site Improvements	.150	N/A	N/A	3,371	3,371	0
0	Demolition (In ea. sys. above)			0	0	0	* 0
1							
2							
3							
4							
5							
Sub-Total Supporting Facilities					* \$ 67,752		

Total Estimated Contract Cost: 1 Jan 82	\$ 1,154,679
Contingency 10 %	\$ 115,468
SIOH 5.5%	\$ 69,858
Total Budget Cost	\$ 1,340,005
Rounded	\$ 1,300,000

\*Asteric indicates these totals on 1391.



BUDGET ESTIMATE SUMMARY SHEET FOR P-697

Title: DINING FACILITIES MODERNIZATION

Costs Escalated to: 1 JAN 82

Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%

Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%


	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT	
BUILDING M424			22,530 SF				
1	Foundation	.534	N/A	N/A	12,036	12,036	0
2	Slab on Grade	.616	N/A	N/A	13,883	13,883	0
3	Structural Frame	.989	N/A	N/A	22,275	22,275	0
4	Supported Floor	0	N/A	N/A	0	0	0
5	Roof	.910	N/A	N/A	20,496	20,496	0
6	Exterior Walls	2.121	N/A	N/A	47,787	47,787	0
7	Interior Walls	.924	N/A	N/A	20,814	20,814	0
8	Interior Finishes	9.690	N/A	N/A	218,320	218,320	0
9	Doors and Windows	3.240	N/A	N/A	73,007	73,007	0
0	Specialties	1.243	N/A	N/A	28,016	28,016	0
1	Plumbing	6.466	N/A	N/A	145,682	145,682	0
2	Mechanical	10.013	N/A	N/A	225,585	225,585	0
3	Electrical	8.90	N/A	N/A	200,564	200,564	0
4	Equipment	6.599	N/A	N/A	148,680	0	148,680
SUBTOTAL							
5	Solar Systems	.80	47.69	380 Coll. SF	18,123	18,123	0
Sub-Total Building				53.05	\$1,195,268	\$*1,046,588	\$*148,680

1	Piling			0	0	0	* 0
2	Elec. Substation & Dist.	2.80	N/A	N/A	63,000	63,000	0
3	Not Used			0	0	0	* 0
4	Telephone & Fire Alarm			0	0	0	0
5	Water Distribution			0	0	0	0
6	Sanitary Sewers	.106	N/A	N/A	2,381	2,381	0
7	Roads, Parking, Sidewalks			0	0	0	* 0
8	Storm Sewers			0	0	0	* 0
9	Site Improvements	.431	N/A	N/A	9,712	9,712	0
0	Demolition (In ea. sys.			0	0	0	* 0
1	above)						
2							
3							
4							
5							
Sub-Total Supporting Facilities					* \$ 75,093		

Total Estimated Contract Cost: 1 Jan 82	\$ 1,270,361
Contingency 10 %	\$ 127,036
SIOH 5.5%	\$ 76,857
Total Budget Cost	\$ 1,474,254
Rounded	\$ 1,450,000

M424

\*Asteric indicates these totals on 1391.



BUDGET ESTIMATE SUMMARY SHEET FOR P-697

Title: DINING FACILITIES MODERNIZATION Costs Escalated to: 1 JAN 82

Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%

Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%


	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT	
BUILDING 508			22,475 SF				
1	Foundation	.378	N/A	N/A	8,499	8,499	0
2	Slab on Grade	.381	N/A	N/A	8,562	8,562	0
3	Structural Frame	.609	N/A	N/A	13,681	13,681	0
4	Supported Floor	0	N/A	N/A	0	0	0
5	Roof	.760	N/A	N/A	17,073	17,073	0
6	Exterior Walls	1.483	N/A	N/A	33,336	33,336	0
7	Interior Walls	.633	N/A	N/A	14,225	14,225	0
8	Interior Finishes	10.074	N/A	N/A	226,411	226,411	0
9	Doors and Windows	2.014	N/A	N/A	45,262	45,262	0
0	Specialties	.744	N/A	N/A	16,720	16,720	0
1	Plumbing	5.247	N/A	N/A	117,934	117,934	0
2	Mechanical	7.761	N/A	N/A	174,428	174,428	0
3	Electrical	5.70	N/A	N/A	128,087	128,087	0
4	Equipment	3.744	N/A	N/A	84,152	0	84,152
SUBTOTAL							
5	Solar Systems	.45	56.03	180 SF	10,086	10,086	0
Sub-Total Building				39.98	\$898,456	*\$814,304	*\$84,152

1	Piling			0	0	0	* 0
2	Elec. Substation & Dist.	2.80	N/A	N/A	63,000	63,000	0
3	Not Used			0	0	0	* 0
4	Telephone & Fire Alarm			0	0	0	0
5	Water Distribution			0	0	0	0
6	Sanitary Sewers	.530	N/A	N/A	11,905	11,905	0
7	Roads, Parking, Sidewalks			0	0	0	* 0
8	Storm Sewers			0	0	0	* 0
9	Site Improvements	.513	N/A	N/A	11,533	11,533	0
0	Demolition (In ea. sys.			0	0	0	* 0
1	above)						
2							
3							
4							
5							
Sub-Total Supporting Facilities					* \$ 86,438		

Total Estimated Contract Cost: 1 Jan 82	\$ 984,894
Contingency 10 %	\$ 98,489
SIOH 5.5%	\$ 59,586
Total Budget Cost	\$ 1,142,969
Rounded	\$ 1,150,000

- 508

\*Asteric indicates these totals on 1391.



BUDGET ESTIMATE SUMMARY SHEET FOR P-697

Title: DINING FACILITIES MODERNIZATION Costs Escalated to: 1 JAN 82

Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%

Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%


	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT	
BUILDING RR-3			22,475 SF				
1	Foundation	.250	N/A	5,636	5,636	0	
2	Slab on Grade	.140	N/A	3,155	3,155	0	
3	Structural Frame	.747	N/A	16,785	16,785	0	
4	Supported Floor	0	N/A	0	0	0	
5	Roof	.762	N/A	17,134	17,134	0	
6	Exterior Walls	1.473	N/A	33,113	33,113	0	
7	Interior Walls	.457	N/A	10,272	10,272	0	
8	Interior Finishes	5.439	N/A	122,237	122,237	0	
9	Doors and Windows	1.806	N/A	40,590	40,590	0	
0	Specialties	.588	N/A	13,210	13,210	0	
1	Plumbing	1.960	N/A	44,042	44,042	0	
2	Mechanical	7.761	N/A	174,428	174,428	0	
3	Electrical	5.70	N/A	128,087	128,087	0	
4	Equipment	3.603	N/A	80,971	0	80,971	
SUBTOTAL							
5	Solar Systems	.45	56.03	180 Coll.SF	10,086	10,086	0
Sub-Total Building				31.13	\$699,746	*\$618,775	*\$80,971

1	Piling			0	0	0	* 0
2	Elec. Substation & Dist.	2.80		N/A	63,000	63,000	0
3	Not Used			0	0	0	* 0
4	Telephone & Fire Alarm			0	0	0	0
5	Water Distribution			0	0	0	0
6	Sanitary Sewers	.106		N/A	2,381	2,381	0
7	Roads, Parking, Sidewalks			0	0	0	* 0
8	Storm Sewers			0	0	0	* 0
9	Site Improvements	.124		N/A	2,792	2,792	0
0	Demolition (In ea. sys. above)			0	0	0	* 0
1							
2							
3							
4							
5							
Sub-Total Supporting Facilities					* \$ 68,173		

Total Estimated Contract Cost: 1 Jan 82	\$	767,919
Contingency 10 %	\$	76,792
SIOH 5.5%	\$	46,459
Total Budget Cost	\$	891,170
Rounded	\$	890,000

RR-3

\*Asteric indicates these totals on 1391.



BUDGET ESTIMATE SUMMARY SHEET FOR P-697

Title: DINING FACILITIES MODERNIZATION Costs Escalated to: 1 JAN 82

Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%

Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%


	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT	
BUILDING BA-103			12,965 SF				
1	Foundation	.299	N/A	N/A	3,880	3,880	0
2	Slab on Grade	.527	N/A	N/A	6,837	6,837	0
3	Structural Frame	.603	N/A	N/A	7,816	7,816	0
4	Supported Floor	0	N/A	N/A	0	0	0
5	Roof	.563	N/A	N/A	7,299	7,299	0
6	Exterior Walls	1.507	N/A	N/A	19,533	19,533	0
7	Interior Walls	.668	N/A	N/A	8,659	8,659	0
8	Interior Finishes	9.927	N/A	N/A	128,709	128,709	0
9	Doors and Windows	3.860	N/A	N/A	50,047	50,047	0
0	Specialties	.933	N/A	N/A	12,098	12,098	0
1	Plumbing	3.095	N/A	N/A	40,125	40,125	0
2	Mechanical	9.812	N/A	N/A	127,210	127,210	0
3	Electrical	7.15	N/A	N/A	92,755	92,755	0
4	Equipment	6.780	N/A	N/A	87,904	0	87,904
SUBTOTAL							
5	Solar Systems	.39	56.03	90 Coll.SF	5,045	5,045	0
Sub-Total Building				46.12	\$597,917	*\$510,013	*\$87,904

1	Piling			0	0	0	* 0
2	Elec. Substation & Dist.	3.93	N/A	N/A	51,000	51,000	0
3	Not Used			0	0	0	* 0
4	Telephone & Fire Alarm			0	0	0	0
5	Water Distribution			0	0	0	0
6	Sanitary Sewers	.184	N/A	N/A	2,381	2,381	0
7	Roads, Parking, Sidewalks			0	0	0	* 0
8	Storm Sewers			0	0	0	* 0
9	Site Improvements	.215	N/A	N/A	2,792	2,792	0
0	Demolition (In ea. sys. above)			0	0	0	* 0
1							
2							
3							
4							
5							
Sub-Total Supporting Facilities					* \$ 56,173		

Total Estimated Contract Cost: 1 Jan 82	\$ 654,090
Contingency 10 %	\$ 65,409
SION 5.5%	\$ 39,572
Total Budget Cost	\$ 759,071
Rounded	\$ 760,000

\*Asteric indicates these totals on 1391.

BA 103



## DESIGN CONCEPTS

Activity and Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

Project Title: DINING FACILITIES MODERNIZATION (P-697)

Date: 1 JULY 1980

### USE OF DEFINITIVES AND PREVIOUS DESIGNS

Although definitives for Dining Facilities have been superseded, Definitives 1286674, 75, 76, and 77 were used for reference during design of interior functions and equipment layout. The scope of the modernization of the facilities does not warrant use of existing definitives.

### SPECIAL DESIGN CHARACTERISTICS

Floor Plan: Existing building layout limited modernization approach. However, new locations for entries, toilets, serving line equipment and sculleries are proposed in order to relieve present internal cross traffic patterns of inefficiency.


Ventilation: Heat, humidity and odors produced during facility use require new ventilation in following areas: Bakery, Pot Wash, Scullery, Food Service, Garbage Rooms, Toilets and Attics above air conditioned spaces.

Air Conditioning is provided for all dining areas, salad prep areas, and offices.

Finishes: Terrazzo floors and quarry tile floor and wainscots are planned for all major spaces not presently finished as such in order to create sanitary and easily maintainable surfaces.


### ENERGY CONSERVATION AND SOLAR ENERGY

1. Energy Conservation: The following energy conservation measures were considered and analyzed for the design of this building:
  - a. Insulation in wall: The benefit/cost was computed for two (2) representative buildings, M424 and 508, using Trace computer program to determine the reduction in building heating and cooling loads due to installation of additional insulation in the wall. Results are tabulated in "Summary of Energy Conservation Analysis."



- b. Insulation in Attic: The benefit/cost was computed for two (2) representative buildings, M424 and 508, using Trace computer program to determine the reduction in building heating and cooling loads due to installation of additional insulation in the attic. Results are tabulated in "Summary of Energy Conservation Analysis."
  - c. Exhaust Heat Recovery: A run around coil was considered for computing exhaust heat recovery from scullery to preheat outside air makeup for buildings M424 and 508. System CFM not of feasible capacity. Kitchen hoods use untempered makeup air with only 20 percent tempered air from dining.
  - d. Hot Water Recovery: Heat recovery from pot sink and dish machines was considered for preheating make-up water for the hot water heater for building M424 and 508. The locations of the various hot water using equipment makes it impractical to collect waste hot water for reclaiming heat. Very long pipe runs, intermediate sumps and pumping to a central location close to the domestic hot water heater will have to be provided so that make-up water can be preheated. This conservation feature is, therefore, not considered feasible.
  - e. Condensate Heat Recovery: Since condensate is returned back to central system, heat recovery at this use terminal would not be feasible. Condensate recovery would be considered more feasible at the central energy plant.
  - f. Storm Windows for Existing Windows: Approximately 45 percent of the windows in the dining areas are removed and blocked up for other than energy savings reasons. The balance of the windows in occupied spaces were considered for adding storm windows and were determined to be feasible.
  - g. Vestibules: Vestibules are proposed for all major entrances and exits by simply adding doors to 10 existing vestibule areas, adding two complete vestibules and maintaining six existing vestibules. No detail analysis was made, since the construction cost was so small.
2. Solar Energy: The feasibility of Solar Energy Systems for the five buildings was determined by the "Solcost" computer program. Two of the five buildings (508, M424), were run on the computer. Two buildings (RR-3, 1209) were nearly identical to the two run. Solar systems to BA-103 (similar shape to 508) were scaled down from building 508 sizes. Domestic hot water is based on people served while space heating is based on area of building.

Two alternatives were considered: (1) domestic hot water and (2) domestic hot water combined with space heating. The combined system was considered since the design will integrate both aspects into one system.



Each building was determined to be feasible within the limits of Government criteria for solar assisted Domestic Hot Water heating only. See charts indicating Solar Collector Sizing. Listed below is statistical information (totals for all buildings).

---

a.	Type system included:	DOMESTIC HOT WATER HEATING
b.	Type collector:	Single glazed flat plate
c.	Area collector, all buildings:	1,210 square feet
d.	Systems cost, all buildings:	\$61,463
e.	Annual energy savings:	Barrels of oil equivalent = 44.5
f.	Percent energy contribution from solar system to DHW Heat:	83%
g.	Payback:	9 years
h.	System design cost:	\$30,000

---

The combined domestic hot water and space heating system is not economically feasible.

3. An economic study was made to provide a basis for selection of an HVAC system. A Variable Temperature Constant Volume System was compared with a Variable Air Volume System with Reheat serving Dining Areas, Packaged Terminal Air Conditioning Units serving certain support areas and Perimeter Radiation serving total building except for areas served by Variable Air Volume System with Reheat.


Analysis proved that the Variable Temperature Constant Volume Systems will provide a lower present worth.

4. Energy Monitoring and Control System (EMCS):

- a. Camp Lejeune's present EMCS is set up to operate or monitor the following:
- 1) Stop and start of each air conditioning unit.
  - 2) Room supply air flow status.
  - 3) Room temperature of each area.
- b. Telephone lines are used for transmission of signal from each building to the master monitoring unit (CPU).
- c. Each building will require a field panel to be installed.
- d. The electric power, steam and fire alarm system are not to be monitored at this time.

5. Energy Summary: The analysis of energy conserving measures (listed on Energy Analysis Summary) indicates feasibility of several features:

- a. The following features are feasible and have been incorporated into the project, and the cost is included in the building costs:



- 1) Insulation of walls of AC space
- 2) Insulation of ceiling of AC space
- 3) Solar assisted domestic hot water heating
- 4) Storm windows

b. The following features are not feasible and have not been incorporated into the project:

- 1) Hot water recovery
- 2) Exhaust air heat recovery
- 3) Condensate heat recovery
- 4) Solar space heating

#### POLLUTION ABATEMENT ASPECTS OF DESIGN

No pollution of air, water, noise, erosion, etc., is anticipated resulting from the work proposed in this project; therefore, no need for permits from authorities in this regard is anticipated.

Additional toilet fixtures added to each building will be tied into the existing building sewer, therefore negating the need to tie into sanitary sewer at additional connection points. The additional quantity of discharge for each building is anticipated as identified below:

Building 1209	3240 GPD
Building M424	3240 GPD
Building 508	1620 GPD
Building RR3	1620 GPD
Building BA103	810 GPD


The additional discharge is anticipated to be absorbed within the existing sanitary sewers and the effluent is anticipated to be handled by existing treatment plant.

#### SITE APPROVAL

The five separate sites involved with this project have been approved as described in letter CMC, LFF-1-AJR:bab of January 11, 1980.

#### ECONOMIC ANALYSIS

Economic analyses were done on two Base Buildings M424 and 508 for the considerations mentioned in the ENERGY SUMMARY. Since Building 1209 is similar to M424, it is deduced that all energy conservation measures applicable to M424 can be used for Building 1209. Similarly, Building 508 measures are applicable to RR3. Since Building BA103 is also similar to 508 and half as large in area as 508, energy conservation measures are applied to this building, providing half the credit that can be obtained




from conservation and solar contributions. The building loads for the base buildings are calculated on a Trace program, and economic analyses of system type and equipment to be used for the heating, ventilating, and air conditioning for these base buildings are selected based on a TRACE computer program.

SPECIAL ENGINEERING SERVICES


None Required.

CONTINGENCY ALLOWANCE

A 10% contingency allowance is considered as necessary at this phase of design since the project involves remodeling of (5) individual buildings over 30 years old.




$$\begin{aligned}
 LCS &= \text{ENERGY REQD} \times \text{ENERGY COST} \times \text{PRESENT VALUE FACTOR} \\
 &= 78.84 \times 10^6 \text{ BTU/YR} \times 12.53 \text{¢/}10^6 \text{ BTU} \times 80.23 \\
 &= 79,256.
 \end{aligned}$$



AREA	FIRST COST	f	SAVINGS	Δ\$	SF COLLECTOR
40	1908	.284	22509	20601	
80	3816	.495	39232	35416	
120	5724	.656	51992	46268	
140	6678	.722	57223	50545	
180	8586	.828	65624	57038	
220	10494	.903	71568	61074	
260	12402	.950	75293	62891	
300	14310	.970	76819	62569	
340	16218	.986	77907	61691	


SOLAR COLLECTOR SIZING



$$LCS = \text{ENERGY REQD.} \times \text{ENERGY COST} \times \text{PRESENT VALUE FACTOR}$$

$$= 157.68 \times \text{BTU/YR} \times \$12.53 \text{ MIL BTU} \times 80.23$$

$$= \$158,513$$



AREA	FIRST COST	f	SAVINGS	Δ\$
80	3822	.283	44859	41037
160	7643	.496	78623	70980
240	11465	.662	104936	93471
300	14331	.760	120470	106139
380	18152	.859	136163	118011
460	21974	.931	147576	125602
540	25796	.960	152173	126377
620	29617	.979	155184	125567
700	33439	.989	156770	123331

SOLAR COLLECTOR SIZING



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDING BA 103

MARINE CORPS BASE

DINING FACILITY MODERNIZATION (P-697)

1 JULY 80

$E_{75} = 2054 \times 10^6$  BTU/Yr (Total annual energy consumption, 75)


$E_{\text{Current}} = 1157 \times 10^6$  BTU/Yr (Total annual energy consumption incorporating current criteria)

$R = (1 - (E_{\text{Current}}/E_{75})) \times 100 = 43.8$  (Percent reduction in energy consumption current year vs. existing situation)

ECC=634,400 (Estimated construction cost for current criteria)

Barrels of Oil Equivalent (B.O.E.) = 153 \*(Barrels of Fuel Oil Saved, Current Design vs. 1975)  
5,825,400 BTU/B.O.E.

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	$10^6$ BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	$10^6$ BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000)
1.	Insulate Walls	129	-24.	5.38	1,925	6.3	148,476	6.3	7.2	641.6
2.	Insulate Ceiling	692	-154.	4.49	1,233	33.7	95,102	40.0	6.0	647.6
3.	Storm Windows	57	-23.	2.47	1,176	2.8	90,706	42.8	1.4	649
4.	Solar Domestic HW	19	=28.	0.67	1,157	1.0	89,240	43.8	5.0	654



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDINGS 1209, M424, 508, RR-3 AND BA103

MARINE CORPS BASE

DINING FACILITY MODERNIZATION (P-697)

1 JULY 80

$$E_{75} = 17,200 \times 10^6 \text{ BTU/Yr (Total annual energy consumption, 75)}$$

$$E_{\text{Current}} = 9467 \times 10^6 \text{ BTU/Yr (Total annual energy consumption incorporating current criteria)}$$


$$R = (1 - (E_{\text{Current}}/E_{75})) \times 100 = 44.9 \text{ (Percent reduction in energy consumption current year vs. existing situation)}$$

$$ECC = 4,604,900 \text{ (Estimated construction cost for current criteria)}$$

$$\text{Barrels of Oil Equivalent (B.O.E.)} = 1360 \text{ *(Barrels of Fuel Oil Saved, Current Design vs. 1975)}$$

$$5,825,400 \text{ BTU/B.O.E.}$$

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	$10^6$ BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	$10^6$ BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000)
1.	Insulate Walls	1,189	-204.	5.82	16011	6.9	155,484	6.9	82.1	4,687
2.	Insulate Ceiling	5,694	-1262.	4.51	10317	33.1	100,189	40.0	69.2	4,757
3.	Storm Windows	591	-139.	4.25	9726	3.4	94,450	43.4	15.5	4,773.5
4.	Solar Domestic HW	259	-384.	.67	9467	1.5	91,934	44.9	61.5	4,835



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDING 1209

MARINE CORPS BASE

DINING FACILITY MODERNIZATION (P-697)

1 JULY 80

$E_{75} = 3708 \times 10^6$  BTU/Yr (Total annual energy consumption, 75)


$E_{\text{Current}} = 2179 \times 10^6$  BTU/Yr (Total annual energy consumption incorporating current criteria)

$R = (1 - (E_{\text{Current}}/E_{75})) \times 100 = 41.2$  (Percent reduction in energy consumption current year vs. existing situation)

ECC = 1,094,700 (Estimated construction cost for current criteria)

Barrels of Oil Equivalent (B.O.E.) = 295 \*(Barrels of Fuel Oil Saved, Current Design vs. 1975)  
5,825,400 BTU/B.O.E.

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	$10^6$ BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	$10^6$ BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000)
1.	Insulate Walls	272	-42.	6.47	3,436	7.3	152,507	7.3	23.2	1,117.9
2.	Storm Windows	154	-33.	4.66	3,282	4.1	145,672	11.4	4.3	1,122.2
3.	Insulate Ceiling	1,022	-224.	4.56	2,260	27.5	100,310	38.9	14.7	1,136.9
4.	Solar Domestic HW	81	-121.	.67	2,179	2.2	96,715	41.2	18.1	1,155



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDING M424

MARINE CORPS BASE      DINING FACILITY MODERNIZATION (P-697)      1 JULY 80

E75 =  $3900 \times 10^6$  BTU/Yr (Total annual energy consumption, 75)


E Current =  $2179 \times 10^6$  BTU/Yr (Total annual energy consumption incorporating current criteria)

R =  $(1 - (E \text{ Current}/E75)) \times 100 = 44.1$  (Percent reduction in energy consumption current year vs. existing situation)

ECC=1,207,000 (Estimated construction cost for current criteria)

Barrels of Oil Equivalent (B.O.E.) = 295      \*(Barrels of Fuel Oil Saved, Current Design vs. 1975)  
5,825,400 BTU/B.O.E.

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	$10^6$ BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	$10^6$ BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000)
1.	Insulate Walls	272	-42.	6.47	3,628	7.0	161,030	7.0	23.2	1,230.2
2.	Storm Windows	154	-33.	4.66	3,474	3.9	154,194	10.9	4.3	1,234.5
3.	Insulate Ceiling	1,214	-266.	4.56	2,260	31.1	100,311	42.0	17.4	1,251.9
4.	Solar Domestic HW	81	-121.	.67	2,179	2.1	96,715	44.1	18.1	1,270



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDING 508

MARINE CORPS BASE

DINING FACILITY MODERNIZATION (P-697)

1 JULY 80

$$E_{75} = 3769 \times 10^6 \text{ BTU/Yr (Total annual energy consumption, 75)}$$


$$E_{\text{Current}} = 1976 \times 10^6 \text{ BTU/Yr (Total annual energy consumption incorporating current criteria)}$$

$$R = (1 - (E_{\text{Current}}/E_{75})) \times 100 = 47.5 \text{ (Percent reduction in energy consumption current year vs. existing situation)}$$

ECC=942,400 (Estimated construction cost for current criteria)

Barrels of Oil Equivalent (B.O.E.) =307 \*(Barrels of Fuel Oil Saved, Current Design vs. 1975)  
5,825,400 BTU/B.O.E.

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	10 <sup>6</sup> BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	10 <sup>6</sup> BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000)
1.	Insulate Walls	258	-48.	5.38	3,511	6.8	156,218	6.8	14.2	956.6
2.	Storm Windows	113	-25.	4.52	3,398	3.0	151,190	9.8	2.8	959.4
3.	Insulate Ceiling	1,383	-309.	4.47	2,015	36.7	89,655	46.5	15.5	974.9
4.	Solar Domestic HW	39	-57.	.68	1,976	1.0	87,920	47.5	10.1	985



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDING RR-3

MARINE CORPS BASE

DINING FACILITY MODERNIZATION (P-697)

1 JULY 80

$$E_{75} = 3769 \times 10^6 \text{ BTU/Yr (Total annual energy consumption, 75)}$$


$$E_{\text{Current}} = 1976 \times 10^6 \text{ BTU/Yr (Total annual energy consumption incorporating current criteria)}$$

$$R = (1 - (E_{\text{Current}}/E_{75})) \times 100 = 47.5 \text{ (Percent reduction in energy consumption current year vs. existing situation)}$$

$$ECC = 725,400 \text{ (Estimated construction cost for current criteria)}$$

$$\text{Barrels of Oil Equivalent (B.O.E.)} = 307 \text{ *(Barrels of Fuel Oil Saved, Current Design vs. 1975)} \\ 5,825,400 \text{ BTU/B.O.E.}$$

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	$10^6$ BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	$10^6$ BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000)
1.	Insulate Walls	258	-48.0	5.38	3,511	6.8	156,218	6.8	14.2	739.6
2.	Storm Windows	113	-25.	4.52	3,398	3.0	151,190	9.8	2.8	742.4
3.	Insulate Ceiling	1,383	-309.	4.47	2,015	36.7	89,655	46.5	15.5	757.9
4.	Solar Domestic HW	39	-57.0	.68	1,976	1.0	87,920	47.5	10.1	768



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 1209; BUILDING M424	DATE 1 JULY 80
ACTIVITY (Name and Location) MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA	
PROJECT TITLE DINING FACILITIES MODERNIZATION	P NO. P-697
DESCRIPTION OF ALTERNATIVES	

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Variable temp. constant volume split system, packaged terminal A/C and Fin. Rad.      ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$101,181			\$101,181
OPERATIONS    Elec.		\$51,794	18.049	934,830
Steam (oil)		25,502	20.050	511,315
MAINTENANCE		2,321	9.524	22,105
PERSONNEL				
TERMINAL VALUE				
OTHER:				
TOTAL PRESENT VALUE ALTERNATIVE A - \$ 1,569,431			DISCOUNT FACTOR ÷ 9.524	UNIFORM ANNUAL COST = \$164,787


ALTERNATIVE B Variable air volume with reheat, packaged terminal A/C and Fin. Rad.      ECONOMIC LIFE \_\_\_\_\_ YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$163,601			\$163,601
OPERATIONS    Elec.		\$52,183	18.049	941,851
Steam (oil)		25,372	20.050	508,709
MAINTENANCE		2,453	9.524	23,362
PERSONNEL				
TERMINAL VALUE				
OTHER:				
TOTAL PRESENT VALUE ALTERNATIVE B - \$ 1,637,523			DISCOUNT FACTOR ÷ 9.524	UNIFORM ANNUAL COST = \$171,936


REMARKS

Alternative "A" is feasible.  
 Life Cycle Cost  
 Alt. A - 1,569,431  
 Alt. B - 1,637,523  
 L.C.C. - 68,092  
 - 68 x 10<sup>3</sup>

$$S.I.R. = \frac{1,637,523}{1,569,431} = 1.04$$







ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 1209; BUILDING M424

DATE  
1 JULY 80

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Storm Windows ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$4,293			\$4,293
OPERATIONS Steam		0		
Elec.		0		
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 4,293 ÷ 9.524 = \$451


ALTERNATIVE B No Storm Windows ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	0			0
OPERATIONS Steam Savings		\$1,442	20.05	\$28,912
Elec. Savings		453	18.049	8,176
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 37,088 ÷ 9.524 = \$3,894

REMARKS  
Alternative "A" is feasible due to lower total present value than "B".  
Life Cycle Cost  
Alt. A - 4,293  
Alt. B - 37,088  
L.C.C. - 32,795  
          - 33 x 10<sup>3</sup>

S.I.R. =  $\frac{37,088}{4,293} = 8.64$



BUILDING 1209 and BUILDING M424 - STORMS

Total Window Area (Heating) = 1,596 SF  
 (Cooling) = 1,281 SF  
 Savings from Storm Windows

1. Winter Savings

Reduction in Infiltration  $\times \Delta T \times 1.08 \times \text{SF Window}$   
 + Reduction in Transmission  $\times \Delta T \times \text{SF Window}$   
 =  $0.5(1.6 - 0.8) \text{ CFM/SF} \times (68 - 23) \times 1.08 \times 1,596 \text{ SF}$   
 +  $(1.04 - 0.54) \times (68 - 23) \times 1,596 \text{ SF}$   
 = 66,936 BTUH  
 Annual Savings in BTU's  
 $\frac{2901 \text{ HDD} \times 24 \times 66,936}{(68 - 23) \times .90(\text{Effy.})} = 115.07 \text{ MIL BTU/YR.}$

Annual Dollar Savings  
 $\$12.53/\text{MIL BTUS} \times 115.07 \text{ MIL BTU/YR.} = \$1,442$

2. Summer Savings

Reduction in Infiltration  $\times \Delta H \times 4.45 \times \text{SF Window}$   
 + Reduction in Transmission  $\times \Delta T \times \text{SF Window}$   
 =  $0.5(0.8 - 0.4) \text{ CFM/SF} \times 12. \times 4.45 \times 1,281 \text{ SF}$   
 +  $(1.04 - 0.54) \times (90 - 78) \times 1,281 \text{ SF}$   
 = 21,367 BTUH

Annual Savings in BTU's  
 $\frac{1810 \text{ CDD} \times 21,367 \text{ BTUH}}{3,413 \text{ KWH/BTU}} = 11,331 \text{ KWH}$   
 or 38.67 MIL BTU/YR

Annual Dollar Savings  
 $\$0.04/\text{KWH} \times 11,331 \text{ KWH} = \$453$


3. Total Annual Savings from Storm Windows  
 $\$1,442 + \$453 = \$1,895$

4. Cost of Storm Windows

Jan 80 Jun 80 Jan 82  
 $\$2.27/\text{SF} \times 1.036 \times 1.143 = \$2.69$  represents cost to add storms to proposed  
 cost for screens under equipment section.

Installation Cost of Storm Windows  
 $1,596 \text{ SF} \times \$2.69/\text{SF} = \$4,293$

5. Discount Factor - Use 20.050 for 25 years for oil, 8%; and use 18.049 for 25 years for electricity, 7%.



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING M424	DATE 1 JULY 80
ACTIVITY (Name and Location) MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA	
PROJECT TITLE DINING FACILITIES MODERNIZATION	P NO. P-697
DESCRIPTION OF ALTERNATIVES	

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add insulation above ceiling ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$17,437			\$17,437
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 17,437 ÷ 9.524 = \$1,831


ALTERNATIVE B Continue to operate with current losses ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	0			0
OPERATIONS Steam		\$8,305	20.05	\$166,515
OPERATIONS Elec.		6,457	18.049	116,542
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 283,057 ÷ 9.524 = \$29,720

REMARKS Alternative "A" is feasible due to lower total present value.  
 Life Cycle Cost  
 Alt. A - \$ 17,437  
 Alt. B - 283,057  
 L.C.C. - 265,620  
           - 266 x 10<sup>3</sup>

S.I.R. =  $\frac{283,057}{17,437} = 16.23$



BUILDING M424

1. Additional insulation above ceiling  
Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Roof Area SF}$$

over heated space

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Roof Area SF}$$

over A/C space

$$U_{\text{Exist.}} = 0.44 \text{ BTU/HR}^{\circ}\text{F.SF} \quad U_{\text{New}} = 0.05 \text{ BTU/HR}^{\circ}\text{F.SF}$$

From Trace  
Heat Loss with  $U_{\text{New}} (.05)$  = 49,427 BTUH

Heat Loss with  $U_{\text{Exist.}} (.44)$   
 $\frac{49,427 \times .44}{.05}$  = 434,958 BTUH

Winter Energy Saved = 385,531 BTUH

Annual Savings in BTU's  
 $\frac{2901 \text{ HDD} \times 24 \times 385,531 \text{ BTUH}}{(68 - 23) \times .90 \text{ (Effy.)}}$  = 662.77 MIL BTU/YR.

Annual Dollar Savings  
 $\$12.53/\text{MIL BTUS} \times 662.77 \text{ MIL BTUS/YR.} = \$8,305$

From Trace  
Heat Gain with  $U_{\text{New}} (.05)$  = 39,027 BTUH

Heat Gain with  $U_{\text{Exist.}} (.44)$   
 $\frac{39,027 \times .44}{.05}$  = 343,438 BTUH

Summer Energy Saved = 304,411 BTUH

Annual Savings in BTU's  
 $\frac{1810 \text{ CDD} \times 304,411 \text{ BTUH}}{3,413 \text{ KWH/BTU}}$  = 161,437 KWH/YR.  
 or 551 MIL BTU/YR.

Annual Dollar Savings  
 $\$.04/\text{KWH} \times 161,437 \text{ KWH} = \$6,457$



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 1209

DATE  
1 JULY 80

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add insulation above ceiling

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$14,670			\$14,670
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A = \$ 14,670 ÷ 9.524 = \$ 1,540

ALTERNATIVE B Continue to operate with current losses

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	0			0
OPERATIONS		\$6,988	20.05	\$140,109
MAINTENANCE		5,434	18.049	98,078
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B = \$ 238,187 ÷ 9.524 = \$ 25,009

REMARKS

Alternative "A" is feasible due to lower total present value.

Life Cycle Cost

Alt. A - \$ 14,670

Alt. B - 238,187

L.C.C. - 223,517

- 224 x 10<sup>3</sup>

$$S.I.R. = \frac{238,187}{14,670} = 16.24$$



BUILDING 1209

1. Additional insulation above ceiling

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Roof Area SF over heated space}$$

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Roof Area SF over A/C space}$$

$$U_{\text{Exist.}} = 0.44 \text{ BTU/HR}^{\circ}\text{F.SF} \quad U_{\text{New}} = 0.05 \text{ BTU/HR}^{\circ}\text{F.SF}$$

From Trace (for Bldg. M424)  
Heat Loss with  $U_{\text{New}}$  (.05) = 49,427 BTUH

Heat Loss with  $U_{\text{Exist.}}$  (.44)  
 $\frac{49,427 \times .44}{.05} = 434,958 \text{ BTUH}$

Winter Energy Saved = 385,531 BTUH

Annual Savings in BTU's  
 $\frac{2901 \text{ HDD} \times 24 \times 385,531 \text{ BTUH}}{(68 - 23) \times .90 \text{ (Effy.)}} = 662.77 \text{ MIL BTU/YR.}$

or

$$\frac{12,736\text{SF}}{15,136\text{SF}} \times 662.77 = 557.78 \text{ MIL BTU/YR. for Bldg. 1209}$$

Annual Dollar Savings  
\$12.53/MIL BTUS x 557.68 MIL BTUS/YR. = \$6,988

From Trace  
Heat Gain with  $U_{\text{New}}$  (.05) = 39,027 BTUH

Heat Gain with  $U_{\text{Exist.}}$  (.44)  
 $\frac{39,027 \times .44}{.05} = 343,438 \text{ BTUH}$


Summer Energy Saved = 304,411 BTUH

Annual Savings in BTU's  
 $\frac{1810 \text{ CDD} \times 304,411 \text{ BTUH}}{3,413 \text{ KWH/BTU}} = 161,437 \text{ KWH/YR.}$

or

$$\frac{12,736\text{SF}}{15,136\text{SF}} \times 161,437 = 135,839 \text{ KWH/YR. or } 464 \text{ MIL BTU/YR.}$$

Annual Dollar Savings  
\$0.04/KWH x 135,839 KWH = \$5,434



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 1209; BUILDING M424 DATE 1 JULY 80  
 ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA  
 PROJECT TITLE P NO.  
DINING FACILITIES MODERNIZATION P-697  
 DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Insulate exterior walls ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$23,232			\$23,232
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 23,232 ÷ 9.524 DISCOUNT FACTOR = \$2,439 UNIFORM ANNUAL COST

ALTERNATIVE B Continue to operate with current losses ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS	Steam	\$2,468	20.05	\$49,483
	Elec.	882	18.049	15,919
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 65,402 ÷ 9.524 DISCOUNT FACTOR = \$6,867 UNIFORM ANNUAL COST

REMARKS

Alternative "A" is feasible.

Life Cycle Cost


Alt. A - \$23,232

Alt. B - 65,402

L.C.C. - 42,170

- \$ 42 x 10<sup>3</sup>

$$S.I.R. = \frac{65,402}{23,232} = 2.82$$



BUILDING 1209 and BUILDING M424

2. Additional insulation in walls

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Wall Area SF} \\ \text{across heated space}$$

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Wall Area SF} \\ \text{across A/C space}$$

$$U_{\text{Exist.}} = 0.35 \text{ BTU/HR}^{\circ}\text{F.SF} \quad U_{\text{New}} = 0.15 \text{ BTU/HR}^{\circ}\text{F.SF}$$

$$\text{From Trace} \\ \text{Heat Loss with } U_{\text{New}} (.15) = 85,932 \text{ BTUH}$$

$$\text{Heat Loss with } U_{\text{Exist.}} (.35) \\ \frac{85,932 \times .35}{.15} = 200,508 \text{ BTUH}$$

$$\text{Energy Saved for Heating} = 114,575 \text{ BTUH}$$

$$\text{Annual Energy Savings} \\ \frac{2901 \text{ HDD} \times 24 \times 114,575 \text{ BTUH}}{(68 - 23) \times .90(\text{Effy.})} = 196.97 \text{ MIL.BTU/YR.}$$

$$\text{Annual Dollar Savings} \\ \$12.53/\text{MIL BTUS} \times 196.97 \text{ MIL BTUS/YR.} = \$2,468$$


$$\text{From Trace} \\ \text{Heat Gain with } U_{\text{New}} (.15) = 31,166 \text{ BTUH}$$

$$\text{Heat Gain with } U_{\text{Exist.}} (.35) \\ \frac{31,166 \times .35}{.15} = 72,721 \text{ BTUH}$$

$$\text{Energy Saved for Cooling} = 41,555 \text{ BTUH}$$

$$\text{Annual Energy Savings} \\ \frac{1810 \text{ CDD} \times 41,555 \text{ BTUH}}{3,413} = 22,038 \text{ KWH/YR} \\ \text{or } 75.22 \text{ MIL BTU/YR.}$$

$$\text{Annual Dollar Savings} \\ \$0.04/\text{KWH} \times 22,038 \text{ KWH} = \$882$$



ECONOMIC ANALYSIS OF SHORE FACILITY  
 BUILDING 1209 and BUILDING M424

DATE  
 1 JULY 80

ACTIVITY (Name and Location)  
 MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
 DINING FACILITIES MODERNIZATION

P NO.  
 P-697

DESCRIPTION OF ALTERNATIVES

---



---



---



---



---

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Solar Domestic Hot Water ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	18,125		80.23	18,125
OPERATIONS Oil (Steam)		244		19,581
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A . \$ 37,706 ÷ DISCOUNT FACTOR = UNIFORM ANNUAL COST


ALTERNATIVE B Conventional Steam ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT			80.23	
OPERATIONS Oil (Steam)		1,976		158,534
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B . \$ 158,534 ÷ DISCOUNT FACTOR = UNIFORM ANNUAL COST

REMARKS  
 Alternate A is feasible.  
 Life Cycle Cost  
 Alt. A - \$ 37,706  
 Alt. B - 158,534  
 L.C.C. - 120,828  
 - \$121 x 10<sup>3</sup>


S.I.R. =  $\frac{158,534}{37,706} = 4.2$   
 Payback =  $\frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{18,125}{1,732} = 10.5$   
 From Enclosure 14 = Less than 8 years. Encl 7



BUILDING 1209 AND BUILDING M424 - SOLAR DHW  
SOLAR ANALYSIS

1. Investment Cost: Back-up estimate esc. to 1 January 82.
2. Energy Cost: FY 80      FY 81      FY 82  
Steam (Oil) \$9.27/Mil BTU x 1.04 x 1.14 x 1.14 = 12.53/Mil BTU
3. Energy Consumption  
Alternate A  
    Auxiliary Energy Required = 19.44 MBTU/YR\*  
    Cost of Aux. Energy 19.44 x 12.53 = \$244  
  
Alternate B  
    Conventional Energy Required = 157.68 MBTU/YR\*  
    Cost of Conventional Energy = 157.68 x 12.53 = \$1,976
4. Discount Factor - Use 80.23 for 25 years for oil from enclosure 14 (FY 82)
5. Payback =  $\frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{18,125}{1,732} = 10:5$   
  
From Enclosure 14 = Less Than 8 years.

\* Refer to SOLCOST analysis



ECONOMIC ANALYSIS OF SHORE FACILITY

<b>BUILDING 508 and BUILDING RR3</b>	<b>DATE</b> 1 JULY 80
<b>ACTIVITY (Name and Location)</b> MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA	
<b>PROJECT TITLE</b> DINING FACILITIES MODERNIZATION	<b>P NO.</b> P-697
<b>DESCRIPTION OF ALTERNATIVES</b> See Below	

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Variable temperature constant volume split system, packaged terminal A/C and Fin. Rad.      ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$87,249			\$ 87,249
OPERATIONS    Elec.		\$51,836	18.049	935,588
Steam (oil)		21,914	20.050	439,376
MAINTENANCE		2,213	9.524	21,077
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 1,483,290      ÷ 9.524 DISCOUNT FACTOR = \$155,742 UNIFORM ANNUAL COST


ALTERNATIVE B Variable air volume with reheat air cooled chiller, packaged terminal A/C and Fin. Rad.      ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$145,487			\$145,487
OPERATIONS    Elec.		\$52,801	18.049	953,005
Steam (oil)		21,891	20.050	438,915
MAINTENANCE		2,397	9.524	22,829
PERSONNEL				
TERMINAL VALUE				
OTHER:				


TOTAL PRESENT VALUE ALTERNATIVE B - \$ 1,560,236      ÷ 9.524 DISCOUNT FACTOR = \$163,822 UNIFORM ANNUAL COST

REMARKS  
 Alternative "A" is feasible.  
 Life Cycle Cost  
 Alt. A - \$1,483,290  
 Alt. B - 1,560,236  
 L.C.C. - \$ 76,946  
           - 77 x 10<sup>3</sup>

$$S.I.R. = \frac{1,560,236}{1,483,290} = 1.05$$







ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 508; BUILDING RR-3

DATE  
1 JULY 80

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Storm Windows

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$2,763			\$2,763
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 2,763 ÷ 9.524 = 290 UNIFORM ANNUAL COST

ALTERNATIVE B No Storm Windows

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT		\$1,143	20.05	\$22,917
OPERATIONS		254	18.049	4,584
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 27,501 ÷ 9.524 = 2,886 UNIFORM ANNUAL COST

REMARKS Alternative A is feasible due to lower present value than B.

Life Cycle Cost


Alt. A - \$ 2,763

Alt. B - 27,501

L.C.C. - \$24,738

- \$25 x 10<sup>3</sup>

$$S.I.R. = \frac{27,501}{2,763} = 9.95$$



BUILDING 508 and BUILDING RR-3 - Storms

TOTAL WINDOW AREA (Heating) = 1,027 SF  
(Cooling) = 759 SF  
SAVINGS FROM STORM WINDOWS

1. Winter Savings:

Reduction in Infiltration x  $\Delta T$  x 1.08 x SF Window  
+ Reduction in Transmission x  $\Delta T$  x SF Window  
=  $0.5(2.4 - 1.2)$  CFM/SF x  $(68 - 23)$  x  $1.08$  x  $1,027$   
+  $(1.04 - 0.54)$  x  $(68 - 23)$  x  $1,027$  SF  
= 53,055 BTUH

ANNUAL SAVINGS IN BTU's

$\frac{2901 \text{ HDD} \times 24 \times 53,055}{(68 - 23) \times .90(\text{Effy.})} = 91.21 \text{ MIL BTU/YR.}$

ANNUAL DOLLAR SAVINGS

$\$12.53/\text{MIL BTU's} \times 91.21 \text{ MIL BTU/YR.} = \$1,143$

2. Summer Savings:

Reduction in Infiltration x  $\Delta H$  x 4.45 x SF Window  
+ Reduction in Transmission x  $\Delta T$  x SF Window  
=  $0.5(1.2 - 0.6)$  CFM/SF x  $12$  x  $4.45$  x  $759$  SF  
+  $(1.04 - 0.54)$  x  $(68 - 23)$  x  $759$  SF  
= 11,958 BTUH

ANNUAL SAVINGS IN BTU's

$\frac{1810 \text{ CDD} \times 11,958 \text{ BTUH}}{3,413 \text{ KWH/BTU}} = 6,342 \text{ KWH}$   
or 21.6 MIL BTU/YR.

ANNUAL DOLLAR SAVINGS

$\$0.04/\text{KWH} \times 6,342 \text{ KWH} = \$254$

3. Total Annual Savings from Storm Windows

$\$1,143 + \$254 = \$1,397$


4. Cost of Storm Windows

Jan 80      Jun 80      Jan 82  
 $\$2.27/\text{SF} \times 1.036 \times 1.142 = \$2.69$  represents cost to add storms to proposed  
cost for screens under equipment section.

INSTALLATION COST OF STORM WINDOWS

$1,027 \text{ SF} \times \$2.69/\text{SF} = \$2,763$

5. Discount Factor - Use 20.050 for 25 years for oil, 8%; and use 18.049 for 25 years for electricity, 7%.



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 508; BUILDING RR-3

DATE  
1 JULY 80

ACTIVITY (Name and Location)

MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE

DINING FACILITIES MODERNIZATION

P NO.

P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add insulation in ceiling

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$15,538			\$15,538
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A = \$ 15,538 ÷ 9.524 DISCOUNT FACTOR = \$1,631 UNIFORM ANNUAL COST

ALTERNATIVE B Continue to operate with current losses

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS		\$8,915	20.05	\$182,758
		7,874	18.049	142,118
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B = \$ 324,876 ÷ 9.524 DISCOUNT FACTOR = \$34,111 UNIFORM ANNUAL COST

REMARKS

Alternative "A" is feasible.

Life Cycle Cost


Alt. A - \$ 15,538

Alt. B - 324,876

L.C.C. - \$309,338

- \$309 x 10<sup>3</sup>

$$S.I.R. = \frac{324,876}{15,538} = 20.91$$



BUILDING 508 and BUILDING RR-3

1. Additional insulation above ceiling

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Roof Area SF} \\ \text{over heated space}$$

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Roof Area SF} \\ \text{over A/C space}$$

$$U_{\text{Exist.}} = 0.44 \text{ BTU/HR}^{\circ}\text{F. SF} \quad U_{\text{New}} = 0.05 \text{ BTU/HR}^{\circ}\text{F. SF}$$

From Trace

$$\text{Heat Loss with } U_{\text{New}} (.05) = 53,060 \text{ BTUH}$$

$$\text{Heat Loss with } U_{\text{Exist.}} (.44)$$

$$\frac{53,060 \times .44}{.05} = 466,928 \text{ BTUH}$$

$$\text{Winter Energy Saved} = 413,868 \text{ BTUH}$$

Annual Savings in BTU's

$$\frac{2901 \text{ HDD} \times 24 \times 413,868 \text{ BTUH}}{(68 - 23) \times .90(\text{Effy.})} = 711.48 \text{ MIL BTU/YR.}$$

Annual Dollar Savings

$$\$12.53/\text{MIL BTUS} \times 711.48 \text{ MIL BTUS/YR.} = \$8,915$$

From Trace

$$\text{Heat Gain with } U_{\text{New}} (.05) = 47,588 \text{ BTUH}$$

$$\text{Heat Gain with } U_{\text{Exist.}} (.44)$$

$$\frac{47,588 \times .44}{.05} = 418,774 \text{ BTUH}$$


$$\text{Summer Energy Saved} = 371,186 \text{ BTUH}$$

Annual Savings in BTU's

$$\frac{1810 \text{ CDD} \times 371,186 \text{ BTUH}}{3,413 \text{ KWH/BTU}} = 196,850 \text{ KWH/YR.} \\ \text{or } 671.85 \text{ MIL BTU/YR.}$$

Annual Dollar Savings

$$\$0.04/\text{KWH} \times 196,850 \text{ KWH} = \$7,874$$



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 508; BUILDING RR-3

DATE 1 JULY 80

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO. P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add insulation in walls ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$14,206			\$14,206
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 14,206 ÷ 9.524 = \$1,492

ALTERNATIVE B Continue to operate with current losses ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS	Steam (oil)	\$2,252	20.05	\$45,153
	Elec.	922	18.049	16,641
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 61,794 ÷ 9.524 = \$6,488

REMARKS

Alternative "A" is feasible.

Life Cycle Cost


Alt. A - \$14,206

Alt. B - 61,794

L.C.C. - \$47,588

- \$48 x 10<sup>3</sup>

$$S.I.R. = \frac{61,794}{14,206} = 4.35$$



BUILDING 508 and BUILDING RR-3

2. Additional insulation in walls

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Wall Area SF} \\ \text{across heated space}$$

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Wall Area SF} \\ \text{across A/C space}$$

$$U_{\text{Exist.}} = 0.35 \text{ BTU/HR}^\circ\text{F.SF.} \quad U_{\text{New}} = 0.15 \text{ BTU/HR}^\circ\text{F.SF.}$$

From Trace  
Heat Loss with  $U_{\text{New}} (.15)$  = 78,402 BTUH

Heat Loss with  $U_{\text{Exist.}} (.35)$   
 $\frac{78,402 \times .35}{.15}$  = 182,938 BTUH

Energy Saved for Heating = 104,536 BTUH

Annual Energy Savings  
 $\frac{2901 \text{ HDD} \times 24 \times 104,586 \text{ BTUH}}{(68 - 23) \times .90(\text{Effy.})}$  = 179.71 MIL BTU/YR.

Annual Dollar Savings  
\$12.53/MIL BTUS x 179.71 MIL BTU/YR. = \$2,252


From Trace  
Heat Gain with  $U_{\text{New}} (.15)$  = 32,586 BTUH

Heat Gain with  $U_{\text{Exist.}} (.35)$   
 $\frac{32,586 \times .35}{.15}$  = 76,034 BTUH

Energy Saved for Cooling = 43,448 BTUH

Annual Energy Savings  
 $\frac{1810 \text{ CDD} \times 43,448 \text{ BTU}}{3,413}$  = 23,042 KWH/YR.  
78.64 MIL BTU/YR.

Annual Dollar Savings  
\$0.04/KWH x 23,042 KWH = \$922



ECONOMIC ANALYSIS OF SHORE FACILITY

Building 508 and Building RR3  
 ACTIVITY (Name and Location)  
 MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA  
 PROJECT TITLE  
 DINING FACILITIES MODERNIZATION  
 DESCRIPTION OF ALTERNATIVES

DATE  
1 JULY 80

P NO.  
P-697

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Solar Domestic Hot Water Heating ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	10,087		80.23	10,087
OPERATIONS		149		11,954
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 22,041 ÷ DISCOUNT FACTOR = UNIFORM ANNUAL COST

ALTERNATIVE B Operate Domestic Hot Water System with Hot Water Generator Using Steam ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT			80.23	
OPERATIONS		988		79,267
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 79,267 ÷ DISCOUNT FACTOR = UNIFORM ANNUAL COST


REMARKS

Alternate "A" is feasible.  
 Life Cycle Cost  
 Alt. A - \$22,041  
 Alt. B - 79,269  
 L.C.C. - 57,228<sup>3</sup>  
 - \$57 x 10<sup>3</sup>

$$S.I.R. = \frac{79,267}{22,041} = 3.60$$

$$\text{Payback} = \frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{5043}{419} = 12.02$$


From Enclosure 14 = Less than 9 years. Encl 7



BUILDING 508 AND BUILDING RR3 - SOLAR DHW  
SOLAR ANALYSIS

1. Investment cost: Back-up estimate esc. to 1 January 82.
2. Energy Cost: FY 80    FY 81    FY 82  
Steam (oil) \$9.27/MIL BTU x 1.04 x 1.14 x 1.14 = 12.53/MIL BTU.
3. Energy Consumption  
  Alternate A  
    Auxiliary Energy Required = 11.93 MBTU/YR\*  
    Cost of Aux. Energy = 11.93 x 12.53 = \$149  
  
  Alternate B  
    Conventional Energy Required = 78.84 MBTU/YR\*  
    Cost of Conventional Energy = 78.84 x 12.53 = \$988
4. Discount Factor - use 80.23 for 25 years for oil from enclosure 14 (FY 82).
5. Payback =  $\frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{10,087}{839} = 12.02$   
From Enclosure 14                    = Less than 9 years.

\* Refer to SOLCOST analysis.



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING BA-103

DATE  
1 JULY 80

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add Storm Windows

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT		\$1,383		\$1,383
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 1,383 ÷ 9.524 = \$145 UNIFORM ANNUAL COST

ALTERNATIVE B

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS	Steam (oil)	\$572	20.05	\$11,526
	Elec.	703	18.049	12,688
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 24,214 ÷ 9.524 = \$2,542 UNIFORM ANNUAL COST

REMARKS Alternative "A" is feasible.

Life Cycle Cost


Alt. A - \$ 1,383

Alt. B - 24,214

L.C.C. - 22,831

- 23 x 10<sup>3</sup>

$$S.I.R. = \frac{24,214}{1,383} = 17.51$$



BUILDING BA-103 - STORMS  
(Glazed Area Considered 1/2 of Building 508)

Total Window Area (Heating) = 514 SF  
 (Cooling) = 380 SF  
 Savings From Storm Windows

1. Winter Savings

Reduction in Infiltration x  $\Delta T$  x 1.08 x SF Window  
 + Reduction in Transmission x  $\Delta T$  x SF Window  
 =  $0.5(2.4 - 1.2)$  CFM/SF x  $(68 - 23)$  x  $1.08$  x 514 SF  
 +  $(1.04 - 0.54)$  x  $(68 - 23)$  x 514 SF  
 = 26,553 BTUH  
 Annual Savings in BTU's  
 $\frac{2901 \text{ HDD} \times 24 \times 26,553}{(68 - 23) \times .90 \text{ (Effy.)}}$  = 45.65 MIL BTU/YR.

Annual Dollar Savings  
 $\$12.53/\text{MIL BTUS} \times 45.65 \text{ MIL BTU/YR.} = \$572$

2. Summer Savings

Reduction in Infiltration x  $\Delta H$  x 4.45 x SF Window  
 + Reduction in Transmission x  $\Delta T$  x SF Window  
 =  $0.5(1.2 - 0.6)$  CFM/SF x  $12$  x  $4.45$  x 380 SF  
 +  $(1.04 - 0.54)$  x  $(68 - 23)$  x 380 SF  
 = 6,174 BTUH  
 Annual Savings in BTU's  
 $\frac{1810 \text{ CDD} \times 6,174 \text{ BTUH}}{3,413 \text{ KWH/BTU}}$  = 3,274 KWH  
 or 11.17 MIL BTU/YR.

Annual Dollar Savings  
 $\$0.04/\text{KWH} \times 3,274 \text{ KWH} = \$131$


3. Total Annual Savings from Storm Windows  
 $\$572 + \$131 = \$703$

4. Cost of Storm Windows

Jan 80      Jun 80      Jan 82  
 $\$2.27/\text{SF} \times 1.036 \times 1.142 = \$2.69$  represents cost to add storms to proposed  
 cost for screens under equipment section.

Installation Cost of Storm Windows  
 $514 \text{ SF} \times \$2.69/\text{SF} = \$1,383$

5. Discount Factor - Use 20.050 for 25 years for oil, 8%; and use 18.049 for 25 years for electricity, 7%.



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING BA-103

DATE  
1 JULY 80

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add insulation above ceiling ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$6,027			\$6,027
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 6,027 ÷ 9.524 = 633 DISCOUNT FACTOR UNIFORM ANNUAL COST

ALTERNATIVE B Operate with existing losses ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS	Steam (oil)	\$4,457	20.05	\$89,363
	Elec.	3,937	18.049	71,059
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 160,422 ÷ 9.524 = \$16,844 DISCOUNT FACTOR UNIFORM ANNUAL COST

REMARKS

Alternative "A" is feasible.

Life Cycle Cost


Alt. A - \$ 6,027

Alt. B - 160,422

L.C.C. - 154,395

- \$154 x 10<sup>3</sup>

$$S.I.R. = \frac{160,422}{6,027} = 26.62$$



BUILDING BA-103

1. Additional insulation above ceiling  
Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Roof Area SF} \quad \text{over heated space}$$

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Roof Area SF} \quad \text{over A/C space}$$

$$U_{\text{Exist.}} = 0.44 \text{ BTU/HR}^{\circ}\text{F.SF} \quad U_{\text{New}} = 0.05 \text{ BTU/HR}^{\circ}\text{F.SF}$$

From Trace  
Heat Loss with  $U_{\text{New}} (.05)$  = 26,530 BTUH

Heat Loss with  $U_{\text{Exist.}} (.44)$   
 $\frac{26,530 \times .44}{.05}$  = 233,464 BTUH

Winter Energy Saved = 206,934 BTUH

Annual Savings in BTU's  
 $\frac{2901 \text{ HDD} \times 24 \times 206,934 \text{ BTUH}}{(68 - 23) \times .90(\text{Effy.})}$  = 355.74 MIL BTU/YR.

Annual Dollar Savings  
 $\$12.53/\text{MIL BTUS} \times 355.74 \text{ MIL BTUS/YR.} = \$4,457$


From Trace  
Heat Gain with  $U_{\text{New}} (.05)$  = 23,794 BTUH

Heat Gain with  $U_{\text{Exist.}} (.44)$   
 $\frac{23,794 \times .44}{.05}$  = 209,387 BTUH

Summer Energy Saved = 185,593 BTUH

Annual Savings in BTU's  
 $\frac{1810 \text{ CDD} \times 185,593 \text{ BTUH}}{3,413 \text{ KWH/BTU}}$  = 98,425 KWH/YR.  
 or 335.92 MIL BTU/YR.

Annual Dollar Savings  
 $\$0.04/\text{KWH} \times 161,437 \text{ KWH} = \$3,937$



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING BA-103

DATE  
1 JULY 80

ACTIVITY (Name and Location)

MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE

DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Insulate exterior walls

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$7,225			\$7,225
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 7,225 ÷ 9.524 = \$759

ALTERNATIVE B Operate with existing losses.

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS	Steam (oil)	\$1,126	20.05	\$22,576
	Elec.	461	18.049	8,321
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 30,897 ÷ 9.524 = \$3,244

REMARKS Alternative "A" is feasible.

Life Cycle Cost


Alt. A - \$ 7,225

Alt. B - 30,897

L.C.C. - 23,672

- \$24 x 10<sup>3</sup>

$$S.I.R. = \frac{30,897}{7,225} = 4.28$$



BUILDING BA-103

2. Additional insulation in walls

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Wall Area SF} \\ \text{across heated space}$$

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Wall Area SF} \\ \text{across A/C space}$$

$$U_{\text{Exist.}} = 0.35 \text{ BTU/HR}^\circ\text{F.SF} \quad U_{\text{New}} = 0.15 \text{ BTU/HR}^\circ\text{F.SF}$$

From Trace  
Heat Loss with  $U_{\text{New}} (.15)$  = 39,201 BTUH

Heat Loss with  $U_{\text{Exist.}} (.35)$   
 $\frac{39,201 \times .35}{.15}$  = 91,469 BTUH

Energy Saved for Heating = 52,268 BTUH

Annual Energy Savings  
 $\frac{2901 \text{ HDD} \times 24 \times 52,268 \text{ BTUH}}{(68 - 23) \times .90(\text{Effy.})}$  = 89.86 MIL BTU/YR.

Annual Dollar Savings  
\$12.53/MIL BTUS x 89.86 MIL BTUS/YR. = \$1,126


From Trace  
Heat Gain with  $U_{\text{New}} (.15)$  = 16,293 BTUH

Heat Gain with  $U_{\text{Exist.}} (.35)$   
 $\frac{16,293 \times .35}{.15}$  = 38,017 BTUH

Energy Saved for Cooling = 21,724 BTUH

Annual Energy Savings  
 $\frac{1810 \text{ CDD} \times 21,724 \text{ BTUH}}{3413}$  = 11,521 KWH/YR.  
or 39.32 MIL BTU/YR.

Annual Dollar Savings  
\$0.04/KWH x 22,038 KWH = \$461



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING BA-103	DATE 1 JULY 80
ACTIVITY (Name and Location) MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA	
PROJECT TITLE DINING FACILITIES MODERNIZATION	P NO. P-697
DESCRIPTION OF ALTERNATIVES	


PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A <u>Solar Domestic Hot Water</u>		ECONOMIC LIFE	25	YRS.
DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$5,043		80.23	\$5,043
OPERATIONS		\$75		6,017
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				
TOTAL PRESENT VALUE ALTERNATIVE A - \$				11,060
				÷
				DISCOUNT FACTOR
				UNIFORM ANNUAL COST
				=

ALTERNATIVE B <u>Operate domestic hot water system with hot water generator using steam</u>		ECONOMIC LIFE	25	YRS.
DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT			80.23	
OPERATIONS		\$489		\$39,232
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				
TOTAL PRESENT VALUE ALTERNATIVE B - \$				39,232
				÷
				DISCOUNT FACTOR
				UNIFORM ANNUAL COST
				=

REMARKS  
 Alternative "A" is feasible.  
 Life Cycle Cost  
 Alt. A - \$11,060  
 Alt. B - 39,232  
 L.C.C. - 28,172<sup>3</sup>  
           - \$28 x 10<sup>3</sup>

S.I.R. =  $\frac{39,232}{11,060} = 3.55$   
 Payback =  $\frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{10,087}{839} = 12.02$   
 From Enclosure 14 = Less than 9 years. Encl 7



BUILDING BA-103 - SOLAR DHW

1. Investment Cost: Back-up estimate escalates to 1 JAN 82.
2. Energy Cost:  


	FY 80	FY 81	FY 82	
Steam (oil)	R9.27/MIL	x 1.04	x 1.14	x 1.14 = 12.53/MIL BTU
				BTU
3. Energy Consumption:  

Alternate A:  
Auxiliary Energy Required = 5.97 MIL BTU/YR\*  
Cost of Auxiliary Energy = 5.97 x 12.53 = \$75

Alternate B:  
Conventional Energy Required = 39.42 MIL BUT/YR\*  
Cost of Conventional Energy = 39.42 x 12.53 = \$494
4. Discount Factor - Use 80.23 for 25 years for oil from enclosure 14(FY 82).
5. Payback =  $\frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{5,043}{419} = 12.02$

From Enclosure 14 = Less Than 9 years.

\*Refer to Solcost Analysis.



**COLLATERAL EQUIPMENT REQUIREMENTS (Initial Outfitting)**

5ND LANTDIV 4-11010/6 (NEW 2-79)

DATE  
1 JULY 80

1. ACTIVITY (Name and Location)


MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

2. PROJECT TITLE

DINING FACILITIES MODERNIZATION

P. NO.  
P-697

COG. SYMBOL AND FED. STOCK NO. OR OTHER SOURCE	ITEM/EQUIPMENT DESCRIPTION	QUAN- TITY	UNIT OF ISSUE	M + L + MV UNIT PRICE	TOTAL COST
<u>1. BUILT-IN EQUIPMENT TO BE MCON FUNDED</u>	*Intercom system amplifiers	5	EA	876	4,380
	*Drinking water coolers	16	EA	804	12,864
	*Venetian blinds	340	EA	138	46,920
	*Window screens	340	EA	37	12,580
	*Serving line vent hood	2	EA	19,106	38,212
	*Soiled ware handling system	6	EA	56,268	337,608
	1 - ea. Bldg. BA-103				
	1 - ea. Bldg. 1209				
	1 - ea. Bldg. RR-3				
	2 - ea. Bldg. M-424				
	1 - ea. Bldg. 508				
	*Convection oven	6	EA	4,495	26,972
	2 - ea. Bldg. BA-103				
	2 - ea. Bldg. RR-3				
	2 - ea. Bldg. M-424				
	*Ice machine	3	EA	3,439	10,318
	1 - ea. Bldg. RR-3				
	2 - ea. Bldg. M-424				
	*Walk-in cooler doors	8	EA	2,768	22,144
	SUBTOTAL (To 1391)				511,998
	*Equipment with associated installation cost and mark ups and escalation to JAN 82 <u>Building BA-103</u>				
<u>2. EXPENSE ITEMS</u>					
Wasserstorm	Refrigerated display case	1	EA	3,355	3,355
Keating	Grill, electric, 6 ft.	1	EA	2,508	2,508
American Warehouse	Hot food table, mobile	2	EA	1,425	2,850
Keating	Deep fat fryer	1	EA	1,164	1,164
Hobart	Vertical cutter, mixer	1	EA	2,778	2,778



**COLLATERAL EQUIPMENT REQUIREMENTS (Initial Outfitting)**

5ND LANTDIV 4-11010/6 (NEW 2-79)

DATE 1 JULY 80

1. ACTIVITY (Name and Location)


MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

2. PROJECT TITLE


DINING FACILITIES MODERNIZATION

P. NO. 697


COG. SYMBOL AND FED. STOCK NO. OR OTHER SOURCE	ITEM/EQUIPMENT DESCRIPTION	QUAN- TITY	UNIT OF ISSUE	UNIT PRICE	TOTAL COST
	SUBTOTAL				12,655
Hobart	<u>Building 1209</u> Vertical cutter, mixer	1	EA	2,777	<u>2,777</u>
	SUBTOTAL				2,777
Hobart	<u>Building RR-3</u> Vertical cutter, mixer	1	EA	2,778	2,778
Wasserstorm	Cold food counters w/sneeze guards	4	EA	1,837	7,348
Keating	Grill, electric, 6 ft.	2	EA	2,508	<u>5,016</u>
	SUBTOTAL				15,142
Wasserstorm	<u>Building M-424</u> Cold food counter w/sneeze guards	4	EA	1,837	7,348
Keating	Grill, electric, 6 ft.	4	EA	2,508	<u>10,032</u>
	SUBTOTAL				17,380
Keating	<u>Building 508</u> Griddle, electric, 6 ft.	2	EA	2,508	5,016
Victory	Reefer, reach in	1	EA	2,310	<u>2,310</u>
	SUBTOTAL				7,326
	Fire Extinguishers for all blds.	24	EA	75	<u>1,800</u>
	TOTAL EXPENSE ITEMS				57,080
	Shipping, packing, handling, installation charges and con- tingencies - 10%				5,700
3. <u>INVESTMENT ITEMS</u>	NONE				
4. <u>APA EQUIPMENT</u>	NONE				
5. <u>TRAINING EQUIPMENT</u>	NONE				
6. <u>OTHER EXPENSES</u>	NONE				
7. <u>EQUIPMENT ON HAND</u>	NONE				
8. <u>SUMMARY</u>	Expense Cost				62,780
















ENERGY ANALYSIS  
SUMMARY

ATLANTIC DIVISION NAVAL FACILITIES ENGINEERING COMMAND

Const. Contr. No. \_\_\_\_\_

NORFOLK, VIRGINIA

DATE 1 JULY 80

PROJECT DINING FACILITIES MODERNIZATION MARINE CORPS BASE  
LOCATION CAMP LEJEUNE, NORTH CAROLINA  PRELIM.  FINAL

DESCRIPTION	REMARKS	BENEFIT/ COST	E/C	YEAR PAYBACK	CURRENT WORKING ESTIMATE	ANNUAL SAVINGS	TOTAL MBTU/YR	( ) MBTU/YR	( ) MBTU/YR	( ) MBTU/
BUILDING RR-3										
1. Storm Windows				3	2,763	1,397	112.85			
2. Ceiling Insulation				1	15,538	16,789	1383.			
3. Wall Insulation				5	14,206	3,174	258.			
4. Solar Dom. HW.				9	10,086	839	39.15			
5. Solar Htg. & DHW	SolCost calculations proved not practical									
6. HW. Recovery	Not practical									
7. Exhaust Air Heat Recovery	Not practical (analysis not made)									
8. Condensate	Condensate is recovered and is pumped to Central Energy plant (analysis not made)									

ENCLOSURE 6







DEPARTMENT OF THE NAVY  
PROJECT ENGINEERING DOCUMENTATION

DINING FACILITIES  
MODERNIZATION

(P-697)

FY 1982 MCON

MARINE CORPS BASE  
CAMP LEJEUNE  
NORTH CAROLINA

ADMINISTERED BY:  
ATLANTIC DIVISION  
NAVAL FACILITIES  
ENGINEERING COMMAND  
NORFOLK, VA. 23511

PREPARED BY:  
ODELL ASSOCIATES, INC.  
222 S. CHURCH ST.  
CHARLOTTE, N.C. 28202



1. COMPONENT NAVY		FY 19 <u>82</u> MILITARY CONSTRUCTION PROJECT DATA		2. DATE 1 JULY 80	
3. INSTALLATION AND LOCATION MARINE CORPS BASE CAMP LEJEUNE, NORTH CAROLINA			4. PROJECT TITLE DINING FACILITIES MODERNIZATION		
5. PROGRAM ELEMENT	6. CATEGORY CODE 722-10	7. PROJECT NUMBER P-697	8. PROJECT COST (\$000) <del>\$5,700</del> 5600		

**9. COST ESTIMATES**

Escalation 14%	ITEM	Bid opening date		U/M	QUANTITY	UNIT COST	COST (\$000)
		1 JANUARY 82					
	Dining Facility Modernization			SF	102,975	\$ 44.14	\$4,482
	Buildings			SF	102,975	38.55	(3,909)
	Built in equipment			LS			( 512)
	Solar Systems			LS			( 61)
	Supporting Facilities						353
	Utilities			LS			( 323)
	Site Improvements			LS			( 30)
	Subtotal						\$4,835
	Contingency (10%)						484
	Total Contract Cost						\$5,319
	Supervision Inspection and Overhead (5.5%)						292
	Total Request						\$5,611
	Total Request (Rounded)						\$5,600
	Equipment provided from other appropriations						(63)

**10. DESCRIPTION OF PROPOSED CONSTRUCTION**


Interior renovations consisting of new wall coverings, new doors, installation of decorative partitions, omit alternate windows in dining wings, providing new lowered ceilings, air conditioning, insulation, fluorescent fixtures; installation of terrazzo and quarry tile on floor, miscellaneous carpentry, plumbing, masonry, mechanical work, painting, site improvements, and related work. (Air conditioning; 285 tons)

11. REQUIREMENTS: 25,946 PN. ADEQUATE: 17,230 PN. SUBSTANDARD: 10,118 PN.  
PROJECT: Renovate the existing enlisted dining facilities, Buildings 1209, M424, 508, RR3, BA103.


REQUIREMENT: The alterations and renovations are considered essential to solve the major problems of poor atmosphere, personnel traffic flow, efficiency of layout, maintenance and cleanliness, durability and flexibility of facilities used.

CURRENT SITUATION: The facilities are in a general run-down condition with little modernization since their construction over 37 years ago. The overall condition and configuration of the existing facilities does not present an environment for efficient or maximum utilization.

IMPACT IF NOT PROVIDED: Continued use of inefficient and outdated dining facilities.



1. COMPONENT NAVY	FY 19 <u>82</u> MILITARY CONSTRUCTION PROJECT DATA	2. DATE 1 JULY 80
3. INSTALLATION AND LOCATION MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA		
4. PROJECT TITLE DINING FACILITIES MODERNIZATION	5. PROJECT NUMBER P 697	
<p><u>ENVIRONMENTAL IMPACT</u> The Environmental Impact Assessment has been reviewed, and where required, the design concepts give consideration to eliminating adverse environmental effects consistent with applicable directives.</p> <p><u>PRESERVATION OF HISTORICAL SITES AND STRUCTURES</u> The project facilities do not directly or indirectly affect a district, site, building, structure, object or setting which is listed in the National Register or otherwise possesses a significant quality of American history.</p> <p><u>FALLOUT SHELTER CONSTRUCTION</u> Fallout shelter excluded - - Shelter not economically feasible as part of this project.</p> <p><u>FLOOD HAZARDS EVALUATION</u> Requirements of Executive Order No. 11988 (Flood plain Management) and Executive Order No. 11990 (Protection of Wetlands) are not applicable.</p> <p><u>POLLUTION, PREVENTION, ABATEMENT AND CONTROL</u> This project will not cause additional air or water pollution.</p> <p><u>DESIGN FOR ACCESSIBILITY OF PHYSICALLY HANDICAPPED PERSONNEL</u> Provisions for physically handicapped personnel not required in preparation and service areas of the facilities, since its use is specifically restricted to able-bodied military personnel. However, a dining area in each building will be made accessible to the handicapped and public toilets will be outfitted for the handicapped.</p>		



BUDGET ESTIMATE SUMMARY SHEET FOR P-697

Title: DINING FACILITIES MODERNIZATION

Costs Escalated to: 1 JAN 82

Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%


Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%

	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT
BUILDINGS 1209, M424, 508, RR-3, BA-103			102,975 SF			
Foundation	.379	N/A	N/A	39,000	39,000	0
Slab on Grade	.447	N/A	N/A	46,000	46,000	0
Structural Frame	.767	N/A	N/A	79,000	79,000	0
Supported Floor	0	N/A	N/A	0	0	0
Roof	.767	N/A	N/A	79,000	79,000	0
Exterior Walls	1.729	N/A	N/A	178,000	178,000	0
Interior Walls	.719	N/A	N/A	74,000	74,000	0
Interior Finishes	8.886	N/A	N/A	915,000	915,000	0
Doors and Windows	2.593	N/A	N/A	267,000	267,000	0
Specialties	.923	N/A	N/A	95,000	95,000	0
Plumbing	4.758	N/A	N/A	490,000	490,000	0
Mechanical	9.002	N/A	N/A	927,000	927,000	0
Electrical	7.000	N/A	N/A	720,000	720,000	0
Equipment	4.972	N/A	N/A	512,000	0	512,000
SUBTOTAL						
Solar Systems	.60	50.80	1210 Coll.SF	61,000	61,000	0
Sub-Total Building	43.53			\$4,482,000	\$3,970,000	\$*512,000

Piling						*
Elec. Substation & Dist.	2.93	N/A	N/A	302,000	302,000	
Not Used						*
Telephone & Fire Alarm						
Water Distribution						
Sanitary Sewers	.204	N/A	N/A	21,000	21,000	
Roads, Parking, Sidewalks						*
Storm Sewers						*
Site Improvements	.291	N/A	N/A	30,000	30,000	
Demolition (In ea. sys. above)						*
Sub-Total Supporting Facilities						* \$ 353,000

Total Estimated Contract Cost: 1 Jan 82	\$ 4,835,000
Contingency 10 %	\$ 483,500
SIOH 5.5%	\$ 292,517
Total Budget Cost	\$ 5,611,017
Rounded	\$ 5,600,000

\*Asteric indicates these totals on 1391.



BUDGET ESTIMATE SUMMARY SHEET FOR P-697

Title: DINING FACILITIES MODERNIZATION

Costs Escalated to: 1 JAN 82


Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%

Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%

	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT
BUILDING 1209			22,530 SF			
Foundation	.400	N/A	N/A	9,023	9,023	0
Slab on Grade	.616	N/A	N/A	13,883	13,883	0
Structural Frame	.836	N/A	N/A	18,825	18,825	0
Supported Floor	0	N/A	N/A	0	0	0
Roof	.768	N/A	N/A	17,298	17,298	0
Exterior Walls	1.953	N/A	N/A	43,995	43,995	0
Interior Walls	.881	N/A	N/A	19,855	19,855	0
Interior Finishes	9.742	N/A	N/A	219,488	219,488	0
Doors and Windows	2.562	N/A	N/A	57,731	57,731	0
Specialties	1.102	N/A	N/A	24,829	24,829	0
Plumbing	6.320	N/A	N/A	142,393	142,393	0
Mechanical	10.013	N/A	N/A	225,585	225,585	0
Electrical	7.54	N/A	N/A	169,971	169,971	0
Equipment	4.701	N/A	N/A	105,928	0	105,928
SUBTOTAL						
Solar Systems	.80	47.69	380 Coll.SF	18,123	18,123	0
Sub-Total Building	48.24			\$1,086,927	\$*980,999	\$*105,928
Piling			0	0	0	* 0
Elec. Substation & Dist.	2.75	N/A	N/A	62,000	62,000	0
Not Used			0	0	0	* 0
Telephone & Fire Alarm			0	0	0	0
Water Distribution			0	0	0	0
Sanitary Sewers	.106	N/A	N/A	2,381	2,381	0
Roads, Parking, Sidewalks			0	0	0	* 0
Storm Sewers			0	0	0	* 0
Site Improvements	.150	N/A	N/A	3,371	3,371	0
Demolition (In ea. sys. above)			0	0	0	* 0
Sub-Total Supporting Facilities						* \$ 67,752

Total Estimated Contract Cost: 1 Jan 82	\$ 1,154,679
Contingency 10 %	\$ 115,468
SIOH 5.5%	\$ 69,858
Total Budget Cost	\$ 1,340,005
Rounded	\$ 1,300,000

\*Asteric indicates these totals on 1391.



Title: DINING FACILITIES MODERNIZATION

Costs Escalated to: 1 JAN 82

Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%


Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%

	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT
BUILDING M424			22,530 SF			
Foundation	.534	N/A	N/A	12,036	12,036	0
Slab on Grade	.616	N/A	N/A	13,883	13,883	0
Structural Frame	.989	N/A	N/A	22,275	22,275	0
Supported Floor	0	N/A	N/A	0	0	0
Roof	.910	N/A	N/A	20,496	20,496	0
Exterior Walls	2.121	N/A	N/A	47,787	47,787	0
Interior Walls	.924	N/A	N/A	20,814	20,814	0
Interior Finishes	9.690	N/A	N/A	218,320	218,320	0
Doors and Windows	3.240	N/A	N/A	73,007	73,007	0
Specialties	1.243	N/A	N/A	28,016	28,016	0
Plumbing	6.466	N/A	N/A	145,682	145,682	0
Mechanical	10.013	N/A	N/A	225,585	225,585	0
Electrical	8.90	N/A	N/A	200,564	200,564	0
Equipment	6.599	N/A	N/A	148,680	0	148,680
SUBTOTAL						
Solar Systems	.80	47.69	380 Coll. SF	18,123	18,123	0
Sub-Total Building	53.05			\$1,195,268	\$*1,046,588	\$*148,680

Piling			0	0	0	* 0
Elec. Substation & Dist.	2.80	N/A	N/A	63,000	63,000	0
Not Used			0	0	0	* 0
Telephone & Fire Alarm			0	0	0	0
Water Distribution			0	0	0	0
Sanitary Sewers	.106	N/A	N/A	2,381	2,381	0
Roads, Parking, Sidewalks			0	0	0	* 0
Storm Sewers			0	0	0	* 0
Site Improvements	.431	N/A	N/A	9,712	9,712	0
Demolition (In ea. sys. above)			0	0	0	* 0
Sub-Total Supporting Facilities				* \$ 75,093		

Total Estimated Contract Cost: 1 Jan 82	\$ 1,270,361
Contingency 10 %	\$ 127,036
SIOH 5.5%	\$ 76,857
Total Budget Cost	\$ 1,474,254
Rounded	\$ 1,450,000

\*Asteric indicates these totals on 1391.



BUDGET ESTIMATE SUMMARY SHEET FOR P-697

Title: DINING FACILITIES MODERNIZATION

Costs Escalated to: 1 JAN 82

Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%

Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%


	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT
BUILDING 508			22,475 SF			
Foundation	.378	N/A	N/A	8,499	8,499	0
Slab on Grade	.381	N/A	N/A	8,562	8,562	0
Structural Frame	.609	N/A	N/A	13,681	13,681	0
Supported Floor	0	N/A	N/A	0	0	0
Roof	.760	N/A	N/A	17,073	17,073	0
Exterior Walls	1.483	N/A	N/A	33,336	33,336	0
Interior Walls	.633	N/A	N/A	14,225	14,225	0
Interior Finishes	10.074	N/A	N/A	226,411	226,411	0
Doors and Windows	2.014	N/A	N/A	45,262	45,262	0
Specialties	.744	N/A	N/A	16,720	16,720	0
Plumbing	5.247	N/A	N/A	117,934	117,934	0
Mechanical	7.761	N/A	N/A	174,428	174,428	0
Electrical	5.70	N/A	N/A	128,087	128,087	0
Equipment	3.744	N/A	N/A	84,152	0	84,152
SUBTOTAL						
Solar Systems	.45	56.03	180 SF	10,086	10,086	0
Sub-Total Building	39.98			\$898,456	\$*814,304	\$*84,152

Piling			0	0	0	* 0
Elec. Substation & Dist.	2.80	N/A	N/A	63,000	63,000	0
Not Used			0	0	0	* 0
Telephone & Fire Alarm			0	0	0	0
Water Distribution			0	0	0	0
Sanitary Sewers	.530	N/A	N/A	11,905	11,905	0
Roads, Parking, Sidewalks			0	0	0	* 0
Storm Sewers			0	0	0	* 0
Site Improvements	.513	N/A	N/A	11,533	11,533	0
Demolition (In ea. sys. above)			0	0	0	* 0

Sub-Total Supporting Facilities \* \$ 86,438

Total Estimated Contract Cost: 1 Jan 82	\$ 984,894
Contingency 10 %	\$ 98,489
SIOH 5.5%	\$ 59,586
Total Budget Cost	\$ 1,142,969
Rounded	\$ 1,150,000

\*Asteric indicates these totals on 1391.



Title: DINING FACILITIES MODERNIZATION Costs Escalated to: 1 JAN 82


Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%

Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%

	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT
BUILDING RR-3			22,475 SF			
Foundation	.250	N/A	N/A	5,636	5,636	0
Slab on Grade	.140	N/A	N/A	3,155	3,155	0
Structural Frame	.747	N/A	N/A	16,785	16,785	0
Supported Floor	0	N/A	N/A	0	0	0
Roof	.762	N/A	N/A	17,134	17,134	0
Exterior Walls	1.473	N/A	N/A	33,113	33,113	0
Interior Walls	.457	N/A	N/A	10,272	10,272	0
Interior Finishes	5.439	N/A	N/A	122,237	122,237	0
Doors and Windows	1.806	N/A	N/A	40,590	40,590	0
Specialties	.588	N/A	N/A	13,210	13,210	0
Plumbing	1.960	N/A	N/A	44,042	44,042	0
Mechanical	7.761	N/A	N/A	174,428	174,428	0
Electrical	5.70	N/A	N/A	128,087	128,087	0
Equipment	3.603	N/A	N/A	80,971	0	80,971
SUBTOTAL						
Solar Systems	.45	56.03	180 Coll.SF	10,086	10,086	0
Sub-Total Building	31.13			\$699,746	*\$ 618,775	*\$ 80,971
Piling			0	0	0	* 0
Elec. Substation & Dist.	2.80		N/A	63,000	63,000	0
Not Used			0	0	0	* 0
Telephone & Fire Alarm			0	0	0	0
Water Distribution			0	0	0	0
Sanitary Sewers	.106		N/A	2,381	2,381	0
Roads, Parking, Sidewalks			0	0	0	* 0
Storm Sewers			0	0	0	* 0
Site Improvements	.124		N/A	2,792	2,792	0
Demolition (In ea. sys. above)			0	0	0	* 0
Sub-Total Supporting Facilities				* \$ 68,173		

Total Estimated Contract Cost: 1 Jan 82	\$ 767,919
Contingency 10 %	\$ 76,792
SIOH 5.5%	\$ 46,459
Total Budget Cost	\$ 891,170
Rounded	\$ 890,000

\*Asteric indicates these totals on 1391.



BUDGET ESTIMATE SUMMARY SHEET FOR P-697

Title: DINING FACILITIES MODERNIZATION

Costs Escalated to: 1 JAN 82

Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA Escalation: 14%


Prepared by: Odell Associates Inc. Date: 1 July 80 Contingency: 10%

	\$/SF	S/SYS	SYS QUAN	TOTAL	BUILDING	BUILT-IN EQUIPMENT
BUILDING BA-103			12,965 SF			
Foundation	.299	N/A	N/A	3,880	3,880	0
Slab on Grade	.527	N/A	N/A	6,837	6,837	0
Structural Frame	.603	N/A	N/A	7,816	7,816	0
Supported Floor	0	N/A	N/A	0	0	0
Roof	.563	N/A	N/A	7,299	7,299	0
Exterior Walls	1.507	N/A	N/A	19,533	19,533	0
Interior Walls	.668	N/A	N/A	8,659	8,659	0
Interior Finishes	9.927	N/A	N/A	128,709	128,709	0
Doors and Windows	3.860	N/A	N/A	50,047	50,047	0
Specialties	.933	N/A	N/A	12,098	12,098	0
Plumbing	3.095	N/A	N/A	40,125	40,125	0
Mechanical	9.812	N/A	N/A	127,210	127,210	0
Electrical	7.15	N/A	N/A	92,755	92,755	0
Equipment	6.780	N/A	N/A	87,904	0	87,904
SUBTOTAL						
Solar Systems	.39	56.03	90 Coll.SF	5,045	5,045	0
Sub-Total Building	46.12			\$597,917	*\$510,013	*\$87,904

Piling			0	0	0	* 0
Elec. Substation & Dist.	3.93	N/A	N/A	51,000	51,000	0
Not Used			0	0	0	* 0
Telephone & Fire Alarm			0	0	0	0
Water Distribution			0	0	0	0
Sanitary Sewers	.184	N/A	N/A	2,381	2,381	0
Roads, Parking, Sidewalks			0	0	0	* 0
Storm Sewers			0	0	0	* 0
Site Improvements	.215	N/A	N/A	2,792	2,792	0
Demolition (In ea. sys. above)			0	0	0	* 0
Sub-Total Supporting Facilities				* \$ 56,173		

Total Estimated Contract Cost: 1 Jan 82	\$ 654,090
Contingency 10 %	\$ 65,409
SIOH 5.5%	\$ 39,572
Total Budget Cost	\$ 759,071
Rounded	\$ 760,000

\*Asteric indicates these totals on 1391.



## DESIGN CONCEPTS

Activity and Location: MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

Project Title: DINING FACILITIES MODERNIZATION (P-697)

Date: 1 JULY 1980

### USE OF DEFINITIVES AND PREVIOUS DESIGNS

Although definitives for Dining Facilities have been superseded, Definitives 1286674, 75, 76, and 77 were used for reference during design of interior functions and equipment layout. The scope of the modernization of the facilities does not warrant use of existing definitives.

### SPECIAL DESIGN CHARACTERISTICS

Floor Plan: Existing building layout limited modernization approach. However, new locations for entries, toilets, serving line equipment and sculleries are proposed in order to relieve present internal cross traffic patterns of inefficiency.


Ventilation: Heat, humidity and odors produced during facility use require new ventilation in following areas: Bakery, Pot Wash, Scullery, Food Service, Garbage Rooms, Toilets and Attics above air conditioned spaces.

Air Conditioning is provided for all dining areas, salad prep areas, and offices.

Finishes: Terrazzo floors and quarry tile floor and wainscots are planned for all major spaces not presently finished as such in order to create sanitary and easily maintainable surfaces.


### ENERGY CONSERVATION AND SOLAR ENERGY

1. Energy Conservation: The following energy conservation measures were considered and analyzed for the design of this building:
  - a. Insulation in wall: The benefit/cost was computed for two (2) representative buildings, M424 and 508, using Trace computer program to determine the reduction in building heating and cooling loads due to installation of additional insulation in the wall. Results are tabulated in "Summary of Energy Conservation Analysis."



- b. Insulation in Attic: The benefit/cost was computed for two (2) representative buildings, M424 and 508, using Trace computer program to determine the reduction in building heating and cooling loads due to installation of additional insulation in the attic. Results are tabulated in "Summary of Energy Conservation Analysis."
  - c. Exhaust Heat Recovery: A run around coil was considered for computing exhaust heat recovery from scullery to preheat outside air makeup for buildings M424 and 508. System CFM not of feasible capacity. Kitchen hoods use untempered makeup air with only 20 percent tempered air from dining.
  - d. Hot Water Recovery: Heat recovery from pot sink and dish machines was considered for preheating make-up water for the hot water heater for building M424 and 508. The locations of the various hot water using equipment makes it impractical to collect waste hot water for reclaiming heat. Very long pipe runs, intermediate sumps and pumping to a central location close to the domestic hot water heater will have to be provided so that make-up water can be preheated. This conservation feature is, therefore, not considered feasible.
  - e. Condensate Heat Recovery: Since condensate is returned back to central system, heat recovery at this use terminal would not be feasible. Condensate recovery would be considered more feasible at the central energy plant.
  - f. Storm Windows for Existing Windows: Approximately 45 percent of the windows in the dining areas are removed and blocked up for other than energy savings reasons. The balance of the windows in occupied spaces were considered for adding storm windows and were determined to be feasible.
  - g. Vestibules: Vestibules are proposed for all major entrances and exits by simply adding doors to 10 existing vestibule areas, adding two complete vestibules and maintaining six existing vestibules. No detail analysis was made, since the construction cost was so small.
2. Solar Energy: The feasibility of Solar Energy Systems for the five buildings was determined by the "Solcost" computer program. Two of the five buildings (508, M424), were run on the computer. Two buildings (RR-3, 1209) were nearly identical to the two run. Solar systems to BA-103 (similar shape to 508) were scaled down from building 508 sizes. Domestic hot water is based on people served while space heating is based on area of building.

Two alternatives were considered: (1) domestic hot water and (2) domestic hot water combined with space heating. The combined system was considered since the design will integrate both aspects into one system.



Each building was determined to be feasible within the limits of Government criteria for solar assisted Domestic Hot Water heating only. See charts indicating Solar Collector Sizing. Listed below is statistical information (totals for all buildings).

---

a.	Type system included:	DOMESTIC HOT WATER HEATING
b.	Type collector:	Single glazed flat plate
c.	Area collector, all buildings:	1,210 square feet
d.	Systems cost, all buildings:	\$61,463
e.	Annual energy savings:	Barrels of oil equivalent = 44.5
f.	Percent energy contribution from solar system to DHW Heat:	83%
g.	Payback:	9 years
h.	System design cost:	\$30,000

---

The combined domestic hot water and space heating system is not economically feasible.

3. An economic study was made to provide a basis for selection of an HVAC system. A Variable Temperature Constant Volume System was compared with a Variable Air Volume System with Reheat serving Dining Areas, Packaged Terminal Air Conditioning Units serving certain support areas and Perimeter Radiation serving total building except for areas served by Variable Air Volume System with Reheat.


Analysis proved that the Variable Temperature Constant Volume Systems will provide a lower present worth.

4. Energy Monitoring and Control System (EMCS):

- a. Camp Lejeune's present EMCS is set up to operate or monitor the following:
- 1) Stop and start of each air conditioning unit.
  - 2) Room supply air flow status.
  - 3) Room temperature of each area.
- b. Telephone lines are used for transmission of signal from each building to the master monitoring unit (CPU).
- c. Each building will require a field panel to be installed.
- d. The electric power, steam and fire alarm system are not to be monitored at this time.

5. Energy Summary: The analysis of energy conserving measures (listed on Energy Analysis Summary) indicates feasibility of several features:

- a. The following features are feasible and have been incorporated into the project, and the cost is included in the building costs:



- 1) Insulation of walls of AC space
- 2) Insulation of ceiling of AC space
- 3) Solar assisted domestic hot water heating
- 4) Storm windows

b. The following features are not feasible and have not been incorporated into the project:

- 1) Hot water recovery
- 2) Exhaust air heat recovery
- 3) Condensate heat recovery
- 4) Solar space heating

#### POLLUTION ABATEMENT ASPECTS OF DESIGN

No pollution of air, water, noise, erosion, etc., is anticipated resulting from the work proposed in this project; therefore, no need for permits from authorities in this regard is anticipated.

Additional toilet fixtures added to each building will be tied into the existing building sewer, therefore negating the need to tie into sanitary sewer at additional connection points. The additional quantity of discharge for each building is anticipated as identified below:

Building 1209	3240 GPD
Building M424	3240 GPD
Building 508	1620 GPD
Building RR3	1620 GPD
Building BA103	810 GPD


The additional discharge is anticipated to be absorbed within the existing sanitary sewers and the effluent is anticipated to be handled by existing treatment plant.

#### SITE APPROVAL

The five separate sites involved with this project have been approved as described in letter CMC, LFF-1-AJR:bab of January 11, 1980.

#### ECONOMIC ANALYSIS

Economic analyses were done on two Base Buildings M424 and 508 for the considerations mentioned in the ENERGY SUMMARY. Since Building 1209 is similar to M424, it is deduced that all energy conservation measures applicable to M424 can be used for Building 1209. Similarly, Building 508 measures are applicable to RR3. Since Building BA103 is also similar to 508 and half as large in area as 508, energy conservation measures are applied to this building, providing half the credit that can be obtained




from conservation and solar contributions. The building loads for the base buildings are calculated on a Trace program, and economic analyses of system type and equipment to be used for the heating, ventilating, and air conditioning for these base buildings are selected based on a TRACE computer program.

SPECIAL ENGINEERING SERVICES


None Required.

CONTINGENCY ALLOWANCE

A 10% contingency allowance is considered as necessary at this phase of design since the project involves remodeling of (5) individual buildings over 30 years old.




$$\begin{aligned}
 LCS &= \text{ENERGY REQD} \times \text{ENERGY COST} \times \text{PRESENT VALUE FACTOR} \\
 &= 18.84 \times 10^6 \text{ BTU/YR} \times 12.53 \text{¢/}10^6 \text{ BTU} \times 80.23 \\
 &= 79,256.
 \end{aligned}$$




AREA	100 FIRST COST	200 F	300 SAVINGS	Δ\$	400 SF COLLECTOR
40	1908	.284	22509	20601	
80	3816	.495	39232	35416	
120	5724	.656	51992	46268	
140	6618	.722	57223	50545	
180	8586	.828	65624	57038	
220	10494	.903	71568	61074	
260	12402	.950	75293	62891	
300	14310	.970	76819	62569	
340	16218	.983	77909	61691	

SOLAR COLLECTOR SIZING




$$\begin{aligned}
 \text{LCS} &= \text{ENERGY REQD.} \times \text{ENERGY COST} \times \text{PRESENT VALUE FACTOR} \\
 &= 157.68 \times \text{BTU/YR} \times \$12.53 \text{ MIL BTU} \times 80.23 \\
 &= \$153,513
 \end{aligned}$$



AREA	FIRST COST	f	SAVINGS	Δ\$
80	3822	.283	44859	41037
160	7643	.496	78623	70980
240	11465	.662	104936	93471
300	14331	.760	120470	106139
380	18152	.859	136163	118011
460	21974	.931	147576	125602
540	25796	.960	152173	126377
620	29617	.979	155184	125567
700	33439	.989	156770	123331

SOLAR COLLECTOR SIZING



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDINGS 1209, M424, 508, RR-3 AND BA103

MARINE CORPS BASE

DINING FACILITY MODERNIZATION (P-697)

1 JULY 80

$E_{75} = 17,2002 \times 10^6$  BTU/Yr (Total annual energy consumption, 75)

$E_{\text{Current}} = 9467 \times 10^6$  BTU/Yr (Total annual energy consumption incorporating current criteria)

$R = (1 - (E_{\text{Current}}/E_{75})) \times 100 = 44.9$  (Percent reduction in energy consumption current year vs. existing situation)

$ECC = 4,253,700$  (Estimated construction cost for current criteria)

Barrels of Oil Equivalent (B.O.E.) = 1360 \*(Barrels of Fuel Oil Saved, Current Design vs. 1975)  
5,825,400 BTU/B.O.E.

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	$10^6$ BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	$10^6$ BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000)
1.	Insulate Walls	1,189	204.	5.82	16011	6.9	155,484	6.9	82.1	4,687
2.	Insulate Ceiling	5,694	1262.	4.51	10317	33.1	100,189	40.0	69.2	4,757
3.	Storm Windows	591	139.	4.25	9726	3.4	94,450	43.4	15.5	4,773.5
4.	Solar Domestic HW	259	384.	.67	9467	1.5	91,934	44.9	61.5	4,835



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDING 1209

MARINE CORPS BASE

DINING FACILITY MODERNIZATION (P-697)

1 JULY 80

$E_{75} = 3708 \times 10^6$  BTU/Yr (Total annual energy consumption, 75)

$E_{\text{Current}} = 2179 \times 10^6$  BTU/Yr (Total annual energy consumption incorporating current criteria)

$R = (1 - (E_{\text{Current}}/E_{75})) \times 100 = 41.2$  (Percent reduction in energy consumption current year vs. existing situation)

$ECC = 1,026,700$  (Estimated construction cost for current criteria)

Barrels of Oil Equivalent (B.O.E.) = 295 \*(Barrels of Fuel Oil Saved, Current Design vs. 1975)  
5,825,400 BTU/B.O.E.

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	$10^6$ BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	$10^6$ BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000)
1.	Insulate Walls	272	42.	6.47	3,436	7.3	152,507	7.3	23.2	1,117.9
2.	Storm Windows	154	33.	4.66	3,282	4.1	145,672	11.4	4.3	1,122.2
3.	Insulate Ceiling	1,022	224.	4.56	2,260	27.5	100,310	38.9	14.7	1,136.9
4.	Solar Domestic HW	81	121.	.67	2,179	2.2	96,715	41.2	18.1	1,155



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDING M424

MARINE CORPS BASE      DINING FACILITY MODERNIZATION (P-697)      1 JULY 80

E75 = 3900 x 10<sup>6</sup> BTU/Yr (Total annual energy consumption, 75)

E Current = 2179 x 10<sup>6</sup> BTU/Yr (Total annual energy consumption incorporating current criteria)

R = (1 - (E Current/E75) ) 100 = 44.1 (Percent reduction in energy consumption current year vs. existing situation)

ECC=1,132,000 (Estimated construction cost for current criteria)

Barrels of Oil Equivalent (B.O.E.) = 295      \*(Barrels of Fuel Oil Saved, Current Design vs. 1975)  
5,825,400 BTU/B.O.E.

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	10 <sup>6</sup> BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	10 <sup>6</sup> BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000)
1.	Insulate Walls	272	42.	6.47	3,628	7.0	161,030	7.0	23.2	1,230.2
2.	Storm Windows	154	33.	4.66	3,474	3.9	154,194	10.9	4.3	1,234.5
3.	Insulate Ceiling	1,214	266.	4.56	2,260	31.1	100,311	42.0	17.4	1,251.9
4.	Solar Domestic HW	81	121.	.67	2,179	2.1	96,715	44.1	18.1	1,270



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDING 508

MARINE CORPS BASE      DINING FACILITY MODERNIZATION (P-697)      1 JULY 80

E75 = 3769 x 10<sup>6</sup> BTU/Yr (Total annual energy consumption, 75)


E Current = 1976 x 10<sup>6</sup> BTU/Yr (Total annual energy consumption incorporating current criteria)

R = (1 - (E Current/E75) ) 100 = 47.5 (Percent reduction in energy consumption current year vs. existing situation)

ECC=855,400 (Estimated construction cost for current criteria)

Barrels of Oil Equivalent (B.O.E.) = 307      \*(Barrels of Fuel Oil Saved, Current Design vs. 1975)  
5,825,400 BTU/B.O.E.

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	10 <sup>6</sup> BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	10 <sup>6</sup> BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000).
1.	Insulate Walls	258	48.	5.38	3,511	6.8	156,218	6.8	14.2	956.6
2.	Storm Windows	113	25.	4.52	3,398	3.0	151,190	9.8	2.8	959.4
3.	Insulate Ceiling	1,383	309.	4.47	2,015	36.7	89,655	46.5	15.5	974.9
4.	Solar Domestic HW	39	57.	.68	1,976	1.0	87,920	47.5	10.1	985



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDING RR-3

MARINE CORPS BASE

DINING FACILITY MODERNIZATION (P-697)

1 JULY 80

$$E75 = 3769 \times 10^6 \text{ BTU/Yr (Total annual energy consumption, 75)}$$

$$E \text{ Current} = 1976 \times 10^6 \text{ BTU/Yr (Total annual energy consumption incorporating current criteria)}$$

$$R = (1 - (E \text{ Current}/E75)) \times 100 = 47.5 \text{ (Percent reduction in energy consumption current year vs. existing situation)}$$

$$ECC=657,400 \text{ (Estimated construction cost for current criteria)}$$

$$\text{Barrels of Oil Equivalent (B.O.E.)} = 307 \text{ *(Barrels of Fuel Oil Saved, Current Design vs. 1975)}$$

$$5,825,400 \text{ BTU/B.O.E.}$$

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	10 <sup>6</sup> BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	10 <sup>6</sup> BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000).
1.	Insulate Walls	258	48.0	5.38	3,511	6.8	156,218	6.8	14.2	739.6
2.	Storm Windows	113	25.	4.52	3,398	3.0	151,190	9.8	2.8	742.4
3.	Insulate Ceiling	1,383	309.	4.47	2,015	36.7	89,655	46.5	15.5	757.9
4.	Solar Domestic HW	39	57.0	.68	1,976	1.0	87,920	47.5	10.1	768



SUMMARY OF ENERGY CONSERVATION ANALYSIS

BUILDING BA 103

MARINE CORPS BASE

DINING FACILITY MODERNIZATION (P-697)

1 JULY 80

$E_{75} = 2054 \times 10^6$  BTU/Yr (Total annual energy consumption, 75)


E Current =  $1157 \times 10^6$  BTU/Yr (Total annual energy consumption incorporating current criteria)

$R = (1 - (E \text{ Current}/E_{75})) \times 100 = 43.8$  (Percent reduction in energy consumption current year vs. existing situation)

ECC=578,400 (Estimated construction cost for current criteria)

Barrels of Oil Equivalent (B.O.E.) = 153 \*(Barrels of Fuel Oil Saved, Current Design vs. 1975)  
5,825,400 BTU/B.O.E.

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
Priority	Description Of Measure	$10^6$ BTUs Saved/Yr	Life Cycle Cost (\$1000) Expressed as present worth	(3)/(4)	$10^6$ BTUs Consumption/ Yr E	% Energy Reduction of Measure R	(6) Annual Consumption Bldg. Square Footage BTU/SF/Yr	Cumula- tive % Reduc- tion	First Cost of Measure (\$1000)	Total Construc- tion Cost (10) + ECC (\$1000).
1.	Insulate Walls	129	24.	5.38	1,925	6.3	148,476	6.3	7.2	641.6
2.	Insulate Ceiling	692	154.	4.49	1,233	33.7	95,102	40.0	6.0	647.6
3.	Storm Windows	57	23.	2.47	1,176	2.8	90,706	42.8	1.4	649
4.	Solar Domestic HW	19	28.	0.67	1,157	1.0	89,240	43.8	5.0	654



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 1209; BUILDING M424

DATE

1 JULY 80

ACTIVITY (Name and Location)

MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE

DINING FACILITIES MODERNIZATION

P NO.

P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Variable temp. constant volume split system,  
packaged terminal A/C and Fin. Rad.

ECONOMIC  
LIFE

25

YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$101,181			\$101,181
OPERATIONS Elec.		\$51,794	18.049	934,830
Steam (oil)		25,502	20.050	511,315
MAINTENANCE		2,321	9.524	22,105
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$1,569,431 ÷ DISCOUNT FACTOR 9.524 = UNIFORM ANNUAL COST \$164,787

ALTERNATIVE B Variable air volume with reheat, packaged  
terminal A/C and Fin. Rad.

ECONOMIC  
LIFE

YRS.


DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$163,601			\$163,601
OPERATIONS Elec.		\$52,183	18.049	941,851
Steam (oil)		25,372	20.050	508,709
MAINTENANCE		2,453	9.524	23,362
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$1,637,523 ÷ DISCOUNT FACTOR 9.524 = UNIFORM ANNUAL COST \$171,936


REMARKS

Alternative "A" is feasible.  
Life Cycle Cost  
Alt. A - 1,569,431  
Alt. B - 1,637,523  
L.C.C. - 68,092  
- 68 x 10<sup>3</sup>

$$S.I.R. = \frac{1,637,523}{1,569,431} = 1.04$$







ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 1209; BUILDING M424

DATE  
1 JULY 80

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Storm Windows

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$4,293			\$4,293
OPERATIONS Steam		0		
Elec.		0		
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 4,293 ÷ 9.524 = \$451 UNIFORM ANNUAL COST

ALTERNATIVE B No Storm Windows

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	0			0
OPERATIONS Steam Savings		\$1,442	20.05	\$28,912
Elec. Savings		453	18.049	8,176
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 37,088 ÷ 9.524 = \$3,894 UNIFORM ANNUAL COST

REMARKS

Alternative "A" is feasible due to lower total present value than "B".

Life Cycle Cost


Alt. A - 4,293

Alt. B - 37,088

L.C.C. - 32,795

- 33 x 10<sup>3</sup>

$$S.I.R. = \frac{37,088}{4,293} = 8.64$$



BUILDING 1209 and BUILDING M424 - STORMS

Total Window Area (Heating) = 1,596 SF  
(Cooling) = 1,281 SF

Savings from Storm Windows

1. Winter Savings

Reduction in Infiltration  $\times \Delta T \times 1.08 \times \text{SF Window}$   
+ Reduction in Transmission  $\times \Delta T \times \text{SF Window}$   
=  $0.5(1.6 - 0.8) \text{ CFM/SF} \times (68 - 23) \times 1.08 \times 1,596 \text{ SF}$   
+  $(1.04 - 0.54) \times (68 - 23) \times 1,596 \text{ SF}$   
= 66,936 BTUH  
Annual Savings in BTU's  
 $\frac{2901 \text{ HDD} \times 24 \times 66,936}{(68 - 23) \times .90(\text{Effy.})} = 115.07 \text{ MIL BTU/YR.}$

Annual Dollar Savings

$\$12.53/\text{MIL BTUS} \times 115.07 \text{ MIL BTU/YR.} = \$1,442$

2. Summer Savings

Reduction in Infiltration  $\times \Delta H \times 4.45 \times \text{SF Window}$   
+ Reduction in Transmission  $\times \Delta T \times \text{SF Window}$   
=  $0.5(0.8 - 0.4) \text{ CFM/SF} \times 12. \times 4.45 \times 1,281 \text{ SF}$   
+  $(1.04 - 0.54) \times (90 - 78) \times 1,281 \text{ SF}$   
= 21,367 BTUH  
Annual Savings in BTU's  
 $\frac{1810 \text{ CDD} \times 21,367 \text{ BTUH}}{3,413 \text{ KWH/BTU}} = 11,331 \text{ KWH}$   
or 38.67 MIL BTU/YR

Annual Dollar Savings

$\$0.04/\text{KWH} \times 11,331 \text{ KWH} = \$453$

3. Total Annual Savings from Storm Windows

$\$1,442 + \$453 = \$1,895$


4. Cost of Storm Windows

Jan 80      Jun 80      Jan 82  
 $\$2.27/\text{SF} \times 1.036 \times 1.143 = \$2.69$  represents cost to add storms to proposed  
cost for screens under equipment section.

Installation Cost of Storm Windows

$1,596 \text{ SF} \times \$2.69/\text{SF} = \$4,293$

5. Discount Factor - Use 20.050 for 25 years for oil, 8%; and use 18.049 for 25 years for electricity, 7%.



ECONOMIC ANALYSIS OF SHORE FACILITY

DATE  
1 JULY 80

BUILDING M424

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add insulation above ceiling ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT.	\$17,437			\$17,437
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A • \$ 17,437 ÷ 9.524 = \$1,831

ALTERNATIVE B Continue to operate with current losses ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	0			0
OPERATIONS Steam		\$8,305	20.05	\$166,515
OPERATIONS Elec.		6,457	18.049	116,542
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B • \$ 283,057 ÷ 9.524 = \$29,720

REMARKS

Alternative "A" is feasible due to lower total present value.

Life Cycle Cost


Alt. A - \$ 17,437

Alt. B - 283,057

L.C.C. - 265,620

- 266 x 10<sup>3</sup>

$$S.I.R. = \frac{283,057}{17,437} = 16.23$$



BUILDING M424

1. Additional insulation above ceiling

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Roof Area SF over heated space}$$

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Roof Area SF over A/C space}$$

$$U_{\text{Exist.}} = 0.44 \text{ BTU/HR}^{\circ}\text{F.SF} \quad U_{\text{New}} = 0.05 \text{ BTU/HR}^{\circ}\text{F.SF}$$

From Trace  
Heat Loss with  $U_{\text{New}} (.05)$  = 49,427 BTUH

Heat Loss with  $U_{\text{Exist.}} (.44)$   
 $\frac{49,427 \times .44}{.05}$  = 434,958 BTUH

Winter Energy Saved = 385,531 BTUH

Annual Savings in BTU's  
 $\frac{2901 \text{ HDD} \times 24 \times 385,531 \text{ BTUH}}{(68 - 23) \times .90 \text{ (Effy.)}}$  = 662.77 MIL BTU/YR.

Annual Dollar Savings  
\$12.53/MIL BTUS x 662.77 MIL BTUS/YR. = \$8,305


From Trace  
Heat Gain with  $U_{\text{New}} (.05)$  = 39,027 BTUH

Heat Gain with  $U_{\text{Exist.}} (.44)$   
 $\frac{39,027 \times .44}{.05}$  = 343,438 BTUH

Summer Energy Saved = 304,411 BTUH

Annual Savings in BTU's  
 $\frac{1810 \text{ CDD} \times 304,411 \text{ BTUH}}{3,413 \text{ KWH/BTU}}$  = 161,437 KWH/YR.  
or 551 MIL BTU/YR.

Annual Dollar Savings  
\$0.04/KWH x 161,437 KWH = \$6,457



ECONOMIC ANALYSIS OF SHORE FACILITY

DATE  
1 JULY 80

BUILDING 1209

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add insulation above ceiling

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$14,670			\$14,670
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 14,670 ÷ 9.524 = \$1,540 UNIFORM ANNUAL COST

ALTERNATIVE B Continue to operate with current losses

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	0			0
OPERATIONS Steam		\$6,988	20.05	\$140,109
Elec.		5,434	18.049	98,078
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 238,187 ÷ 9.524 = \$25,009 UNIFORM ANNUAL COST

REMARKS

Alternative "A" is feasible due to lower total present value.

Life Cycle Cost

Alt. A - \$ 14,670

Alt. B - 238,187

L.C.C. - 223,517

- 224 x 10<sup>3</sup>

$$S.I.R. = \frac{238,187}{14,670} = 16.24$$



BUILDING 1209

1. Additional insulation above ceiling

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Roof Area SF}$$

over heated space

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Roof Area SF}$$

over A/C space

$$U_{\text{Exist.}} = 0.44 \text{ BTU/HR}^\circ\text{F.SF} \quad U_{\text{New}} = 0.05 \text{ BTU/HR}^\circ\text{F.SF}$$

From Trace (for Bldg. M424)

$$\text{Heat Loss with } U_{\text{New}} (.05) = 49,427 \text{ BTUH}$$

Heat Loss with  $U_{\text{Exist.}}$  (.44)

$$\frac{49,427 \times .44}{.05} = 434,958 \text{ BTUH}$$

$$\text{Winter Energy Saved} = 385,531 \text{ BTUH}$$

Annual Savings in BTU's

$$\frac{2901 \text{ HDD} \times 24 \times 385,531 \text{ BTUH}}{(68 - 23) \times .90 \text{ (Effy.)}} = 662.77 \text{ MIL BTU/YR.}$$

or

$$\frac{12,736\text{SF}}{15,136\text{SF}} \times 662.77 = 557.78 \text{ MIL BTU/YR.}$$

for Bldg. 1209

Annual Dollar Savings

$$\$12.53/\text{MIL BTUS} \times 557.68 \text{ MIL BTUS/YR.} = \$6,988$$

From Trace

$$\text{Heat Gain with } U_{\text{New}} (.05) = 39,027 \text{ BTUH}$$

Heat Gain with  $U_{\text{Exist.}}$  (.44)

$$\frac{39,027 \times .44}{.05} = 343,438 \text{ BTUH}$$

$$\text{Summer Energy Saved} = 304,411 \text{ BTUH}$$

Annual Savings in BTU's

$$\frac{1810 \text{ CDD} \times 304,411 \text{ BTUH}}{3,413 \text{ KWH/BTU}} = 161,437 \text{ KWH/YR.}$$


or

$$\frac{12,736\text{SF}}{15,136\text{SF}} \times 161,437 = 135,839 \text{ KWH/YR.}$$

or 464 MIL BTU/YR.

Annual Dollar Savings

$$\$0.04/\text{KWH} \times 135,839 \text{ KWH} = \$5,434$$



ECONOMIC ANALYSIS OF SHORE FACILITY

DATE

BUILDING 1209; BUILDING M424

1 JULY 80

ACTIVITY (Name and Location)

MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE

DINING FACILITIES MODERNIZATION

P NO.

P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Insulate exterior walls

ECONOMIC LIFE

25

YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$23,232			\$23,232
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 23,232 ÷ 9.524 = \$2,439

ALTERNATIVE B Continue to operate with current losses

ECONOMIC LIFE

25

YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS		\$2,468	20.05	\$49,483
MAINTENANCE		882	18.049	15,919
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 65,402 ÷ 9.524 = \$6,867

REMARKS

Alternative "A" is feasible.

Life Cycle Cost


Alt. A - \$23,232

Alt. B - 65,402

L.C.C. - 42,170

- \$ 42 x 10<sup>3</sup>

$$S.I.R. = \frac{65,402}{23,232} = 2.82$$



BUILDING 1209 and BUILDING M424

2. Additional insulation in walls

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Wall Area SF} \\ \text{across heated space}$$

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Wall Area SF} \\ \text{across A/C space}$$

$$U_{\text{Exist.}} = 0.35 \text{ BTU/HR}^{\circ}\text{F.SF} \quad U_{\text{New}} = 0.15 \text{ BTU/HR}^{\circ}\text{F.SF}$$

From Trace  
Heat Loss with  $U_{\text{New}} (.15)$  = 85,932 BTUH

Heat Loss with  $U_{\text{Exist.}} (.35)$   
 $\frac{85,932 \times .35}{.15}$  = 200,508 BTUH

Energy Saved for Heating = 114,575 BTUH

Annual Energy Savings  
 $\frac{2901 \text{ HDD} \times 24 \times 114,575 \text{ BTUH}}{(68 - 23) \times .90(\text{Effy.})}$  = 196.97 MIL.BTU/YR.

Annual Dollar Savings  
\$12.53/MIL BTUS x 196.97 MIL BTUS/YR. = \$2,468


From Trace  
Heat Gain with  $U_{\text{New}} (.15)$  = 31,166 BTUH

Heat Gain with  $U_{\text{Exist.}} (.35)$   
 $\frac{31,166 \times .35}{.15}$  = 72,721 BTUH

Energy Saved for Cooling = 41,555 BTUH

Annual Energy Savings  
 $\frac{1810 \text{ CDD} \times 41,555 \text{ BTUH}}{3,413}$  = 22,038 KWH/YR  
or 75.22 MIL BTU/YR.

Annual Dollar Savings  
\$0.04/KWH x 22,038 KWH = \$882



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 1209 and BUILDING M424

DATE  
1 JULY 80

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION  
DESCRIPTION OF ALTERNATIVES

P NO.  
P-697

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Solar Domestic Hot Water ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	18,125			18,125
OPERATIONS Oil (Steam)		244	80.23	19,581
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A = \$ 37,706 ÷ DISCOUNT FACTOR = UNIFORM ANNUAL COST

ALTERNATIVE B Conventional Steam ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS Oil (Steam)		1,976	80.23	158,534
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B = \$ 158,534 ÷ DISCOUNT FACTOR = UNIFORM ANNUAL COST

REMARKS

Alternate A is feasible.

Life Cycle Cost

Alt. A - \$ 37,706

Alt. B - 158,534


L.C.C. - 120,828

- \$121 x 10<sup>3</sup>

$$S.I.R. = \frac{158,534}{37,706} = 4.2$$

$$\text{Payback} = \frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{18,125}{1,732} = 10.5$$


From Enclosure 14 = Less than 8 years. Encl 7



BUILDING 1209 AND BUILDING M424 - SOLAR DHW  
SOLAR ANALYSIS

1. Investment Cost: Back-up estimate esc. to 1 January 82.
2. Energy Cost: FY 80    FY 81    FY 82  
Steam (Oil) \$9.27/Mil BTU x 1.04 x 1.14 x 1.14 = 12.53/Mil BTU
3. Energy Consumption  
Alternate A  
    Auxiliary Energy Required = 19.44 MBTU/YR\*  
    Cost of Aux. Energy 19.44 x 12.53 = \$244  
  
Alternate B  
    Conventional Energy Required = 157.68 MBTU/YR\*  
    Cost of Conventional Energy = 157.68 x 12.53 = \$1,976
4. Discount Factor - Use 80.23 for 25 years for oil from enclosure 14 (FY 82)
5. Payback =  $\frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{18,125}{1,732} = 10:5$   
  
From Enclosure 14 = Less Than 8 years.

\* Refer to SOLCOST analysis



ECONOMIC ANALYSIS OF SHORE FACILITY

DATE  
1 JULY 80

BUILDING 508 and BUILDING RR3

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES  
See Below

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Variable temperature constant volume split ECONOMIC LIFE 25 YRS.  
system, packaged terminal A/C and Fin. Rad.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$87,249			\$ 87,249
OPERATIONS Elec.		\$51,836	18.049	935,588
OPERATIONS Steam (oil)		21,914	20.050	439,376
MAINTENANCE		2,213	9.524	21,077
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 1,483,290 ÷ DISCOUNT FACTOR 9.524 = UNIFORM ANNUAL COST \$155,742


ALTERNATIVE B Variable air volume with reheat ECONOMIC LIFE 25 YRS.  
air cooled chiller, packaged terminal A/C and Fin. Rad.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$145,487			\$145,487
OPERATIONS Elec.		\$52,801	18.049	953,005
OPERATIONS Steam (oil)		21,891	20.050	438,915
MAINTENANCE		2,397	9.524	22,829
PERSONNEL				
TERMINAL VALUE				
OTHER:				


TOTAL PRESENT VALUE ALTERNATIVE B - \$ 1,560,236 ÷ DISCOUNT FACTOR 9.524 = UNIFORM ANNUAL COST \$163,822

REMARKS  
Alternative "A" is feasible.  
Life Cycle Cost  
Alt. A - \$1,483,290  
Alt. B - 1,560,236  
L.C.C. - \$ 76,946  
- 77 x 10<sup>3</sup>

$$S.I.R. = \frac{1,560,236}{1,483,290} = 1.05$$







ECONOMIC ANALYSIS OF SHORE FACILITY

DATE  
1 JULY 80

BUILDING 508; BUILDING RR-3

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Storm Windows ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT.	\$2,763			\$2,763
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 2,763 ÷ 9.524 = 290 UNIFORM ANNUAL COST

ALTERNATIVE B No Storm Windows ECONOMIC LIFE 25 YRS.


DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS		\$1,143	20.05	\$22,917
MAINTENANCE		254	18.049	4,584
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 27,501 ÷ 9.524 = 2,886 UNIFORM ANNUAL COST

REMARKS Alternative A is feasible due to lower present value than B.

Life Cycle Cost  
 Alt. A - \$ 2,763  
 Alt. B - 27,501  
 L.C.C. - \$24,738  
 - \$25 x 10<sup>3</sup>

$$S.I.R. = \frac{27,501}{2,763} = 9.95$$



BUILDING 508 and BUILDING RR-3 - Storms

TOTAL WINDOW AREA (Heating) = 1,027 SF  
(Cooling) = 759 SF  
SAVINGS FROM STORM WINDOWS

1. Winter Savings:

Reduction in Infiltration x  $\Delta T$  x 1.08 x SF Window  
+ Reduction in Transmission x  $\Delta T$  x SF Window  
=  $0.5(2.4 - 1.2)$  CFM/SF x  $(68 - 23)$  x  $1.08$  x 1,027  
+  $(1.04 - 0.54)$  x  $(68 - 23)$  x 1,027 SF  
= 53,055 BTUH

ANNUAL SAVINGS IN BTU's

$\frac{2901 \text{ HDD} \times 24 \times 53,055}{(68 - 23) \times .90(\text{Effy.})} = 91.21 \text{ MIL BTU/YR.}$

ANNUAL DOLLAR SAVINGS

$\$12.53/\text{MIL BTU's} \times 91.21 \text{ MIL BTU/YR.} = \$1,143$

2. Summer Savings:

Reduction in Infiltration x  $\Delta H$  x 4.45 x SF Window  
+ Reduction in Transmission x  $\Delta T$  x SF Window  
=  $0.5(1.2 - 0.6)$  CFM/SF x 12 x 4.45 x 759 SF  
+  $(1.04 - 0.54)$  x  $(68 - 23)$  x 759 SF  
= 11,958 BTUH

ANNUAL SAVINGS IN BTU's

$\frac{1810 \text{ CDD} \times 11,958 \text{ BTUH}}{3,413 \text{ KWH/BTU}} = 6,342 \text{ KWH}$   
or 21.6 MIL BTU/YR.

ANNUAL DOLLAR SAVINGS

$\$0.04/\text{KWH} \times 6,342 \text{ KWH} = \$254$

3. Total Annual Savings from Storm Windows  
 $\$1,143 + \$254 = \$1,397$

4. Cost of Storm Windows

Jan 80      Jun 80      Jan 82  
 $\$2.27/\text{SF} \times 1.036 \times 1.142 = \$2.69$  represents cost to add storms to proposed  
cost for screens under equipment section.

INSTALLATION COST OF STORM WINDOWS

$1,027 \text{ SF} \times \$2.69/\text{SF} = \$2,763$

5. Discount Factor - Use 20.050 for 25 years for oil, 8%; and use  
18.049 for 25 years for electricity, 7%.



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 508; BUILDING RR-3

DATE  
1 JULY 80

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add insulation in ceiling ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$15,538			\$15,538
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 15,538 ÷ 9.524 = \$1,631

ALTERNATIVE B Continue to operate with current losses ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT		\$8,915	20.05	\$182,758
OPERATIONS	Steam (oil) Elec.	7,874	18.049	142,118
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 324,876 ÷ 9.524 = \$34,111

REMARKS

Alternative "A" is feasible.

Life Cycle Cost

Alt. A - \$ 15,538

Alt. B - 324,876

L.C.C. - \$309,338

- \$309 x 10<sup>3</sup>

$$S.I.R. = \frac{324,876}{15,538} = 20.91$$

Encl 7



BUILDING 508 and BUILDING RR-3

1. Additional insulation above ceiling

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Roof Area SF}$$

over heated space

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Roof Area SF}$$

over A/C space

$$U_{\text{Exist.}} = 0.44 \text{ BTU/HR}^{\circ}\text{F. SF} \quad U_{\text{New}} = 0.05 \text{ BTU/HR}^{\circ}\text{F. SF}$$

From Trace

$$\text{Heat Loss with } U_{\text{New}} (.05) = 53,060 \text{ BTUH}$$

$$\text{Heat Loss with } U_{\text{Exist.}} (.44)$$

$$\frac{53,060 \times .44}{.05} = 466,928 \text{ BTUH}$$

$$\text{Winter Energy Saved} = 413,868 \text{ BTUH}$$

Annual Savings in BTU's

$$\frac{2901 \text{ HDD} \times 24 \times 413,868 \text{ BTUH}}{(68 - 23) \times .90(\text{Effy.})} = 711.48 \text{ MIL BTU/YR.}$$

Annual Dollar Savings

$$\$12.53/\text{MIL BTUS} \times 711.48 \text{ MIL BTUS/YR.} = \$8,915$$

From Trace

$$\text{Heat Gain with } U_{\text{New}} (.05) = 47,588 \text{ BTUH}$$

$$\text{Heat Gain with } U_{\text{Exist.}} (.44)$$

$$\frac{47,588 \times .44}{.05} = 418,774 \text{ BTUH}$$

$$\text{Summer Energy Saved} = 371,186 \text{ BTUH}$$

Annual Savings in BTU's

$$\frac{1810 \text{ CDD} \times 371,186 \text{ BTUH}}{3,413 \text{ KWH/BTU}} = 196,850 \text{ KWH/YR.}$$

or 671.85 MIL BTU/YR.

Annual Dollar Savings

$$\$0.04/\text{KWH} \times 196,850 \text{ KWH} = \$7,874$$



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING 508; BUILDING RR-3

DATE

1 JULY 80

ACTIVITY (Name and Location)

MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE

DINING FACILITIES MODERNIZATION

P NO.

P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add insulation in walls

ECONOMIC LIFE

25

YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$14,206			\$14,206
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 14,206 ÷ 9.524 = \$1,492

ALTERNATIVE B Continue to operate with current losses

ECONOMIC LIFE

25

YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS	Steam (oil)	\$2,252	20.05	\$45,153
	Elec.	922	18.049	16,641
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 61,794 ÷ 9.524 = \$6,488

REMARKS

Alternative "A" is feasible.

Life Cycle Cost

Alt. A - \$14,206

Alt. B - 61,794

L.C.C. - \$47,588

- \$48 x 10<sup>3</sup>

$$S.I.R. = \frac{61,794}{14,206} = 4.35$$



BUILDING 508 and BUILDING RR-3

2. Additional insulation in walls

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Wall Area SF} \\ \text{across heated space}$$

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Wall Area SF} \\ \text{across A/C space}$$

$$U_{\text{Exist.}} = 0.35 \text{ BTU/HR}^{\circ}\text{F.SF.} \quad U_{\text{New}} = 0.15 \text{ BTU/HR}^{\circ}\text{F.SF.}$$

From Trace  
Heat Loss with  $U_{\text{New}} (.15)$  = 78,402 BTUH

Heat Loss with  $U_{\text{Exist.}} (.35)$   
 $\frac{78,402 \times .35}{.15}$  = 182,938 BTUH

Energy Saved for Heating = 104,536 BTUH

Annual Energy Savings  
 $\frac{2901 \text{ HDD} \times 24 \times 104,586 \text{ BTUH}}{(68 - 23) \times .90(\text{Effy.})}$  = 179.71 MIL BTU/YR.

Annual Dollar Savings  
\$12.53/MIL BTUS x 179.71 MIL BTU/YR. = \$2,252

From Trace  
Heat Gain with  $U_{\text{New}} (.15)$  = 32,586 BTUH

Heat Gain with  $U_{\text{Exist.}} (.35)$   
 $\frac{32,586 \times .35}{.15}$  = 76,034 BTUH

Energy Saved for Cooling = 43,448 BTUH

Annual Energy Savings  
 $\frac{1810 \text{ CDD} \times 43,448 \text{ BTU}}{3,413}$  = 23,042 KWH/YR.  
78.64 MIL BTU/YR.

Annual Dollar Savings  
\$0.04/KWH x 23,042 KWH = \$922



ECONOMIC ANALYSIS OF SHORE FACILITY

DATE  
1 JULY 80

Building 508 and Building RR3  
ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION  
DESCRIPTION OF ALTERNATIVES  
P NO.  
P-697

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Solar Domestic Hot Water Heating ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	10,087		80.23	10,087
OPERATIONS		149		11,954
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 22,041 ÷ DISCOUNT FACTOR = UNIFORM ANNUAL COST

ALTERNATIVE B Operate Domestic Hot Water System with Hot Water Generator Using Steam ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT			80.23	
OPERATIONS		988		79,267
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 79,267 ÷ DISCOUNT FACTOR = UNIFORM ANNUAL COST

REMARKS

Alternate "A" is feasible.  
Life Cycle Cost  
Alt. A - \$22,041  
Alt. B - 79,269  
L.C.C. - 57,228<sup>3</sup>  
- \$57 x 10<sup>3</sup>

$$S.I.R. = \frac{79,267}{22,041} = 3.60$$

$$Payback = \frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{5043}{419} = 12.02$$

From Enclosure 14 = Less than 9 years. Encl 7



BUILDING 508 AND BUILDING RR3 - SOLAR DHW  
SOLAR ANALYSIS

1. Investment cost: Back-up estimate esc. to 1 January 82.
2. Energy Cost: FY 80    FY 81    FY 82  
Steam (oil) \$9.27/MIL BTU x 1.04 x 1.14 x 1.14 = 12.53/MIL BTU.
3. Energy Consumption  
Alternate A  
    Auxiliary Energy Required = 11.93 MBTU/YR\*  
    Cost of Aux. Energy = 11.93 x 12.53 = \$149  
  
Alternate B  
    Conventional Energy Required = 78.84 MBTU/YR\*  
    Cost of Conventional Energy = 78.84 x 12.53 = \$988
4. Discount Factor - use 80.23 for 25 years for oil from enclosure 14 (FY 82).
5. Payback =  $\frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{10,087}{839} = 12.02$   
From Enclosure 14                      = Less than 9 years.

\* Refer to SOLCOST analysis.



ECONOMIC ANALYSIS OF SHORE FACILITY

DATE  
1 JULY 80

BUILDING BA-103

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add Storm Windows ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT		\$1,383		\$1,383
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 1,383 ÷ 9.524 = \$145

ALTERNATIVE B \_\_\_\_\_ ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS	Steam (oil)	\$572	20.05	\$11,526
	Elec.	703	18.049	12,688
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 24,214 ÷ 9.524 = \$2,542

REMARKS  
Alternative "A" is feasible.  
Life Cycle Cost  
Alt. A - \$ 1,383  
Alt. B - 24,214  
L.C.C. - 22,831  
- 23 x 10<sup>3</sup>

$$S.I.R. = \frac{24,214}{1,383} = 17.51$$



BUILDING BA-103 - STORMS  
(Glazed Area Considered 1/2 of Building 508)

Total Window Area (Heating) = 514 SF  
(Cooling) = 380 SF  
Savings From Storm Windows

1. Winter Savings

Reduction in Infiltration  $\times \Delta T \times 1.08 \times \text{SF Window}$   
+ Reduction in Transmission  $\times \Delta T \times \text{SF Window}$   
=  $0.5(2.4 - 1.2) \text{ CFM/SF} \times (68 - 23) \times 1.08 \times 514 \text{ SF}$   
+  $(1.04 - 0.54) \times (68 - 23) \times 514 \text{ SF}$   
= 26,553 BTUH  
Annual Savings in BTU's  
 $\frac{2901 \text{ HDD} \times 24 \times 26,553}{(68 - 23) \times .90 \text{ (Effy.)}} = 45.65 \text{ MIL BTU/YR.}$

Annual Dollar Savings

$\$12.53/\text{MIL BTUS} \times 45.65 \text{ MIL BTU/YR.} = \$572$

2. Summer Savings

Reduction in Infiltration  $\times \Delta H \times 4.45 \times \text{SF Window}$   
+ Reduction in Transmission  $\times \Delta T \times \text{SF Window}$   
=  $0.5(1.2 - 0.6) \text{ CFM/SF} \times 12 \times 4.45 \times 380 \text{ SF}$   
+  $(1.04 - 0.54) \times (68 - 23) \times 380 \text{ SF}$   
= 6,174 BTUH  
Annual Savings in BTU's  
 $\frac{1810 \text{ CDD} \times 6,174 \text{ BTUH}}{3,413 \text{ KWH/BTU}} = 3,274 \text{ KWH}$   
or 11.17 MIL BTU/YR.

Annual Dollar Savings

$\$0.04/\text{KWH} \times 3,274 \text{ KWH} = \$131$

3. Total Annual Savings from Storm Windows

$\$572 + \$131 = \$703$

4. Cost of Storm Windows

Jan 80      Jun 80      Jan 82  
 $\$2.27/\text{SF} \times 1.036 \times 1.142 = \$2.69$  represents cost to add storms to proposed  
cost for screens under equipment section.

Installation Cost of Storm Windows

$514 \text{ SF} \times \$2.69/\text{SF} = \$1,383$

5. Discount Factor - Use 20.050 for 25 years for oil, 8%; and use 18.049 for 25 years for electricity, 7%.



ECONOMIC ANALYSIS OF SHORE FACILITY

DATE  
1 JULY 80

BUILDING BA-103

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Add insulation above ceiling ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$6,027			\$6,027
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 6,027 ÷ 9.524 = 633 UNIFORM ANNUAL COST

ALTERNATIVE B Operate with existing losses ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS	Steam (oil)	\$4,457	20.05	\$89,363
	Elec.	3,937	18.049	71,059
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 160,422 ÷ 9.524 = \$16,844 UNIFORM ANNUAL COST

REMARKS

Alternative "A" is feasible.

Life Cycle Cost

Alt. A - \$ 6,027

Alt. B - 160,422

L.C.C. - 154,395

- \$154 x 10<sup>3</sup>

$$S.I.R. = \frac{160,422}{6,027} = 26.62$$



BUILDING BA-103

1. Additional insulation above ceiling

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Roof Area SF}$$

over heated space

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Roof Area SF}$$

over A/C space

$$U_{\text{Exist.}} = 0.44 \text{ BTU/HR}^{\circ}\text{F.SF} \quad U_{\text{New}} = 0.05 \text{ BTU/HR}^{\circ}\text{F.SF}$$

From Trace

$$\text{Heat Loss with } U_{\text{New}} (.05) = 26,530 \text{ BTUH}$$

$$\text{Heat Loss with } U_{\text{Exist.}} (.44) = 233,464 \text{ BTUH}$$

$$\frac{26,530 \times .44}{.05}$$

$$\text{Winter Energy Saved} = 206,934 \text{ BTUH}$$

Annual Savings in BTU's

$$\frac{2901 \text{ HDD} \times 24 \times 206,934 \text{ BTUH}}{(68 - 23) \times .90(\text{Effy.})} = 355.74 \text{ MIL BTU/YR.}$$

Annual Dollar Savings

$$\$12.53/\text{MIL BTUS} \times 355.74 \text{ MIL BTUS/YR.} = \$4,457$$

From Trace

$$\text{Heat Gain with } U_{\text{New}} (.05) = 23,794 \text{ BTUH}$$

$$\text{Heat Gain with } U_{\text{Exist.}} (.44) = 209,387 \text{ BTUH}$$

$$\frac{23,794 \times .44}{.05}$$

$$\text{Summer Energy Saved} = 185,593 \text{ BTUH}$$

Annual Savings in BTU's

$$\frac{1810 \text{ CDD} \times 185,593 \text{ BTUH}}{3,413 \text{ KWH/BTU}} = 98,425 \text{ KWH/YR.}$$

or 335.92 MIL BTU/YR.

Annual Dollar Savings

$$\$0.04/\text{KWH} \times 161,437 \text{ KWH} = \$3,937$$



ECONOMIC ANALYSIS OF SHORE FACILITY

BUILDING BA-103

DATE  
1 JULY 80

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Insulate exterior walls

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$7,225			\$7,225
OPERATIONS				
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 7,225 ÷ 9.524 = \$759

ALTERNATIVE B Operate with existing losses.

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT				
OPERATIONS	Steam (oil)	\$1,126	20.05	\$22,576
	Elec.	461	18.049	8,321
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 30,897 ÷ 9.524 = \$3,244

REMARKS Alternative "A" is feasible.

Life Cycle Cost

Alt. A - \$ 7,225

Alt. B - 30,897

L.C.C. - 23,672

- \$24 x 10<sup>3</sup>

$$S.I.R. = \frac{30,897}{7,225} = 4.28$$



BUILDING BA-103

2. Additional insulation in walls

Energy Saved:

$$\text{Winter} = (U_{\text{Exist.}} - U_{\text{New}}) \times \Delta T \times \text{Wall Area SF} \\ \text{across heated space}$$

$$\text{Summer} = (U_{\text{Exist.}} - U_{\text{New}}) \times \text{Solar Gain Factor} \times \text{Wall Area SF} \\ \text{across A/C space}$$

$$U_{\text{Exist.}} = 0.35 \text{ BTU/HR}^{\circ}\text{F.SF} \quad U_{\text{New}} = 0.15 \text{ BTU/HR}^{\circ}\text{F.SF}$$

From Trace  
Heat Loss with  $U_{\text{New}} (.15)$  = 39,201 BTUH

Heat Loss with  $U_{\text{Exist.}} (.35)$   
 $\frac{39,201 \times .35}{.15}$  = 91,469 BTUH

Energy Saved for Heating = 52,268 BTUH

Annual Energy Savings  
 $\frac{2901 \text{ HDD} \times 24 \times 52,268 \text{ BTUH}}{(68 - 23) \times .90(\text{Effy.})}$  = 89.86 MIL BTU/YR.

Annual Dollar Savings  
\$12.53/MIL BTUS x 89.86 MIL BTUS/YR. = \$1,126

From Trace  
Heat Gain with  $U_{\text{New}} (.15)$  = 16,293 BTUH

Heat Gain with  $U_{\text{Exist.}} (.35)$   
 $\frac{16,293 \times .35}{.15}$  = 38,017 BTUH

Energy Saved for Cooling = 21,724 BTUH

Annual Energy Savings  
 $\frac{1810 \text{ CDD} \times 21,724 \text{ BTUH}}{3413}$  = 11,521 KWH/YR.  
or 39.32 MIL BTU/YR.

Annual Dollar Savings  
\$0.04/KWH x 22,038 KWH = \$461



ECONOMIC ANALYSIS OF SHORE FACILITY

DATE  
1 JULY 80

BUILDING BA-103

ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE  
DINING FACILITIES MODERNIZATION

P NO.  
P-697

DESCRIPTION OF ALTERNATIVES

PROJECT COST PROJECTIONS BY ALTERNATIVES

ALTERNATIVE A Solar Domestic Hot Water

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT	\$5,043		80.23	\$5,043
OPERATIONS		\$75		6,017
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE A - \$ 11,060 ÷ DISCOUNT FACTOR = UNIFORM ANNUAL COST

ALTERNATIVE B Operate domestic hot water system with hot water generator using steam

ECONOMIC LIFE 25 YRS.

DESCRIPTION AND YEAR	COSTS (\$)		DISCOUNT FACTOR	PRESENT VALUE (\$)
	ONE TIME	RECURRING		
INVESTMENT			80.23	
OPERATIONS		\$489		\$39,232
MAINTENANCE				
PERSONNEL				
TERMINAL VALUE				
OTHER:				

TOTAL PRESENT VALUE ALTERNATIVE B - \$ 39,232 ÷ DISCOUNT FACTOR = UNIFORM ANNUAL COST

REMARKS Alternative "A" is feasible.

Life Cycle Cost

Alt. A - \$11,060

Alt. B - 39,232

L.C.C. - 28,172

- \$28 x 10<sup>3</sup>

$$S.I.R. = \frac{39,232}{11,060} = 3.55$$

$$\text{Payback} = \frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{10,087}{839} = 12.02$$

From Enclosure 14 = Less than 9 years. Encl 7



BUILDING BA-103 - SOLAR DHW

1. Investment Cost: Back-up estimate escalates to 1 JAN 82.
2. Energy Cost:  

		FY 80	FY 81	FY 82	
Steam (oil)	R9.27/MIL x	1.04	x 1.14	x 1.14	= 12.53/MIL BTU
					BTU

3. Energy Consumption:

Alternate A:

Auxiliary Energy Required = 5.97 MIL BTU/YR\*  
Cost of Auxiliary Energy = 5.97 x 12.53 = \$75

Alternate B:

Conventional Energy Required = 39.42 MIL BUT/YR\*  
Cost of Conventional Energy = 39.42 x 12.53 = \$494

4. Discount Factor - Use 80.23 for 25 years for oil from enclosure 14(FY 82).

5. Payback =  $\frac{\text{Investment Cost}}{\text{Annual Savings}} = \frac{5,043}{419} = 12.02$

From Enclosure 14 = Less Than 9 years.

\*Refer to Solcost Analysis.



COLLATERAL EQUIPMENT REQUIREMENTS (Initial Outfitting)

DLANTDIV 4-11010/6 (NEW 2-79)

DATE

1 JULY 80

ACTIVITY (Name and Location)

MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE

DINING FACILITIES MODERNIZATION

P. NO.

P-697

COG. SYMBOL AND FED. STOCK NO. OR OTHER SOURCE	ITEM/EQUIPMENT DESCRIPTION	QUAN- TITY	UNIT OF ISSUE	M + L + MV UNIT PRICE	TOTAL COST
<u>BUILT-IN EQUIPMENT</u> <u>TO BE MCON FUNDED</u>	*Intercom system amplifiers	5	EA	876	4,380
	*Drinking water coolers	16	EA	804	12,864
	*Venetian blinds	340	EA	138	46,920
	*Window screens	340	EA	37	12,580
	*Serving line vent hood	2	EA	19,106	38,212
	*Soiled ware handling system	6	EA	56,268	337,608
	1 - ea. Bldg. BA-103				
	1 - ea. Bldg. 1209				
	1 - ea. Bldg. RR-3				
	2 - ea. Bldg. M-424				
	1 - ea. Bldg. 508				
	*Convection oven	6	EA	4,495	26,972
	2 - ea. Bldg. BA-103				
	2 - ea. Bldg. RR-3				
2 - ea. Bldg. M-424					
*Ice machine	3	EA	3,439	10,318	
1 - ea. Bldg. RR-3					
2 - ea. Bldg. M-424					
*Walk-in cooler doors	8	EA	2,768	22,144	
SUBTOTAL (To 1391)				511,998	
	*Equipment with associated installation cost and mark ups and escalation to JAN 82 <u>Building BA-103</u>				
<u>EXPENSE ITEMS</u>					
asserstorm	Refrigerated display case	1	EA	3,355	3,355
eating	Grill, electric, 6 ft.	1	EA	2,508	2,508
merican Warehouse	Hot food table, mobile	2	EA	1,425	2,850
eating	Deep fat fryer	1	EA	1,164	1,164
obart	Vertical cutter, mixer	1	EA	2,778	2,778



COLLATERAL EQUIPMENT REQUIREMENTS (Initial Outfitting)

D LANTDIV 4-11010/8 (NEW 2-79)

DATE

1 JULY 80

ACTIVITY (Name and Location)

MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

PROJECT TITLE

DINING FACILITIES MODERNIZATION


P. NO.

697


COG. SYMBOL AND FED. STOCK NO. OR OTHER SOURCE	ITEM/EQUIPMENT DESCRIPTION	QUAN- TITY	UNIT OF ISSUE	UNIT PRICE	TOTAL COST
	SUBTOTAL				12,655
Hobart	<u>Building 1209</u> Vertical cutter, mixer	1	EA	2,777	<u>2,777</u>
	SUBTOTAL				2,777
Hobart	<u>Building RR-3</u> Vertical cutter, mixer	1	EA	2,778	2,778
Wasserstorm	Cold food counters w/sneeze guards	4	EA	1,837	7,348
Keating	Grill, electric, 6 ft.	2	EA	2,508	<u>5,016</u>
	SUBTOTAL				15,142
Wasserstorm	<u>Building M-424</u> Cold food counter w/sneeze guards	4	EA	1,837	7,348
Keating	Grill, electric, 6 ft.	4	EA	2,508	<u>10,032</u>
	SUBTOTAL				17,380
Keating	<u>Building 508</u> Griddle, electric, 6 ft.	2	EA	2,508	5,016
Victory	Reefer, reach in	1	EA	2,310	<u>2,310</u>
	SUBTOTAL				7,326
	Fire Extinguishers for all blds.	24	EA	75	<u>1,800</u>
	TOTAL EXPENSE ITEMS				57,080
	Shipping, packing, handling, installation charges and con- tingencies - 10%				5,700
3. <u>INVESTMENT ITEMS</u>	NONE				
4. <u>APA EQUIPMENT</u>	NONE				
5. <u>TRAINING EQUIPMENT</u>	NONE				
6. <u>OTHER EXPENSES</u>	NONE				
7. <u>EQUIPMENT ON HAND</u>	NONE				
8. <u>SUMMARY</u>	Expense Cost				62,780


























ODELL ASSOCIATES INC.

PLANNING  
ARCHITECTURE  
ENGINEERING

222 SOUTH CHURCH STREET · CHARLOTTE, NORTH CAROLINA 28202  
704-377-5941

December 5, 1980

Public Works Department  
Building 1005  
Marine Corps Base  
Camp Lejeune, North Carolina 28542

Attention: Commanding Officer

Re: Dining Facilities Modernization  
Camp Lejeune North Carolina  
Buildings 1209, M424, 508, RR3, BA103

Gentlemen:


According to the instructions of our Contract, we are transmitting herewith the thirty-five percent (35%) design submittal including sketch drawings, basis of design, outline specifications, tabulation of gross floor areas and cost estimate all dated December 3, 1980.

Please review the enclosed information and forward your comments to Department of the Navy, Atlantic Division, Attention: Mr. M. L. Bryant, by December 19, 1980, and forward a copy to our office.

We understand that this concludes our efforts in connection with the thirty-five percent (35%) design and will await your review, approval and notice to proceed from the Naval Facilities Engineering Command before proceeding with the final drawing phase.

Very truly yours,

ODELL ASSOCIATES INC.



Stephen D. Thomas

E-1412

Encl.: 35% design submittal (2 cys.)

cc: DON - Bryant



ODELL ASSOCIATES INC.

PLANNING  
ARCHITECTURE  
ENGINEERING

222 SOUTH CHURCH STREET · CHARLOTTE, NORTH CAROLINA 28202  
704-377-5941

December 5, 1980

Public Works Department  
Building 1005  
Marine Corps Base  
Camp Lejeune, North Carolina 28542

Attention: Commanding Officer

Re: Dining Facilities Modernization  
Camp Lejeune North Carolina  
Buildings 1209, M424, 508, RR3, BA103

Gentlemen:


According to the instructions of our Contract, we are transmitting herewith the thirty-five percent (35%) design submittal including sketch drawings, basis of design, outline specifications, tabulation of gross floor areas and cost estimate all dated December 3, 1980.

Please review the enclosed information and forward your comments to Department of the Navy, Atlantic Division, Attention: Mr. M. L. Bryant, by December 19, 1980, and forward a copy to our office.

We understand that this concludes our efforts in connection with the thirty-five percent (35%) design and will await your review, approval and notice to proceed from the Naval Facilities Engineering Command before proceeding with the final drawing phase.

Very truly yours,

ODELL ASSOCIATES INC.



Stephen D. Thomas

E-1412

Encl.: 35% design submittal (2 cys.)

cc: DON - Bryant

1 DEC 8 A10:30

SECRET  
NO FORN DISSEM  
NO UNCLASSIFIED  
NO UNCLASSIFIED  
NO UNCLASSIFIED

PWO:408:EGJ:bb  
11000

7 NOV 1980

100  
EJ  
04  
20

From: Commanding General  
 To: Commandant of the Marine Corps (LFF)

Subj: Supplemental Information Requested by Congress for FY-82  
 Military Construction Program; submittal of

Ref: (a) CMC ltr LFF-1-AN:apm of 16 Oct 1980


Encl: (1) DD Form 1390, Supplemental Data for FY-82 MCON Program  
 (2) DD Form 1391c, Supplemental Data for FY-82 MCON Project  
 P-526, Combat Vehicle Maintenance Shop, w/work sheets  
 (3) DD Form 1391c, Supplemental Data for FY-82 MCON Project  
 P-175, Communications/Electronics Maintenance Shop,  
 w/work sheets  
 (4) DD Form 1391c, Supplemental Data for FY-82 MCON Project  
 P-414, Unaccompanied Enlisted Personnel Housing, w/work  
 sheets  
 (5) DD Form 1391c, Supplemental Data for FY-82 MCON Project  
 P-697, Modernize Enlisted Dining Facilities BB-103, 1209,  
 M-424, & 508, w/work sheets

1. Reference (a) provided guidance for submission of supplemental information for our FY-82 Military Construction Program, as requested by Congress. Accordingly, enclosures (1) through (5) are hereby forwarded for your continuing action.

R. P. MILLICE, Jr.  
 BV direction

Blind copy to: (w/encs)  
 AC/S, Fac

Return Per Planning Branch



DD FORM 1390 SUPPLEMENTAL DATA  
 FY-82 MILITARY CONSTRUCTION PROGRAM

P-697

<u>Navy</u> COMPONENT	<u>MCB Camp Lejeune NC</u> INSTALLATION/LOCATION	<u>Marine Corps</u> COMMAND
		(\$000)
A. ESTIMATED COST OF BACKLOG REAL PROPERTY MAINTENANCE (BMAR):		<u>*NOTE</u>
	Permanent Facilities: Temporary Facilities:	{ }
B. SIMILAR UNUSED SPACE:		<u>Quantity/Unit of Measure</u>
<u>Real Property Categories:</u>		
	214-XX, COMBAT VEHICLE MAINTENANCE SHOP	**0 SF
	217-XX, COMMUNICATIONS/ELECTRONICS MAINTENANCE SHOP	***0. SF
	721-XX, UNACCOMPANIED ENLISTED PERSONNEL HOUSING	****52,291 SF
	722-XX, DINING FACILITY	*****0 SF
C. OUTSTANDING POLLUTION AND SAFETY (OSHA) DEFICIENCIES (\$000):		
	1. Air Pollution	*NOTE
	2. Water Pollution	*NOTE
	3. Safety and Occupational Health	*NOTE

NOTES:


\*CMC (Code LFF) will complete.

\*\*Combat Veh Maint Shops (reference P-526) located in substandard WW-II Butler-type metal buildings constructed in 1952 which do not meet the standards used today and cannot be economically rehabilitated.


\*\*\*Comm/Elec Maint Shops (reference P-175) are located in makeshift temporary metal and semi-permanent wood/concrete block facilities that were constructed for warehousing.

\*\*\*\*The vacant UEPH facilities were constructed in 1943 as emergency multi-use facilities (Admin, Storage, and UEPH). Construction consists of concrete foundation, concrete slab, masonry walls, wood trusses, and asphalt shingles; minimum electric power and detached toilet facilities.


\*\*\*\*\*The overall appearance, condition, and layout of the existing Dining Facilities being modernized (reference P-697) are inefficient, under-utilized, and do not permit a favorable environment while personnel are dining.



1. COMPONENT <p style="text-align: center;">Navy</p>	FY 19 <u>82</u> MILITARY CONSTRUCTION PROJECT DATA	2. DATE <p style="text-align: center;">5 NOV 1980</p>	
3. INSTALLATION AND LOCATION <p style="text-align: center;">MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA 28542</p>			
4. PROJECT TITLE MODERNIZE ENLISTED DINING FACILITIES BB-103, 1209, M-424, & 508		5. PROJECT NUMBER <p style="text-align: center;">P-697</p>	
<u>SUPPLEMENTAL DATA</u>			
A. ESTIMATED ANNUAL COST TO OPERATE THE PROPOSED FACILITY.....	486	( \$000 )	
B. NUMBER OF ADDITIONAL PERSONNEL NECESSARY TO CARRY OUT THE FUNCTION OF THE PROPOSED FACILITY.....	0	( PEOPLE )	
C. ESTIMATED LIFE-CYCLE COST TO OPERATE AND MAINTAIN THE PROPOSED FACILITY.....	*NOTE	( \$000 )	
D. ESTIMATED LIFE-CYCLE COST TO OPERATE AND MAINTAIN THE EXISTING FACILITY IF NEW FACILITY IS A REPLACEMENT.....	N/A	( \$000 )	
E. DESIGN DATA (Estimated): **NOTE			
1. STATUS			
a. Date Design Started.....			
b. Percent Complete as of 1 Jan 19__ .....			
c. Percent Complete as of 1 Oct 19__ .....			
d. Date Design Complete.....			
2. BASIS			
a. Standard or Definitive Design: Yes ___ No ___			
b. Where Design was Most Recently Used: _____			
3. COST (Total) = c = a+b and d+e <span style="float: right;">( \$000 )</span>			
a. Production of Plans and Specifications.....			
b. All Other Design Costs.....			
c. Total.....			
d. Contract.....			
e. In-House.....			
4. CONSTRUCTION START..... <span style="float: right;">( month and year )</span>			
F. EQUIPMENT ASSOCIATED WITH THIS PROJECT WHICH WILL BE PROVIDED FROM OTHER APPROPRIATIONS: *NOTE			
<u>Equipment</u> <u>Nomenclature</u>	<u>Procuring</u> <u>Appropriation</u>	<u>Fiscal Year</u> <u>Appropriated</u> <u>or Requested</u>	<u>Cost</u> <u>( \$000 )</u>
(ALL NOTES ON PAGE 2)			



1. COMPONENT Navy	FY 19 <u>82</u> MILITARY CONSTRUCTION PROJECT DATA	2. DATE 5 NOV 1980
3. INSTALLATION AND LOCATION MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA 28542		
4. PROJECT TITLE MODERNIZE ENLISTED DINING FACILITIES BB-103, 1209, M-424, & 508		5. PROJECT NUMBER P-697
<p>NOTES:</p> <p>*These Dining Facilities are inadequate and are being modernized to bring them up to standards that are required to support today's all volunteer Marine Corps. A cost analysis has been made for feasibility and cost effectiveness, and it was found to be in the best interests of the Government to rehabilitate these facilities.</p> <p>**CMC (Code LFF) will complete.</p>		



WORK SHEETS

P-697, MODERNIZE ENLISTED DINING FACILITIES

A. Annual Maintenance Cost:

Inventory of Like Facilities = 433,312 SF

Cost/Yr of Existing Facilities = \$274,109

Cost/SF  $\frac{\$274,109}{433,312 \text{ SF}}$  = \$.63/SF

Proposed Facility = 95,433 SF

95,433 SF X \$.63 = \$60,123

SOURCE: Base Historical Data

B. Utility Costs:

1. Electricity: 1,200,000 KWH/YR X .0353/KWH = \$42,360

2. Steam: 18,090,900 LBS/YR X .01007/LB = \$182,175

3. Water & Sewage: 65 gal per pn per day:

(a) Annual Water Cost: 4,036 pn X 65 gal/day X \$.6438/1000 gal  
X 365 days = \$61,646

(b) Annual Sewage Cost: 4,036 pn X 65 gal/day X \$.4673/1000 gal  
X 365 days = \$44,746

4. Summary of Utility Costs (Annual):

Electricity:	\$ 42,360
Steam:	\$182,175
Water & Sewage:	<u>\$106,392</u>
TOTAL:	\$330,927

C. Other Engineering Support:

Trash Disposal:	\$11,050
Pest Control:	\$ 5,344
Misc. Services:	<u>\$10,000</u>
TOTAL:	\$26,394



0 0 0 0  
0 0 0 0

WORK SHEETS, P-697, MODERNIZE ENLISTED DINING FACILITIES

D. <u>Summary of Costs:</u>		<u>(escalated to FY-82)</u>
Maintenance & Repair:	\$ 60,123	\$ 69,983
Utilities:	\$330,927	\$385,199
Other Engr. Support:	<u>\$ 26,394</u>	<u>\$ 30,723</u>
TOTAL:	\$417,444	\$485,905

Escalation Factor for Above:

80-81 - 8.3%

81-82 = 7.5%

EF = 1.083 X 1.075 = 1.164



PWO:408:CMB:bb  
P-697

7 Aug 1980

From: Base Commander  
To: Commandant of the Marine Corps (LFS-3)  
Subj: FY-82 MCOH Project P-697, Dining Facilities Modernization; update  
of collateral equipment for  
Ref: (a) MCO P11000.12  
Encl: (1) LANTDIV 4-11010/6 Forms, Collateral Equipment Requirements  
for P-697, Dining Facilities Modernization, dtd 30 Jul 1980

1. Reference (a) provided detailed instruction for the preparation of  
Collateral Equipment Requirements lists. In accordance with reference  
(a), the collateral equipment requirements for the subject project have  
been updated and are hereby submitted as enclosure (1).

V. PODBIELSKI  
By direction

Blind copy to: (w/enc1)  
AC/S, Fac  
AC/S, Sup Serv  
BFSO

PLS return to PW Planning Branch

7 April 1981

File returned to BM Planning Branch

**COLLATERAL EQUIPMENT REQUIREMENTS (Initial Outfitting)**  
 5ND LANTDIV 4-11010/6 (NEW 2-79)


DATE 30 JULY 1980

1. ACTIVITY (Name and Location)  
 MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA 28542

2. PROJECT TITLE  
 DINING FACILITY MODERNIZATION, BLDG BA-103

P. NO. P-697

COG. SYMBOL AND FED. STOCK NO. OR OTHER SOURCE	ITEM/EQUIPMENT DESCRIPTION	QUAN- TITY	UNIT OF ISSUE	UNIT PRICE	TOTAL COST
1. <u>Built-in Equipment to be MCON Funded</u>	*Heating, ventilating, and air- conditioning installations *Fire alarm and intercom systems *Drinking water coolers *Venetian Blinds and Window Screens *Serving line vent hood *Soiled ware handling system *Deep fat fryer *Convection oven *Vertical cutter, mixer		EA EA EA EA EA EA EA EA EA		
	*Equipment with associated installation cost.				
2. <u>Expense Items</u>					
Wasserstorm 2	✓ Refrigerated display case	1	EA	3,355	3,355
Keating	✓ Grill, electric, 6 ft.	1	EA	2,508	2,508
American Warehouse	Hot food table, mobile	2	EA	1,425	2,850
2	✓ Beverage island	1	EA	2,500	2,500
	Subtotal				11,213



**COLLATERAL EQUIPMENT REQUIREMENTS (Initial Outfitting)**

5ND LANTDIV 4-11010/6 (NEW 2-79)


DATE 30 JULY 1980

1. ACTIVITY (Name and Location)  
MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA 28542

2. PROJECT TITLE  
DINING FACILITY MODERNIZATION, BLDG 1209

P. NO. P-697

COG. SYMBOL AND FED. STOCK NO. OR OTHER SOURCE	ITEM/EQUIPMENT DESCRIPTION	QUAN- TITY	UNIT OF ISSUE	UNIT PRICE	TOTAL COST
<p>1. <u>Built-in Equipment to be MCON funded</u></p>	<p>*Heating, Ventilating, and air-conditioning installations *Fire alarm and intercom systems *Drinking water coolers *Venetian blinds and window screens *Dishwasher, flight type *Ventilation hood, serving line *Soiled ware handling system *Vertical cutter, mixer</p>		<p>EA EA EA EA EA EA EA EA</p>		
<p>*Equipment with associated installation cost.</p>					
<p>2. <u>Expense Items</u></p>	<p>Beverage Island Subtotal</p>	<p>3</p>	<p>EA</p>	<p>2,500</p>	<p>7,500 <hr/>7,500</p>



**COLLATERAL EQUIPMENT REQUIREMENTS (Initial Outfitting)**

5ND LANTDIV 4-11010/6 (NEW 2-79)

DATE

30 JULY 1980

1. ACTIVITY (Name and Location)

MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA 28542


2. PROJECT TITLE

DINING FACILITY MODERNIZATION, BLDG. RR-3

P. NO.

P-697

COG. SYMBOL AND FED. STOCK NO. OR OTHER SOURCE	ITEM/EQUIPMENT DESCRIPTION	QUAN- TITY	UNIT OF ISSUE	UNIT PRICE	TOTAL COST
1. <u>Built-in Equipment to be MCON Funded</u>	*Heating, ventilating, and air- conditioning installations		EA		
	*Fire alarm and intercom systems		EA		
	*Drinking water coolers		EA		
	*Venetian blinds and window screens		EA		
	*Pot washer		EA		
	*Vertical cutter, mixer		EA		
	*Convection oven		EA		
	*Soiled ware handling system		EA		
	*Equipment with associated installation cost.				
2. <u>Expense Items</u>					
Wasserstorm	Cold food counters w/sneeze guards	4	EA	1,837	7,348
Keating	Grill, electric, 6 ft.	2	EA	2,508	5,016
Lern	Ice machine	1	EA	1,980	1,980
	Beverage island	2	EA	2,500	5,000
	Subtotal				<u>19,344</u>



**COLLATERAL EQUIPMENT REQUIREMENTS (Initial Outfitting)**  
 5ND LANTDIV 4-11010/6 (NEW 2-79)


DATE 30 JULY 1980

1. ACTIVITY (Name and Location)  
 MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA 28542

2. PROJECT TITLE  
 DINING FACILITY MODERNIZATION, BLDG M-424

P. NO. P-697

COG. SYMBOL AND FED. STOCK NO. OR OTHER SOURCE	ITEM/EQUIPMENT DESCRIPTION	QUAN- TITY	UNIT OF ISSUE	UNIT PRICE	TOTAL COST
1. <u>Built-in Equipment to be MCON Funded</u>	*Heating, ventilating, and air conditioning installation *Fire alarm and intercom system *Drinking water coolers *Venetian blinds and window screens *Pot washer *Soiled ware handling system *Ice dispenser *Convection oven		EA EA EA EA EA EA EA EA		
	*Equipment with associated installation costs.				
2. <u>Expense Items</u>					
Keating	Cold food counter w/sneeze guard	4	EA	1,837	7,348
	Grill, electric, 6 ft.	4	EA	2,508	10,032
	Beverage island	4	EA	2,500	10,000
	Subtotal				<u>27,380</u>



**COLLATERAL EQUIPMENT REQUIREMENTS (Initial Outfitting)**  
 5ND LANTDIV 4-11010/6 (NEW 2-79)

DATE 30 July 1980

1. ACTIVITY (Name and Location)  
 MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA 28542

2. PROJECT TITLE  
 DINING FACILITY MODERNIZATION, BLDG 508

P. NO. P-697

COG. SYMBOL AND FED. STOCK NO. OR OTHER SOURCE	ITEM/EQUIPMENT DESCRIPTION	QUAN- TITY	UNIT OF ISSUE	UNIT PRICE	TOTAL COST
1. <u>Built-in Equipment to be MCON Funded</u>	*Heating, ventilating and air- conditioning installation *Fire alarm and intercom system *Drinking water coolers *Venetian blinds and window screens *Pot washer *Reefer, reach-in *Soiled ware handling system *Serving line vent hood		EA EA EA EA EA EA EA EA		
*Equipment with associated installation costs.					
2. <u>Expense Items</u>					
Keating	Griddle, electric, 6 ft. Beverage island Subtotal	2 2	EA EA	2,508 2,500	5,016 5,000 10,016
	Bldg BA-103 Bldg 1209 Bldg RR-3 Bldg M-424 Bldg 508				11,213 7,500 19,344 27,380 10,016
	Total Expense Items				75,453
	Shipping, packing, handling, installation charges, con- tingencies (10%)				7,545
	Grand Total				82,998



1 AUG 1980

ARCHITECTURAL BRANCH  
CONTRACT PRIORITY LIST

<u>Contract No.</u>	<u>Title</u>	<u>Completion Date</u>
2025	IMPROVE ENL CLUBS, BLDGS 62 & M-134	1 AUG 80
2092	REROOF PORTION BLDG. H-14	1 AUG 80
2040	ADDN TO ENL CLUB, FRENCH CREEK (1)	15 AUG 80
2090	STAINED GLASS WINDOWS	22 AUG 80
2111	ADDITION/ALTERATIONS TO NCO CLUB, COURTHOUSE BAY (2)	5 SEP 80
2099	CONSTRUCT DETENTION CELL, PMO, BLDG AS-122	5 SEP 80
2109	DISBURSING IMPROVEMENTS	19 SEP 80
2108	HELICOPTER INTERNAL STORES 3	3 OCT 80
2106	MOD TO COMM CENTER (4)	17 OCT 80
2107	BATTERY SHOP	31 OCT 80
2077	GYM FLOORS	14 NOV 80
2076	REROOF 1200 & 1500	28 NOV 80

BLDG 14.

1 Oct. -

