

5-3-82

DDS 0091

Date: 27 April 1982

Memorandum for the Record

From: Ms. Betz, Quality Control Lab., Environmental Section, NREAB, BMaintDiv

Subj: Trihalomethane Sampling for April 1982

1. On 19 April 1982, the lab started sampling all eight water systems for TTHM. This will be the first set analyzed by Grainger Lab. Bob Lachapelle and Elizabeth Betz sampled the Tarawa Terrace and Montford Point Systems. The Sewage Lift Station, E-23, was an extra sample taken in the Knox Trailer Park Area, which switches back and forth from Tarawa Terrace to Montford Point systems.
2. On 20 April 1982, Gaines Huneycutt and Elizabeth Betz sampled the New River and Holcomb Blvd Systems.
3. On 21 April 1982, Jerry Monahan and Elizabeth Betz sampled the Rifle Range, Courthouse Bay and Onslow Beach Systems. At the Rifle Range a third point, in the middle of the distribution system, was added so the sampling there would be in complete compliance with the SDWA. The point was back by the target shed in abandoned Bldg. RR-200. At Courthouse Bay, there was a wait for the operator, to get into the plant. In the future, the lab will need to either obtain a key or call before going. At Onslow Beach, there was excessive air in the system. In the future Onslow Beach will be done first so to allow time to get air out of the sample.
4. On 22 April 1982, Gaines Huneycutt and Elizabeth Betz sampled Hadnot Point. The last sample point, at FC-530, was locked. Headquarters, 2nd Supply Bn, now locks their laundry rooms. Before leaving the lab, we will need to call SSGT Stokes at 3405 to arrange to get the laundry room unlocked. This contact was initially made through SSGT Sears at Engineering Operations, Headquarters, 2nd FSSG, by Danny Sharpe. These sample point must remain fixed.
5. On 23 April 1982, the samples and their duplicated were repackaged and taken to NREAB for the 10:00am mail pick up.

Elizabeth A. Betz
 Elizabeth A. Betz
 Supervisory Chemist

CLW

0000000541