

Date: 9 September 1982

Memorandum for the Record

From: Ms. Betz, Quality Control Lab., Environmental Section, NREAB, BMaintDiv

Subj: Rifle Range Water Treatment Plant Sampling on 19 April 1982; Results of

1. Do to the lost of NAVENENVSA quality control check portion of the 5 April 1982 sampling, LANTDIV requested some more samples. This time two containers were filled at wach point. All were send to LANTDIV who sent half to Jennings and half to NAVENENVSA.
2. Jennings did not find any PCB in the finished water. However, this time they found 0.11ppm(110ppb) PCB in raw water well RR 45.
3. NAVENENVSA found no PCB in any of the samples, Jennings is assumed, by LANTDIV, to be in error.

*Elizabeth A. Betz*  
 Elizabeth A. Betz  
 Supervisory Chemist

CLW

0000000644