

0149

NATURAL RESOURCES AND ENVIRONMENTAL AFFAIRS DIVISION
Marine Corps Base
Camp Lejeune, North Carolina 28542

NREAD/DDS/jc
11000
1 Dec 1982

From: Director
To: Assistant Chief of Staff, Facilities *Jam Tbs. c*

Subj: Safe Drinking Water Act Monitoring Requirements

Encl: (1) AC/S, Fac Memo of 24 Nov 1982
(2) Table of Inorganic Analysis Report

1. Enclosure (1) contains laboratory results of inorganic analysis of Base drinking water supplies. The analysis is a requirement of the subject act. Submittal of these results to the North Carolina Division of Health Services is required by State regulations promulgated under the subject act. NREAD will prepare required correspondence for signature of Assistant Chief of Staff, Facilities.

2. Enclosure (2) shows that the only contaminant limit exceeded was iron. Base WQCL monitoring indicates Camp Johnson and Onslow Beach systems routinely show high iron content. The Air Station, Rifle Range and Courthouse Bay systems occasionally show high iron content. State regulations require that approved treatment be added to control the level of iron. No public notification is required. Except for treatment to address iron contamination problem, no further action is required.

D. D. Sharpe
D. D. SHARPE
Acting

Copy to:
BMaintO
SupvyChemist

CLW

0000000690