

0304



North Carolina Department of Human Resources  
Division of Health Services  
P.O. Box 2091 • Raleigh, North Carolina 27602-2091

James G. Martin, Governor  
David T. Flaherty, Secretary

Ronald H. Levine, M.D., M.P.H.  
State Health Director

November 17, 1987

Colonel T. J. Dalzell  
Assistant Chief of Staff  
Facilities by Direction of Commanding General  
U.S. Marine Corps  
Camp Lejeune, North Carolina 28542-5001

Re: 6280 FAC  
"As Built" Well #615  
Camp Lejeune Marine Corps Base  
Onslow County

Dear Colonel Dalzell:

We thank you for your letter of October 15, 1987 along with the information for the referenced project. After the review, we make the following comments:

1. Three (3) copies of "Application for Approval..." forms must be properly completed and signed, then submitted to this office.
2. Three (3) copies of revised plans and detailed specifications must be prepared by a Professional Engineer licensed to practice in the State of North Carolina. The plans and specifications shall bear an imprint of the registration seal of the engineer.
3. The chemical analysis must be done by the Laboratory that's certified by N.C. Division of Health Services. The chemical test results must include 24 parameters.
4. The bacteriological test must be done by the Laboratory that's certified by N.C. Division of Health Services. The result must be recorded in the company's letterhead.
5. Is the well water pumped into the water treatment plant for treatment or distributed directly to the service connection? For the latter, the chlorination is required. Details must be depicted on the drawings.

NREH

YES

We shall continue our review upon receipt of the aforementioned information and revisions. If you have any questions, please call (919) 733-2460.

CLW

0000001668

Page Two

Sincerely,



Heinrich S. Ou  
Environmental Engineer  
Plan Review Unit  
Public Water Supply Branch  
Environmental Health Section

CC: Mike Bell, Regional Engineer  
Bob Alexander

HSO/cj

**CLW**

**0000001669**