

JTB 0308



North Carolina Department of Human Resources
Division of Health Services
P.O. Box 2091 • Raleigh, North Carolina 27602-2091

James G. Mc...
David T. ...

Ronald H. Lee
Star

January 27,

[Redacted]
Deputy Assistant Chief of Staff-Facilities
Marine Corps Base
Camp Lejeune, North Carolina 28542-5001

Re: Holcom...vard Water Plant...ension
Camp... Marine Corps Base
Onslow...

Dear Mr. Elston:

Record drawings for the referenced project prepared by Henry von Oesen and Associates have been reviewed by engineers of this Section. The drawings call for the addition of fourteen new wells each with a pumping rate of 1,400-gpm and one 2,800-gpm supply system at the LeJeune Marine Corps Base and extension of Holcom...vard Water Treatment Plant. We are constructing new softeners, filter brine apparatus, chemical feeding equipment, a raw water reservoir with two (2) 1,400-gpm and two (2) 2,800-gpm centrifugal pumps, a finished water reservoir with two 2,800-gpm vertical turbine pumps, piping, valves, meters, and other appurtenances. The record drawings are approved under Division of Health Services permit number 88-01 dated January 26, 1988.

One copy of the "Application for Approval..." is enclosed. One copy of the record drawings bearing the Division of Health Services stamp of approval is being sent under separate cover to you. One copy of each is being forwarded to the Onslow County Health Department. The third copy is being retained in our permanent files.

If we can be of further service, please call on us at (919)733-2460.

Very truly yours,

James F. Stamey
James F. Stamey, Chief
Environmental Health Section

JFS:JCL:skw

Enclosures

cc: Mike Bell, Regional Engineer
Onslow County Health Department
Henry von Oesen and Associates
S. M. Gale, P. E.

CLW

0000001680