



Ronald H. Levine, M.D., M.P.H.
STATE HEALTH DIRECTOR

DIVISION OF HEALTH SERVICES
P.O. Box 2091
Raleigh, N.C. 27602-2091

June 21, 1983

Colonel J. T. Marshall
Assistant Chief of Staff, Facilities
United State Marine Corps
Camp Lejeune, North Carolina 28542

Re: Compliance Monitoring
Camp Lejeune
Onslow County

Dear Colonel Marshall:

Enclosed are the monitoring reports for trihalomethane, inorganic chemical, sodium and corrosivity. We appreciate the summary format in which you submitted the data; however, such a format does not contain all of necessary information required by this office.

According to the information you supplied, Grainger Laboratory conducted almost all the analyses. Please submit to this office the forms on which Grainger Laboratory submitted the analytical results to you. Grainger Laboratory should have submitted the results of these tests on a form which is similar to the enclosed blank forms.

If you have any questions about the enclosed forms, please do not hesitate to contact me at telephone (919) 733-2321.

Sincerely,

Wm. Larry Elmore
Environmental Engineer
Water Supply Branch
Environmental Health Section

WLE:spm

Enclosures

CLW

0000005096



UNITED STATES MARINE CORPS
MARINE CORPS BASE
CAMP LEJEUNE, NORTH CAROLINA 28542

IN REPLY REFER TO
NREAD/DDS/th
11300

JUN 1 1983



Mr. Charles E. Rundgren, Head
Water Supply Branch
Division of Health Services
Post Office Box 2091
Raleigh, North Carolina 27602-2091

Dear Mr. Rundgren:

Enclosed are results of Inorganic Chemical and Corrosivity Analyses conducted during 1982 for all eight water treatment plants aboard Marine Corps Base, Camp Lejeune, as required by the Safe Drinking Water Act. Also enclosed is a table showing the construction materials used in each distribution system.

The laboratory analysis was run by Grainger Laboratories, Incorporated, Raleigh, North Carolina. The field analyses (temperature and pH) were run by personnel of the Quality Control Laboratory located in the Natural Resources and Environmental Affairs Division, Assistant Chief of Staff, Facilities. Ms. Elizabeth Betz, Quality Control Laboratory, telephone (919) 451-5977, is the point of contact in this matter.

Sincerely,

J. T. MARSHALL
Colonel, U. S. Marine Corps
Assistant Chief of Staff, Facilities
By direction of the Commanding General

Encl:

- (1) Inorganic Chemical Results
- (2) Corrosivity Results
- (3) Construction Materials System

Copy to:
CMDR, NAVFACENCOM (Code 114)

CLW

0000005097

INORGANIC CHEMICAL RESULTS (mg/l) FOR SERIAL NO. 04-67-041 thru 048

Parameter	Method	Containment Code	041 042 043 044 045 046 047 048															
			041	042	043	044	045	046	047	048								
Arsenic	123	1005	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	
Barium	101	1010	0.01	0.04	0.03	0.01	0.04	0.04	0.04	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	
Cadmium	101	1015	0.0011	0.0005	0.0005	0.0005	0.0005	0.0005	0.0005	0.0005	0.0005	0.0011	0.0005	0.0005	0.0005	0.0005	0.0005	
Chromium	101	1020	0.003	0.003	0.003	0.003	0.003	0.017	0.004	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.003	
Fluoride	107	1025	0.994	0.24	0.856	1.00	0.139	0.126	0.109	0.146	0.146	0.146	0.146	0.146	0.146	0.146	0.146	
Lead	101	1030	0.01	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	
Mercury	103	1035	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	
Nitrate (N)	109	1040	0.17	0.05	0.11	0.05	0.05	0.05	0.05	0.11	0.05	0.11	0.05	0.05	0.11	0.05	0.05	
Selenium	123	1045	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	0.002	
Silver	101	1050	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	
Iron	101	1028	0.045	0.338	0.037	0.020	0.673	0.544	0.536	0.556	0.556	0.556	0.556	0.556	0.556	0.556	0.556	
Manganese	101	1032	0.002	0.004	0.002	0.006	0.015	0.030	0.011	0.025	0.025	0.025	0.025	0.025	0.025	0.025	0.025	
Sodium	101	1052	20.7	79.8	24.4	19.8	81.9	88.7	81.5	66.4	66.4	66.4	66.4	66.4	66.4	66.4	66.4	

All Samples Collected (Except Sodium): 29 September 1982
 Sodium Samples Collected: 3 September 1982

All Results Run by Grainger Laboratories (ID# 37709)

CLW
 000005098



CORROSIIVITY RESULTS FOR SERIAL NO. 04-67-041 thru 048

<u>PARAMETER</u>	<u>METHOD</u>	<u>CONTAMINANT CODE</u>	<u>041</u>	<u>042</u>	<u>043</u>	<u>044</u>	<u>045</u>	<u>046</u>	<u>047</u>	<u>048</u>
pH	135	1925	8.8	7.6	8.2	8.2	7.1	8.0	7.9	7.1
Temperature °C	130	1996	20.0	20.0	19.0	20.0	20.0	23.0	21.0	21.0
Total Alkalinity As CaCO ₃ mg/l	142	1927	51.9	136	82.3	76.4	166	151	164	155
Total Filterable Residue mg/l	139	1930	106	320	10	152	126	230	246	140
Calcium As CaCO ₃ mg/l	101	1919	40.9	48.0	56.1	101	41.9	44.3	50.0	111
Stability Index (Langelier)	140	1910	0.25	-0.59	0.03	0.19	-0.95	0.06	-0.12	-0.54

All samples collected: 3 September 1982

pH & temperature run by Quality Control Laboratory (ID #37807)

The rest of the results run by Grainger Lab (ID #37709)



CLW

0000005099