ROUTINE REPLY, ENDORSEMENT, TRANSMI[illegible] OR INFORMATION SHEET
NAVEXOS-3989 (Rev. 12-62)

0104 901 4901

THMs

DATE 15 JUL 85

FROM: CANTDIV CODE 1142

FILE NUMBER: 6280 1142DPG

SUBJECT: VOA/THM

REFERENCE:

TO: MCB CAMP LEJEUNE
BASE MAINTENANCE
ENVIRONMENTAL AFFAIRS
DIVISION

ENCLOSURE: (1) JIK REPORTS #92, #93, #97 (REC'D 15 JUL 85)

WELL + HP + TT TREATED

This form may be used in a window envelope.

VIA

____ Endorsement on

☒ FORWARDED ☐ RETURNED ☐ FOLLOW-UP ☐ REQUEST ☐ ADVISE ☐ SUBMIT

X	MESSAGE	X	MESSAGE	X	MESSAGE
X	FOR APPROPRIATE ACTION		SUBJECT DOCUMENT(S) WAS/WERE FORWARDED TO YOUR OFFICE ____ AS A MATTER UNDER YOUR JURISDICTION.		CERTIFY ENCLOSURE ____ AS TO RECEIPT AND ACCEPTANCE OF MATERIAL AND FORWARD TO ____
	FOR INFORMATION OR CERTIFICATION AND/OR FILE.		SUBJECT DOCUMENTS WAS/WERE APPROVED ____ AND FORWARDED TO YOU.		____ COPIES OF SUBJECT CHANGE ORDER AMENDMENT OR MODIFICATION
	☐ APPROVED ☐ DISAPPROVED		____ COPY(IES) OF THIS CORRESPONDENCE WITH YOUR REPLY.		CHANGE NOTICE TO THE SUPPLIER
	APPROVAL ☐ IS ☐ IS NOT RECOMMENDED		ENCLOSURE(S) ____ IS/ARE FORWARDED AS REQUESTED BY REFERENCE ____		____ COPIES OF APPLICABLE PLANS AND/OR SPECIFICATIONS.
	CONCURRING IN RECOMMENDATIONS MADE IN THE BASIC CORRESPONDENCE.		ENCLOSURE(S) IS/ARE RETURNED FOR CORRECTION AS INDICATED.		FOR PLAN ACTION AS INDICATED
	COMMENTS AND/OR RECOMMENDATIONS.		CORRECTED ENCLOSURE(S) AS REQUESTED		CLASSIFICATIONS OF DEFECTS FOR SUBJECT ITEMS
	MAILING LIST ACTION		SUBJECT PERSON'S ATTENTION SHOULD BE INVITED TO THIS MATTER		CONFIRMATION THAT INSPECTION OR SOURCE INSPECTION IS NOT REQUIRED
	FOR ASSIGNMENT OF BUREAU FILE NUMBER(S)		SUBJECT PERSON(S) REPORTED TO THIS COMMAND ____		INSPECTION UNDER THE SUBJECT SUBCONTRACT IS NOT REQUIRED
	ON A LOAN BASIS RETURN BY ____		SUBJECT PERSON(S) COMPLETED HIS/THEIR DUTY AND WAS/WERE DETACHED FROM THIS COMMAND ____		____ COPIES OF SUBJECT PURCHASE DOCUMENT, IF SOURCE INSPECTION OR PROGRESSING IS REQUIRED
	SIGN ORIGINAL RECEIPT AND RETURN TO THIS OFFICE.		NAME AND LOCATION OF SUPPLIER OF SUBJECT ITEMS.		STATUS OF MATERIAL ON SUBJECT PURCHASE DOCUMENT
	SUBJECT FILES, WHICH ARE LOCATED IN BOX NO. ____ SHIPMENT NO. ____		SUBCONTRACT NUMBER FOR SUBJECT ITEM		CLEARANCE AS INDICATED IN BASIC CORRESPONDENCE VERIFIED. NO REPLY UNLESS NEGATIVE.
	REPLY TO THE ABOVE REFERENCE(S) BY ____		SUBJECT PURCHASE DOCUMENT HAS BEEN REQUESTED AND WILL BE FORWARDED WHEN RECEIVED.		VERIFICATION OF NEED-TO-KNOW FOR VISIT PERSONNEL CLEARANCES VERIFIED.
	____ COPY(IES) OF REFERENCE DESCRIBED ABOVE WAS/WERE NOT RECEIVED.		ENDORSEMENT ____ OF SUBJECT SUBCONTRACT IS BEING DELAYED PENDING RECEIPT OF BASIC PURCHASE DOCUMENT.		
	SUBJECT DOCUMENT(S) WAS/WERE FORWARDED TO ____		APPROPRIATION SYMBOL SUBHEAD AND CHARGEABLE ACTIVITY		
	SUBJECT DOCUMENT(S) IS/ARE WAS/WERE RETURNED FOR ____		WHETHER SUBJECT ITEMS ARE TO BE COMMERCIALLY SHIPPED OR AT GOVERNMENT EXPENSE		
			A CERTIFICATE IN LIEU OF SUBJECT BILL OF LADING WHICH HAS BEEN LOST.		SEE REMARKS ON THE REVERSE SIDE.

TO: 114, 1142, 1145

SIGNATURE: David Gooden

Government Printing Office: 1973—739-007/2082 Region No. 3-11

CLW

0000005131

REPORT # 93

LABORATORY ANALYSIS ON

NAVAL SAMPLES

(A/E CONTRACT N62470-84-B-6932)

JTC REPORT # 85-276

PREPARED FOR:

DEPARTMENT OF THE NAVY

ATLANTIC DIVISION

NAVAL FACILITIES ENGINEERING COMMAND

NORFOLK, VA 23511

PREPARED BY:

JTC ENVIRONMENTAL CONSULTANTS, INC.

4 RESEARCH PLACE, SUITE L-10

ROCKVILLE, MARYLAND 20850

JULY 11, 1985

Ann E. Rosecrance

Ann E. Rosecrance
Laboratory Director

CLW
0000005132

CLW

JTC Environmental Consultants, Inc. 0000005133

Date 7-11-85 Report No. 93 to Naval Facilities Engineering Command, Norfolk, Virginia

JTC Data Report No. 85-276 Table 1 Date of Sample Receipt 7-5-85

NAVY SAMPLE ID	JTC SAMPLE ID	ANALYSIS PARAMETER							
		VOA							
AS 110 12:00	12-1132	see attached sheet							
AS 2800 12:45	12-1133	"							

CLW

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET 0000005134

VOLATILE FRACTION

JTC SAMPLE # 12-1132 PROJECT NO. NF-12

NAVY SAMPLE # AS-110 DATE RECEIVED 7/5/85

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropropylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloroethane	N.D.	47V bromoform	61 ~~N.D.~~
13V 1,1-dichloroethane	N.D.	48V dichlorobromomethane	2* ~~N.D.~~
14V 1,1,2-trichloroethane	N.D.	49V trichlorofluoromethane	N.D.
15V 1,1,2,2-tetrachloroethane	N.D.	50V dichlorodifluoromethane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	15 ~~N.D.~~
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	3* ~~N.D.~~	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloroethylene	N.D.	88V vinyl chloride	N.D.

* Below method detection limit

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

CLW 0000005135

VOLATILE FRACTION

JTC SAMPLE # 12-1133 PROJECT NO. NF-12

NAVY SAMPLE # AS 2800 DATE RECEIVED 7/5/85

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropropylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloroethane	N.D.	47V bromoform	147 ~~N.D.~~
13V 1,1-dichloroethane	N.D.	48V dichlorobromomethane	9* ~~N.D.~~
14V 1,1,2-trichloroethane	N.D.	49V trichlorofluoromethane	N.D.
15V 1,1,2,2-tetrachloroethane	N.D.	50V dichlorodifluoromethane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	47 ~~N.D.~~
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	3* ~~N.D.~~	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloroethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

* Below method detection limit

REPORT # 97

LABORATORY ANALYSIS ON

NAVAL SAMPLES

(A/E CONTRACT N62470-84-B-6932)

JTC REPORT # 85-278

PREPARED FOR:

DEPARTMENT OF THE NAVY

ATLANTIC DIVISION

NAVAL FACILITIES ENGINEERING COMMAND

NORFOLK, VA 23511

PREPARED BY:

JTC ENVIRONMENTAL CONSULTANTS, INC.

4 RESEARCH PLACE, SUITE L-10

ROCKVILLE, MARYLAND 20850

JULY 11, 1985

Ann E Rosecrance

Ann E. Rosecrance
Laboratory Director

CLW

0000005136

CLW

0000005137

JTC Environmental Consultants, Inc.

Date 7/11/85 Report No. 97 to Naval Facilities Engineering Command, Norfolk, Virginia

JTC Data Report No. 85-278 Table 1 Date of Sample Receipt 7-10-85

NAVY SAMPLE ID	JTC SAMPLE ID	ANALYSIS PARAMETER							
		VOA	THM						
HP Treated 7/8/85 11:25	12-1205	See attached Sheet	X						
" Treated 7/8/85 11:52	12-1206	"	X						
490	12-1207	X	See attached Sheet						
491	12-1208	X	"						
492	12-1209	X	"						
493	12-1210	X	"						
494	12-1211	X	"						
495	12-1212	X	"						

CLW

0000005138

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1205 PROJECT NO. NF-12

NAVY SAMPLE # HP Treated 7/8/85 DATE RECEIVED 7/10/85

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropropylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloroethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromomethane	8* ~~N.D.~~
14V 1,1,2-trichloroethane	N.D.	49V trichlorofluoromethane	N.D.
15V 1,1,2,2-tetrachloroethane	N.D.	50V dichlorodifluoromethane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	6* ~~N.D.~~
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	13 ~~N.D.~~	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloroethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

* Below method detection limit

CLW

0000005139

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1206 PROJECT NO. NF-12

NAVY SAMPLE # IT Treated 7/8/85 DATE RECEIVED 7/10/85

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropropylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloroethane	N.D.	47V bromoform	~~N.D.~~ 6
13V 1,1-dichloroethane	N.D.	48V dichlorobromomethane	~~N.D.~~ 3
14V 1,1,2-trichloroethane	N.D.	49V trichlorofluoromethane	N.D.
15V 1,1,2,2-tetrachloroethane	N.D.	50V dichlorodifluoromethane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	~~N.D.~~ 10
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	~~N.D.~~ 3*	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloroethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

* Below method detection limit

CLW

0000005140

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1207 PROJECT NO. NF-12

NAVY SAMPLE # 490 DATE RECEIVED 7/10/85

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropropylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloroethane	N.D.	47V bromoform	N.D.
13V 1,1-dichloroethane	N.D.	48V dichlorobromomethane	8 * ~~N.D.~~
14V 1,1,2-trichloroethane	N.D.	49V trichlorofluoromethane	N.D.
15V 1,1,2,2-tetrachloroethane	N.D.	50V dichlorodifluoromethane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	6 * ~~N.D.~~
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	15 ~~N.D.~~	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloroethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

* Below method detection limit

CLW

0000005141

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1208 PROJECT NO. NF-12

NAVY SAMPLE # 491 DATE RECEIVED 7/10/85

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropropylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloroethane	N.D.	47V bromoform	~~N.D.~~ 52
13V 1,1-dichloroethane	N.D.	48V dichlorobromomethane	~~N.D.~~ 2*
14V 1,1,2-trichloroethane	N.D.	49V trichlorofluoromethane	N.D.
15V 1,1,2,2-tetrachloroethane	N.D.	50V dichlorodifluoromethane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	~~N.D.~~ 15
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	~~N.D.~~ 2*	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloroethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

* Below method detection limit

CLW
0000005142

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1209 PROJECT NO. NF-12

NAVY SAMPLE # 492 DATE RECEIVED 7/10/85

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropropylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloroethane	N.D.	47V bromoform	~~N.D.~~ 170
13V 1,1-dichloroethane	N.D.	48V dichlorobromomethane	~~N.D.~~ 7*
14V 1,1,2-trichloroethane	N.D.	49V trichlorofluoromethane	N.D.
15V 1,1,2,2-tetrachloroethane	N.D.	50V dichlorodifluoromethane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	~~N.D.~~ 42
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	~~N.D.~~ 3*	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloroethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

* Below method detection limit

CLW
0000005143

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1210 PROJECT NO. NF-12

NAVY SAMPLE # 493 DATE RECEIVED

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropropylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloroethane	N.D.	47V bromoform	~~N.D.~~ 143
13V 1,1-dichloroethane	N.D.	48V dichlorobromomethane	~~N.D.~~ 6*
14V 1,1,2-trichloroethane	N.D.	49V trichlorofluoromethane	N.D.
15V 1,1,2,2-tetrachloroethane	N.D.	50V dichlorodifluoromethane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	~~N.D.~~ 32
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	~~N.D.~~ 3*	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloroethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

* Below method detection limit

CLW

0000005144

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1211 PROJECT NO. NF-12

NAVY SAMPLE # 494 DATE RECEIVED 7/10/85

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropropylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloroethane	N.D.	47V bromoform	163 ~~N.D.~~
13V 1,1-dichloroethane	N.D.	48V dichlorobromomethane	4* ~~N.D.~~
14V 1,1,2-trichloroethane	N.D.	49V trichlorofluoromethane	N.D.
15V 1,1,2,2-tetrachloroethane	N.D.	50V dichlorodifluoromethane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	31 ~~N.D.~~
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	2* ~~N.D.~~	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloroethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

*Below method detection limit

CLW

0000005145

JTC ENVIRONMENTAL CONSULTANTS, INC.
PRIORITY POLLUTANT ANALYSIS DATA SHEET

VOLATILE FRACTION

JTC SAMPLE # 12-1212 PROJECT NO. NF-12

NAVY SAMPLE # 495 DATE RECEIVED

METHOD NO. 624 DETECTION LIMIT 10 ug/lit

PARAMETER	RESULT ug/lit	PARAMETER	RESULT ug/lit
2V acrolein	N.D.	32V 1,2-dichloropropane	N.D.
3V acrylonitrile	N.D.	33V 1,3-dichloropropylene	N.D.
4V benzene	N.D.	38V ethylbenzene	N.D.
6V carbon tetrachloride	N.D.	44V methylene chloride	N.D.
7V chlorobenzene	N.D.	45V methyl chloride	N.D.
10V 1,2-dichloroethane	N.D.	46V methyl bromide	N.D.
11V 1,1,1-trichloroethane	N.D.	47V bromoform	173 ~~N.D.~~
13V 1,1-dichloroethane	N.D.	48V dichlorobromomethane	5* ~~N.D.~~
14V 1,1,2-trichloroethane	N.D.	49V trichlorofluoromethane	N.D.
15V 1,1,2,2-tetrachloroethane	N.D.	50V dichlorodifluoromethane	N.D.
16V chloroethane	N.D.	51V chlorodibromomethane	33 ~~N.D.~~
19V 2-chloroethylvinyl ether	N.D.	85V tetrachloroethylene	N.D.
23V chloroform	2* ~~N.D.~~	86V toluene	N.D.
29V 1,1-dichloroethylene	N.D.	87V trichloroethylene	N.D.
30V 1,2-trans-dichloroethylene	N.D.	88V vinyl chloride	N.D.

N.D. = NOT DETECTED
N.A. = NOT APPLICABLE/ANALYZED

* Below method detection limit