

(3) If at any time during which reduced monitoring frequency prescribed under this paragraph applies, the results from any analysis exceed 0.10 mg/l of TTHMs and such results are confirmed by at least one check sample taken promptly after such results are received, or if the system makes any significant change to its source of water or treatment program, the system shall immediately begin monitoring in accordance with the requirements of paragraph (b)(1) of this section, which monitoring shall continue for at least 1 year before the frequency may be reduced again. At the option of the State, a system's monitoring frequency may and should be increased above the minimum in those cases where it is necessary to detect variations of TTHM levels within the distribution system.

(c)(1) Upon written request to the State, a community water system utilizing only ground water sources may seek to have the monitoring frequency required by subparagraph (1) of paragraph (b) of this section reduced to a minimum of one sample for maximum TTHM potential per year for each treatment plant used by the system taken at a point in the distribution system reflecting maximum residence time of the water in the system. The system shall submit to the State the results of at least one sample analyzed for maximum TTHM potential for each treatment plant used by the system taken at a point in the distribution system reflecting the maximum residence time of the water in the system. The system's monitoring frequency may only be reduced upon a written determination by the State that, based upon the data submitted by the system, the system has a maximum TTHM potential of less than 0.10 mg/l and that, based upon an assessment of the local conditions of the system, the system is not likely to approach or exceed the maximum contaminant level for total TTHMs. The results of all analyses shall be reported to the State within 30 days of the system's receipt of such results. Results shall also be reported to EPA until such monitoring requirements have been adopted by the State. All samples collected shall be used for determining whether the system must comply with the monitoring requirements of paragraph (b) of this section, unless the analytical results are invalidated for technical reasons. Sampling and analyses shall be conducted in accordance with the methods listed in paragraph (e) of this section.

(2) If at any time during which the reduced monitoring frequency

prescribed under paragraph (c)(1) of section applies, the results from any analysis taken by the system for maximum TTHM potential are equal to or greater than 0.10 mg/l, and such results are confirmed by at least one check sample taken promptly after such results are received, the system shall immediately begin monitoring in accordance with the requirements of paragraph (b) of this section and such monitoring shall continue for at least one year before the frequency may be reduced again. In the event of any significant change to the system's raw water or treatment program, the system shall immediately analyze an additional sample for maximum TTHM potential taken at a point in the distribution system reflecting maximum residence time of the water in the system for the purpose of determining whether the system must comply with the monitoring requirements of paragraph (b) of this section. At the option of the State, monitoring frequencies may and should be increased above the minimum in those cases where this is necessary to detect variation of TTHM levels within the distribution system.

(d) Compliance with § 141.12(c) shall be determined based on a running annual average of quarterly samples collected by the system as prescribed in subparagraphs (1) or (2) of paragraph (b) of this section. If the average of samples covering any 12 month period exceeds the Maximum Contaminant Level, the supplier of water shall report to the State pursuant to § 141.31 and notify the public pursuant to § 141.32. Monitoring after public notification shall be at a frequency designated by the State and shall continue until a monitoring schedule as a condition to a variance, exemption or enforcement action shall become effective.

(e) Sampling and analyses made pursuant to this section shall be conducted by one of the following EPA approved methods:

(1) "The Analysis of Trihalomethanes in Finished Waters by the Purge and Trap Method," Method 501.1, EMSL, EPA Cincinnati, Ohio.

(2) "The Analysis of Trihalomethanes in Drinking Water by Liquid/Liquid Extraction," Method 501.2, EMSL, EPA Cincinnati, Ohio.

Samples for TTHM shall be dechlorinated upon collection to prevent further production of Trihalomethanes, according to the procedures described in the above two methods. Samples for maximum TTHM potential should not be dechlorinated, and should be held for seven days at 25° C prior to analysis.

according to the procedures described in the above two methods.

(f) Before a community water system makes any significant modifications to its existing treatment process for the purposes of achieving compliance with § 141.12(c), such system must submit and obtain State approval of a detailed plan setting forth its proposed modification and those safeguards that it will implement to ensure that the bacteriological quality of the drinking water served by such system will not be adversely affected by such modification. Each system shall comply with the provisions set forth in the State-approved plan. At a minimum, a State approved plan shall require the system modifying its disinfection practice to:

(1) Evaluate the water system for sanitary defects and evaluate the source water for biological quality;

(2) Evaluate its existing treatment practices and consider improvements that will minimize disinfectant demand and optimize finished water quality throughout the distribution system;

(3) Provide baseline water quality survey data of the distribution system. Such data should include the results from monitoring for coliform and fecal coliform bacteria, fecal streptococci, standard plate counts at 35° C and 20° C, phosphate, ammonia nitrogen and total organic carbon. Virus studies should be required where source waters are heavily contaminated with sewage effluent;

(4) Conduct additional monitoring to assure continued maintenance of optimal biological quality in finished water, for example, when chloramines are introduced as disinfectants or when pre-chlorination is being discontinued. Additional monitoring should also be required by the State for chlorate, chlorite and chlorine dioxide when chlorine dioxide is used as a disinfectant. Standard plate count analyses should also be required by the State as appropriate before and after any modifications;

(5) Demonstrate an active disinfectant residual throughout the distribution system at all times during and after the modification.

This paragraph (f) shall become effective on the date of its promulgation.

CLW

000006452